

PROPOSED SUBSTANTIVE CHANGES TO RULE R309-540

Rule R309-540, *Facility Design and Operation: Pump Stations*, was last amended on February 15, 2009. The Division of Drinking Water is requesting authorization to make substantive changes to the organization and content of the rule to make its requirements more accurate and easier to understand. Because of the substantial reorganization of the rule, a conventional marked-up version of the proposed changes would be difficult to follow. Therefore, the Division proposes repeal and re-enactment; the current rule would be repealed in its entirety, and an amended rule would be re-enacted in its place.

The proposed changes to R309-540 include the following:

- Some titles have been revised to more accurately reflect their content
- Previously un-numbered paragraphs have been numbered for ease of reference
- Unnecessary or inaccurate requirements have been deleted
- New requirements have been added where needed
- Most of the requirements of the current rule are also present in the amendment but they are organized differently
- The reorganization is intended to group like requirements together, which in addition to being more logical should also prove to be more useful
- General requirements that apply to all pumping facilities (pumps, pump stations, and hydropneumatic systems) are gathered together in one section of the amendment (R309-540-4, *General*)
- The requirements found in R309-540-5, *Pumping Facilities*, in the current rule have been distributed among three sections in the amendment:
 1. R309-540-5, *Pumps*
 2. R309-540-6, *Booster Pumps Serving the Distribution System*
 3. R309-540-7, *Pump Stations*
- The section entitled *Hydropneumatic Systems*, R309-540-6 in the current rule, retains much of its original organization in the amendment but unnecessary requirements have been deleted and some of the retained requirements have been reworded

Two versions of the R309-540 amendment are enclosed:

- **The Division of Administrative Rules (DAR) Version:** DAR maintains the official version of rules and oversees the rulemaking process. The official rulemaking document for R309-540 is in the format required by DAR. The DAR format has limited formatting, uses strikeouts for deleted words, and underlines added words. In this case, because the current rule is being repealed, the entire rule is struck through and the amendment is entirely underlined.
- **The Division of Drinking Water Version:** DDW provides a separate version of the rule to the public. The rule content of the DDW version is the same as the DAR version. However, the DDW version is formatted for easier reading and contains DDW's interpretations of the

rule (in the form of guidance paragraphs). The guidance paragraphs are not part of the official rule. In this case, the repealed rule is struck through and the amendment is shown without underling for ease of reading.

Staff Recommendation: Because the proposed changes are substantive, the staff recommends **that the Board authorize Division staff to begin the rulemaking process to repeal and re-enact R309-540 and to file the proposed rule for publication in the Utah State Bulletin on August 1, 2016.**

Key to Proposed Revisions to R309-540, *Facility Design and Operation: Pump Stations*.

Because of the substantial reorganization of the R309-540, a conventional marked-up version of the current rule showing the changes would be difficult to follow. Therefore, the Drinking Water Board packet includes copies of the current rule, to be repealed, shown struck through and the proposed amendment, to be re-enacted, with no changes shown. To aid in the Board's review, the differences between the current rule and the amendment are summarized below.

Unchanged Sections

The following two sections are unchanged and remain the same in the current rule and the amendment:

1. R309-540-2. Authority.
2. R309-540-3. Definitions.

Deleted Requirements

The following requirements included in the current rule have been deleted and are not included in the amendment:

1. Deleted the requirement that a pump station site protect against interruption of service by fire, flood, or other hazards
2. Deleted the requirement that pump stations be protected against entry by animals and unauthorized persons, and replaced it with the requirement that pump stations be protected against unauthorized entry
3. Deleted the requirement that pump station buildings be fire and weather resistant because it is difficult to determine how this requirement would be met
4. Deleted the requirement that interior floors of pump stations be sloped at least one percent
5. Deleted the requirement that drainage from pump glands be provided with an outlet to prevent discharge to the floor, and replaced it with a requirement that a means for handling the drainage be provided
6. Deleted the requirement that wet wells have two pumping compartments to allow the well to be taken out of service for inspection, maintenance, or repair
7. Deleted the requirement that pump stations have specific equipment, such as crane ways, hoist beams, eyebolts; openings in floors and roofs; and tool boards, for equipment maintenance, and replaced it with a general requirement that provisions be made to service or remove heavy or bulky equipment
8. Deleted the requirement concerning sanitary plumbing at pump stations and the discharge of wastes
9. Deleted the requirement that pumping units be provided with readily available spare parts and tools
10. Deleted the requirement that recording gauges be installed in "larger stations"

11. Deleted the requirement that community and non-transient non-community water systems provide unpressurized storage in addition to pressurized storage because it repeats the requirements of R309-510, *Minimum Sizing Requirements*
12. Deleted the requirement that minimum pressure be provided in the distribution system because it is already covered in another rule (R309-105-9, *Minimum Water Pressure*)
13. Deleted the requirement that pressure tanks meet state and local laws for manufacture and installation but retained the requirement that they comply with NSF 61
14. Deleted the formula for calculating the minimum volume of a pressure tank based on pump operating cycle, pump output capacity, percent of volume withdrawn during a given pressure drop, and the water seal volume
15. Deleted the requirement that the method of adjusting the air volume in an air-over-water pressure tank be acceptable to the Director
16. Deleted the requirement that an air intake be at least 10 feet above the ground and replaced it with a requirement that the air source be free of contamination
17. Deleted a separate standby power requirement for hydropneumatic systems because it is now in R309-540-4, *General*, which applies to all pumps

Added Requirements

The following requirements, not included in the current rule, were added to the amendment:

1. Added the requirement that pumps not serving the distribution system meet the “desired operating conditions”
2. Added clarification that foot valves are used in wet wells
3. Added a requirement that piping restraints be provided if necessary to protect piping from water surge or water hammer
4. Added the provision that in place of a standard pressure gauge an alternative means of measuring pressure may be installed on a pump station discharge line
5. Added the provision that in place of a compound gauge an alternative means of measuring pressure may be installed on the suction line
6. Added the clarification that standby power is only required at community water systems that do not have naturally flowing water sources and rely on pumps for water distribution
7. Added the requirement that hydropneumatic tanks be located above ground if possible (this used to be guidance in the DDW version of the rule)
8. Added the requirement that hydropneumatic tanks be sized to avoid excessive pump cycling

Changes

The following requirements, included in the current rule, were changed when transferred to the amendment:

1. The title of the rule is changed from *Pump Stations*, which is a specific type of pumping facility, to *Pumping Facilities*, which is a more general term
2. In R309-500-1, *Purpose*, the reference to “pumping facilities” is replaced with “pump stations” for the same reason that the title of the rule was changed

3. Reworded the requirement that space in pump stations be adequate for installing new pumps and servicing equipment
4. The term “suction wells” was replaced with “wet wells”
5. Reworded specific requirements for handrails and treads on steps in pump stations
6. Combined the heating and lighting requirements for pump stations
7. Replaced the requirement that forced ventilation be provided in pump stations for any area where an unsafe atmosphere or excessive heat may build up with the requirement that forced ventilation be provided where unsafe conditions may develop
8. Rewrote the requirement that pumps be capable of meeting peak day demand
9. Instead of requiring the pumping unit to meet peak day demand against the required distribution pressure without dangerous overloading, the rule now requires pump motors to be sized to meet desired operating conditions without dangerous overloading
10. Made minor changes to clarify pump priming requirements
11. Rewrote the requirement for a minimum of two pumping units for inline booster pumps
12. Reworded and clarified the prohibition against “home booster pumps” to prohibit “service connection booster pumps” used to meet minimum pressure requirements
13. Revised the language requiring isolation valves at pumping facilities but did not change requirements
14. Changed the requirement for a pressure gauge on each pump discharge line to the requirement for a pressure gauge on the pump station discharge line only
15. Made minor wording changes to the requirements for provisions to prevent surge pressures from activating controls at pumping facilities; the requirements remain unchanged however
16. Revised the language prohibiting community water systems from counting hydropneumatic tanks towards water storage requirements
17. Changed references from “diaphragm or air tanks” to “pressure tanks” in R309-540-8, *Hydropneumatic Systems*
18. Replaced the requirement that a pressure gauge be installed on the pressure tank inlet line with a requirement that operating pressures of a hydropneumatic tank be monitored by some means
19. The term “non-diaphragm” pressure tanks was replaced with the term “air-over-water” pressure tanks
20. Minor changes were made to words and terms concerning the water seal in air-over-pressure tanks but the requirements were not changed

R309-540. Facility Design and Operation: Pump Stations

- **DDW Version for Repeal and Re-enact**

~~[R309-540. Facility Design and Operation: Pump Stations.~~

~~R309-540-1. Purpose.~~

~~The purpose of this rule is to provide specific requirements for pump stations utilized to deliver drinking water to facilities of public water systems. It is intended to be applied in conjunction with rules R309-500 through R309-550. Collectively, these rules govern the design, construction, operation and maintenance of public drinking water system facilities. These rules are intended to assure that such facilities are reliably capable of supplying adequate quantities of water which consistently meet applicable drinking water quality requirements and do not pose a threat to general public health.~~

~~R309-540-2. Authority.~~

~~This rule is promulgated by the Drinking Water Board as authorized by Title 19, Environmental Quality Code, Chapter 4, Safe Drinking Water Act, Subsection 104(1)(a)(ii) of the Utah Code and in accordance with 63G-3 of the same, known as the Administrative Rulemaking Act.~~

~~R309-540-3. Definitions.~~

~~Definitions for certain terms used in this rule are given in R309-110 but may be further clarified herein.~~

~~R309-540-4. General.~~

~~Pumping stations shall be designed to maintain the sanitary quality of water and to provide ample quantities of water at sufficient pressure.~~

~~R309-540-5. Pumping Facilities.~~

~~(1) Location.~~

~~(a) The pumping station shall be designed such that:~~

~~(i) the proposed site will meet the requirements for sanitary protection of water quality, hydraulics of the system, and protection against interruption of service by fire, flood or any other hazard;~~

~~***Guidance: Subsurface pits or pump rooms and inaccessible installations should be avoided.***~~

~~(ii) the access to the pump station shall be six inches above the surrounding ground and the station located at an elevation which is a~~

~~minimum of three feet above the 100-year flood elevation, or three feet above the highest recorded flood elevation, which ever is higher, or protected to such elevations;~~

~~(iii) the station is readily accessible at all times unless permitted to be out of service for the period of inaccessibility;~~

~~(iv) surrounding ground is graded so as to lead surface drainage away from the station; and~~

~~(v) the station is protected to prevent vandalism and entrance by animals or unauthorized persons.~~

(2) Pumping Stations.

~~(a) Building structures for both raw and drinking water shall:~~

~~(i) have adequate space for the installation of additional pumping units if needed, and for the safe servicing of all equipment;~~

~~(ii) be of durable construction, fire and weather resistant, with outward-opening doors;~~

~~(iii) have an interior floor elevation at least six inches above the exterior finished grade;~~

~~(iv) have any underground facilities, especially wet wells, waterproofed;~~

~~(v) have all interior floors drained in such a manner that the quality of drinking water contained in any wet wells will not be endangered. All floors shall slope at least one percent (one foot every 100 feet) to a suitable drain; and~~

~~(vi) provide a suitable outlet for drainage from pump glands without discharging onto the floor.~~

~~(b) Suction wells shall:~~

~~(i) be watertight;~~

~~(ii) have floors sloped to permit removal of water and entrained solids;~~

~~(iii) be covered or otherwise protected against contamination; and~~

~~(iv) have two pumping compartments or other means to allow the suction well to be taken out of service for inspection, maintenance, or repair.~~

~~(c) Servicing equipment shall consist of:~~

~~(i) crane ways, hoist beams, eyebolts, or other adequate facilities for servicing or removal of pumps, motors or other heavy equipment;~~

~~(ii) openings in floors, roofs or wherever else needed for removal of heavy-~~

~~or bulky equipment; and~~

~~(iii) a convenient tool board, or other facilities as needed, for proper maintenance of the equipment.~~

~~(d) Stairways and ladders shall:~~

~~(i) be provided between all floors, and in pits or compartments which must be entered; and~~

~~(ii) have handrails on both sides, and treads of non-slip material. They shall have risers not exceeding nine inches and treads wide enough for safety.~~

~~**Guidance: Ramps are preferred in areas where there is frequent traffic or where supplies are transported by hand. Where ramps are not possible, stairs are preferred to ladders.**~~

~~(e) Heating provisions shall be adequate for:~~

~~(i) the comfort of the operator; and~~

~~(ii) the safe and efficient operation of the equipment.~~

~~**Guidance: In pump houses not occupied by personnel, only enough heat need be provided to prevent freezing of equipment or treatment process.**~~

~~(f) Ventilation shall:~~

~~(i) conform to existing local and/or state codes; and~~

~~(ii) forced ventilation of at least six changes of air per hour shall be provided for all rooms, compartments, pits and other enclosures below ground floor, and any area where unsafe atmosphere may develop or where excessive heat may be built up.~~

~~**Guidance: In areas where excess moisture could cause hazards to safety or damage to equipment, means for dehumidification should be provided.**~~

~~(g) Lighting.~~

~~Pump stations shall be adequately lighted throughout. All electrical work shall conform to the requirements of the relevant state and/or local building codes.~~

~~(h) Sanitary and other conveniences.~~

~~Plumbing shall be so installed as to prevent contamination of a public water supply. Wastes shall be discharged in accordance with the plumbing code, R317-4, or R317-1-3.~~

~~(3) Pumps.~~

~~(a) Capacity.~~

~~Capacity shall be provided such that the pump or pumps shall be capable of providing the peak day demand of the system or the specific portion of the system serviced.~~

~~The pumping units shall:~~

- ~~(i) have ample capacity to supply the peak day demand against the required distribution system pressure without dangerous overloading;~~
- ~~(ii) be driven by prime movers able to meet the maximum horsepower condition of the pumps without use of service factors;~~
- ~~(iii) be provided readily available spare parts and tools; and~~
- ~~(iv) be served by control equipment that has proper heater and overload protection for air temperature encountered.~~

~~(b) Suction Lift.~~

~~Suction lift, where possible, shall be avoided. If suction lift is necessary, the required lift shall be within the pump manufacturer's recommended limits and provision shall be made for priming the pumps.~~

~~(c) Priming.~~

~~Prime water shall not be of lesser sanitary quality than that of the water being pumped. Means shall be provided to prevent back siphonage. When an air-operated ejector is used, the screened intake shall draw clean air from a point at least 10 feet above the ground or other source.~~

~~(4) Booster Pumps.~~

~~(a) Booster pumps shall be located or controlled so that:~~

- ~~(i) they will not produce negative pressure in their suction lines;~~

- ~~(ii) automatic cutoff pressure shall be at least 10 psi in the suction line;~~
- ~~(iii) automatic or remote control devices shall have a range between the start and cutoff pressure which will prevent excessive cycling; and~~
- ~~(iv) a bypass is available.~~

~~(b) Inline booster pumps (pumps withdrawing water directly from distribution lines without the benefit of storage and feeding such water directly into other distribution lines rather than storage), in addition to the other requirements of this section, shall have at least two pumping units (such that with any one pump out of service, the remaining pump or pumps shall be capable of providing the peak day demand of the specific portion of the system serviced), shall be accessible for servicing and repair and located or controlled so that the intake pressure shall be at least 20 psi when the pump or pumps are in normal operation.~~

~~(c) Individual home booster pumps shall not be allowed for any individual service from the public water supply main.~~

Guidance: Refer to Guidance found in R309-550-11(3)

~~(5) Automatic and remote controlled stations.~~

~~All remote controlled stations shall be electrically operated and controlled and shall have signaling apparatus of proven performance. Installation of electrical equipment shall conform with the applicable state and local electrical codes and the National Electrical Code.~~

Guidance: All automatic stations should be provided with automatic signaling apparatus which will report when the station is out of service.

~~(6) Appurtenances.~~

~~(a) Valves.~~

~~Valves shall be used to permit satisfactory operation, maintenance, and repair of the equipment. If foot valves are necessary, they shall have a net valve area of at least 2 1/2 times the area of the suction pipe and they shall have a positive-acting check valve on the discharge side between the pump and the shut-off valve.~~

~~(b) Piping.~~

~~Piping within and near pumping stations shall:~~

- ~~(i) be designed so that the friction losses will be minimized;~~
- ~~(ii) not be subject to contamination;~~

- ~~(iii) have watertight joints;~~
- ~~(iv) be protected against surge or water hammer; and~~
- ~~(v) be such that each pump has an individual suction line or that the lines shall be so manifolded that they will insure similar hydraulic and operating conditions.~~

~~(c) Gauges and Meters.~~

~~Each pump shall:~~

- ~~(i) have a standard pressure gauge on its discharge line;~~
- ~~(ii) Have a compound gauge (capable of indicating negative pressure or vacuum as well as positive pressure) on its suction line; and~~
- ~~(iii) have recording gauges in the larger stations.~~

~~**Guidance: Larger pumping stations should have a means for measuring the discharge. The station should have indicating, totalizing, and recording metering of the total water pumped.**~~

~~(d) Water Seal.~~

~~Where pumps utilize water seals, the seals shall:~~

- ~~(i) not be supplied with water of a lesser sanitary quality than that of the water being pumped; and~~
- ~~(ii) when pumps are sealed with potable water and are pumping water of lesser sanitary quality, the seal shall be provided with a break tank open to atmospheric pressure, and have an air gap of at least six inches or two pipe diameters, whichever is greater, between the feeder line and the spill line of the tank.~~

~~(e) Controls.~~

~~Controls shall be designed in such a manner that they will operate their prime-movers, and accessories, at the rated capacity without dangerous overload. Where two or more pumps are installed, provision shall be made for alternation. Provision shall be made to prevent energizing the motor in the event of a backspin cycle. Electrical controls shall be protected against flooding. Equipment shall be provided or other arrangements made to prevent surge pressures from activating controls which switch on pumps or activate other equipment outside the normal design cycle of operation.~~

~~(f) Standby Power.~~

~~Standby power, to ensure continuous service when the primary power has been~~

~~interrupted, shall be provided from at least two independent sources or a standby or an auxiliary source shall be provided. If standby power is provided by onsite generators or engines, the fuel storage and fuel line must be designed to protect the water supply from contamination.~~

~~(g) Water Pre-Lubrication.~~

~~When automatic pre-lubrication of pump bearings is necessary and an auxiliary direct drive power supply is provided, the pre-lubrication line shall be provided with a valved bypass around the automatic control so that the bearings can, if necessary, be lubricated manually before the pump is started or the pre-lubrication controls shall be wired to the auxiliary power supply.~~

~~R309-540-6. Hydropneumatic Systems.~~

~~(1) General.~~

~~Hydropneumatic systems shall comply with all appropriate sections of R309-540-5 except as otherwise indicated herein.~~

~~Unpressurized ground level or elevated storage, designed in accordance with R309-545, shall be provided for community type public water systems or non-transient non-community systems where a demand in excess of the capacity of the source(s) is required, in addition to the diaphragm or air tanks. Diaphragm or air pressure tank storage shall not be considered for fire protection purposes or effective system storage for community type systems.~~

~~(2) Location.~~

~~If diaphragm or air tanks and appurtenances are located below ground, adequate provisions for drainage, ventilation, maintenance, and flood protection shall be made and the electrical controls shall be located above grade so as to be protected from flooding as required by R309-540-5(6)(e). Any discharge piping from combination air release/vacuum relief valves(air/vac's) or pressure relief valves located in below ground chambers shall comply with all the pertinent requirements of R309-550-6(6).~~

~~*Guidance: It is preferred that pressure tanks and appurtenances be located above ground and be protected.*~~

~~(3) Operating Pressures.~~

~~The system shall be designed to provide minimum pressures in R309-105-9 at all points in the distribution system. A pressure gauge shall be installed on the pressure tank inlet line.~~

(4) Piping.

In addition to the bypass required by R309-540-5(4)(iv) on the pumps, the diaphragm or air tanks shall have sufficient bypass piping to permit operation of the hydropneumatic system while one or more of the tanks are being repaired, replaced or painted.

(5) Pumps.

At least two pumping units shall be provided except for those type systems not requiring unpressurized storage in R309-540-6(1); they may use the pump within their groundwater source to pressurize the diaphragm or air tanks. With any pump out of service the remaining pump or pumps shall be capable of providing the peak instantaneous demand of the system as described in R309-510-9(2), while recharging the pressure tank at 115 percent of the upper pressure setting. Pump cycling shall not exceed 15 starts per hour, with a maximum of ten starts per hour preferred.

(6) Pressure Tanks.

(a) Pressure tanks shall meet the requirement of state and local laws and regulations for the manufacture and installation of unfired pressure vessels. Interior coatings or diaphragms used in pressure tanks that will come into contact with the drinking water shall comply with ANSI/NSF Standard 61. Non-diaphragm pressure tanks shall have an access manhole, a drain, control equipment consisting of pressure gauge, water sight glass, automatic or manual air blow off, means for adding air, and pressure operated start stop controls for the pumps.

Guidance: Sizing of hydropneumatic storage tanks should consider the need for disinfectant contact time.

Guidance: For larger pressure tanks, the access manhole should be a minimum 24 inches in diameter.

(b) The minimum volume of the pressure tank or combination of tanks shall be greater than or equal to the sum of S and the value of CX divided by 4W.

Guidance: Volume (min) $\geq S + CX/4W$

where the following values are used in the equation above:

C = minutes per operating cycle, four minutes to meet the requirements of R309-540-6(5) above or preferably six minutes, and is equal to pump ON time plus pump OFF time.

X = output capacity rating of the pump(s) at the high pressure condition in the tank(s), in gpm.

W = percent of volume withdrawn during a given drop in tank pressure: specifically, between P_h and P_l . $W = 100(P_h - P_l)/P_h$ where P_h = high pressure in

tank in psia (high absolute pressure) and P_1 = low pressure in tank in psia (low absolute pressure). Values of W range typically from 0.26 to 0.31 for pressure differentials of 15 to 30 psi and high system pressures of 45 to 85 psi at elevations of approximately 5,000 feet.

S = water seal volume in gallons, the volume of inactive water remaining in tank at low pressure condition.

Guidance: As a rule-of-thumb the minimum volume of the hydropneumatic tank should be at least five times the capacity of the pump(s), rated in gpm. For example, a 200 gpm pump or combination of pumps should have a 1,000 gallon pressure tank.

(7) Air Volume.

The method of adjusting the air volume shall be acceptable to the Director. Air delivered by compressors to the pressure tank shall be adequately filtered, oil free, and be of adequate volume. Any intake shall be screened and draw clean air from a point at least 10 feet above the ground or other source of possible contamination, unless the air is filtered by an apparatus approved by the Director. Discharge piping from air relief valves shall be designed and installed with screens to eliminate the possibility of contamination from this source.

(8) Water Seal.

For air pressure tanks without an internal diaphragm the volume of water remaining in an air pressure tank at the lower pressure setting shall be sufficient to provide an adequate water seal at the outlet to prevent the leakage of air.

Guidance: To prevent the formation of a vortex, a covering baffle may be installed over a vertical bottom outlet large enough to limit the peripheral velocity of approach to the baffle to 0.5 ft/sec or less. At low absolute pressure the depth of water over the top of the baffle should be about one outlet pipe velocity head or greater. For either horizontal or vertical outlets, the pipe outlet itself should be large enough to limit the maximum axial velocity in the pipe to 4.0 ft/sec or less. The use of anti-swirl vanes is always desirable.

The following water seal depths shall be considered as minimum requirements.

(i) Horizontal outlets shall maintain sufficient depth, as measured from the centerline of the horizontal outlet pipe, such that the depth is greater than or equal to the sum of d and twice the value v^2 divided by $2G$.

(ii) Vertical outlets, if unbaffled, the depth shall be the same as in (a) except measured from the pipe outlet; if baffled, the depth shall be greater than or equal to the value v^2 divided by $2G$.

where the following values are used in the equations above:

v = the axial velocity in the pipe outlet for the peak instantaneous demand flow

~~rate of the system.~~

~~d = the diameter of the outlet pipe in ft.~~

~~G = the gravitational constant of 32.2 ft/sec/sec.~~

~~(9) Standby Power Supply.~~

~~Where a hydropneumatic system is intended to serve a public water system, categorized as a community water system as defined in R309-110, a standby source of power shall be provided.]~~

R309-540. Facility Design and Operation: Pumping Facilities.

R309-540-1. Purpose.

The purpose of this rule is to provide specific requirements for the design and operation of drinking water pumping facilities. It is intended to be applied in conjunction with rules R309-500 through R309-550. Collectively, these rules govern the design, construction, operation and maintenance of public drinking water system facilities. These rules are intended to assure that such facilities are reliably capable of supplying adequate quantities of water which consistently meet applicable drinking water quality requirements and do not pose a threat to general public health.

R309-540-2. Authority.

This rule is promulgated by the Drinking Water Board as authorized by Title 19, Environmental Quality Code, Chapter 4, Safe Drinking Water Act, Subsection 104(1)(a)(ii) of the Utah Code and in accordance with 63G-3 of the same, known as the Administrative Rulemaking Act.

R309-540-3. Definitions.

Definitions for certain terms used in this rule are given in R309-110 but may be further clarified in this rule.

R309-540-4. General.

The following requirements apply to all pumping facilities including pumps, pump stations, and hydropneumatic systems. Pumping facilities shall be adequately sized and be designed to maintain the quality of the water and to meet minimum pressure requirements.

(1) Location and Accessibility.

(a) A pumping facility shall be designed and operated to meet the following requirements:

- (i) The facility may not be located at a site that negatively affects drinking water quality.
- (ii) The site shall be compatible with the hydraulics of the water system.
- (iii) The site shall be graded to direct surface runoff away from the facility.
- (iv) The facility shall be accessible at all times unless the facility can be taken out of service during periods of inaccessibility.
- (v) The facility shall be protected from vandalism and unauthorized entry.

(2) Appurtenances.

(a) Valves.

Valves for pumping facilities shall be designed and operated to meet the following requirements.

- (i) Isolation valves shall be included for operation, maintenance, and repair of the pumping equipment.
- (ii) Foot valves in wet wells shall have a net valve area of at least 2 1/2 times the area of the suction pipe and there shall be a positive-acting check valve on the discharge side between the pump and the shut-off valve.
- (iii) The open end of a vent on an air relief valve shall be downturned and covered with a #14 mesh non-corrodible screen. The end of a vent shall terminate in the following location:
 - (A) At least six inches above the floor, if the valve is located in a building
 - (B) At least 12 inches above the top of the water line, if the valve is located in a below grade chamber that is not subject to flooding
 - (C) At least 12 inches above grade, if the valve is located in a below grade chamber that is subject to flooding

(b) Piping.

Piping for pumping facilities shall be designed to meet the following requirements:

- (i) Friction losses shall be minimized.
- (ii) Piping shall not be subject to contamination.
- (iii) Watertight joints shall be provided.
- (iv) Protection against surge or water hammer shall be provided along with suitable restraints if necessary.

(c) Controls.

Controls for pumping facilities shall be designed and operated to meet the following requirements:

- (i) The pump and accessories shall operate at the rated capacity.
- (ii) Where two or more pumps are installed, provisions shall be made for alternation of the pumps.
- (iii) Provisions shall be made to prevent energizing the pump motor in the event of a backspin cycle.

- (iv) Electrical controls shall be protected against flooding.
- (v) Provisions shall be made to prevent surge pressures from activating controls that switch on pumps or activate other equipment outside the normal design cycle of operation.
- (vi) Pump control equipment shall have proper overload protection for the air temperature encountered.

(d) Standby Power.

A community water system that relies solely on a pump to supply water to the distribution system shall provide a redundant power supply. A redundant power supply may include a transfer switch for auxiliary power such as a generator or a power supply service with coverage from two independent substations.

(e) Water Pre-Lubrication.

If automatic pre-lubrication of pump bearings is needed and an auxiliary direct drive power supply is provided, the pre-lubrication line shall be provided with a valved bypass around the automatic control so that the bearings can, if necessary, be lubricated manually before the pump is started or the pre-lubrication controls shall be wired to the auxiliary power supply.

(f) Gauges.

Each pump station shall be designed to include the following gauges:

- (i) The discharge line shall have a standard pressure gauge or an alternative means of measuring pressure on the discharge line.
- (ii) The suction line shall have a compound gauge (capable of indicating negative pressure or vacuum as well as positive pressure) or an alternative means of measuring pressure.

Guidance: It is recommended that larger pumping stations have indicating, totalizing, and recording metering of the total water pumped and recording pressure gauges.

R309-540-5. Pumps.

(a) Capacity.

Pumping facility shall be sized to meet the peak day demand of the specific portion of the distribution system served, or it shall meet the operating conditions if not serving the distribution system.

Guidance: a second pump is recommended if the pump delivers a sole source of water.

(b) Pump Motor.

Pump motors shall meet the following requirements:

(i) The pump motor shall be sized to meet the operating conditions without dangerous overloading.

(ii) The pump shall be driven by prime movers able to meet the maximum horsepower condition of the pumps without use of service factors.

(c) Suction Lift.

Suction lift, where possible, should be avoided. If suction lift is necessary, it shall be within the pump manufacturer's recommended limits and provisions shall be made for priming the pumps.

(d) Priming.

Where pumps require priming, the following requirements shall be met:

(i) Priming water shall not be of lesser sanitary quality than that of the water being pumped.

(ii) A means shall be provided to prevent back siphonage.

(iii) When an air-operated ejector is used for vacuum priming, the screened intake shall draw clean air from a point at least 10 feet above the ground or other source of possible contamination.

(e) Water Seal.

Where pumps use water seals, the seals shall meet the following requirements:

(i) They may not be supplied with water of a lesser sanitary quality than that of the water being pumped.

(ii) When pumps are sealed with potable water and are pumping water of lesser sanitary quality, the water for the seal shall be provided with a break tank open to atmospheric pressure, and have an air gap of at least six inches or two pipe diameters, whichever is greater, between the feeder line and the spill line of the tank.

R309-540-6. Booster Pumps Serving the Distribution System.

(a) Booster pumps shall be designed and operated to meet the following

requirements:

- (i) Negative pressure may not be produced in suction lines.
- (ii) The automatic cutoff pressure shall be at least 10 psi in the suction line.
- (iii) Automatic or remote control devices shall have a range between the start and cutoff pressure that will prevent excessive cycling.
- (iv) A bypass shall be available.

(b) Inline booster pumps (pumps withdrawing water directly from distribution lines without the benefit of storage and feeding such water directly into other distribution lines rather than storage) shall be designed and operated to meet the following requirements:

- (i) At least two pumping units shall be provided with each pump capable of meeting the peak day demand of the specific portion of the system served.
- (ii) The pumps shall be accessible for servicing and repair.
- (iii) The intake pressure shall be at least 20 psi when the pump or pumps are in normal operation.

(c) A public water system may not rely on individual service connection booster pumps to meet minimum pressure requirements.

Guidance: Refer to Guidance found in R309-550-11(3)

R309-540-7. Pump Stations.

(a) If a building structure is provided for pumping facilities it shall be designed to meet the following requirements:

- (i) Adequate space shall be provided for the safe servicing of all equipment and, if needed, the installation of additional pumps.
- (ii) The building shall be durable.
- (iii) Access to the pump station shall be six inches above the surrounding ground and the station located at an elevation which is a minimum of three feet above the 100-year flood elevation, or three feet above the highest recorded flood elevation, whichever is higher, or protected to such elevations.
- (iv) Underground facilities shall be waterproof.
- (v) Interior floors shall be drained in such a manner that the quality of drinking water contained in a wet well will not be endangered.
- (vi) A means shall be provided for handling drainage from pump glands.

- (b) Wet wells shall be designed to meet the following requirements:
- (i) Construction shall be watertight.
 - (ii) Floors shall be sloped to permit removal of water and sediment.
 - (iii) Openings shall be covered and protected against contamination.
- (c) Provisions shall be made for servicing or removal of heavy or bulky equipment.

Guidance: for large facilities, provisions for servicing or removal of heavy or bulky equipment may include crane-ways, hoist beams, eye-bolts, openings in floors or roofs, etc.

- (d) Stairways and ladders shall be designed to meet the following requirements:
- (i) Safe access shall be provided between all floors and in pits or compartments that must be entered.
 - (ii) Added features shall provide for the safety of the operator, for example, by providing handrails on stairways and non-slip treads on steps.

Guidance: Ramps are preferred in areas where there is frequent traffic or where supplies are transported by hand. Where ramps are not possible, stairs are preferred to ladders.

- (e) Adequate heating and lighting shall be provided for the safety and comfort of the operator and the safe and efficient operation of the equipment.

Guidance: In pump houses not occupied by personnel, only enough heat need be provided to prevent freezing of equipment or treatment process.

- (f) Ventilation shall meet the following requirements:

- (i) Forced ventilation of at least six changes of air per hour shall be provided for rooms, compartments, pits and other enclosures below ground floor and for any area where unsafe conditions may develop.
- (ii) Existing local and state codes shall be followed.

Guidance: In areas where excess moisture could cause hazards to safety or damage to equipment, means for dehumidification should be provided.

- (g) Automatic and remote-controlled stations shall meet the following requirements:

- (i) Remote-controlled stations shall have signaling apparatus of proven performance.

(ii) Installation of electrical equipment shall conform with the applicable state and local electrical codes and the National Electrical Code.

Guidance: An automatic station should be provided with an automatic signaling apparatus which will report when the station is out of service.

R309-540-8. Hydropneumatic Systems.

(1) General.

(a) Pressure tanks shall comply with ANSI/NSF Standard 61.

(b) Community water systems shall not use hydropneumatic tanks to meet the water storage sizing requirements in R309-510-8.

Guidance: This section applies to three common types of hydropneumatic tanks: air-over-water pressure tanks, diaphragm pressure tanks, and bladder pressure tanks.

Guidance: Pressure tanks dedicated for fire suppression service are not considered to be hydropneumatic tanks serving drinking water systems

(2) Location.

(a) A hydropneumatic pressure tank shall be located above ground if possible.

(b) If pressure tanks and appurtenances are located below ground, adequate provisions for drainage, ventilation, access, maintenance, and flood protection shall be provided, and the electrical controls shall be located above grade so as to be protected from flooding.

(3) Operating Pressures.

A means of monitoring the operating pressures of a hydropneumatic tank shall be provided.

(4) Bypass Piping.

The hydropneumatic system design shall include bypass piping and isolation valves to allow one or more of the pressure tanks to be serviced without affecting the availability of the remaining units.

(5) Redundancy.

(a) When used to maintain minimum pressures within the distribution system, a community water system shall have a means of providing redundancy to allow the tanks to be taken off line or serviced.

(b) At least two units shall be provided for community water systems if the hydropneumatic system is the only means to maintain minimum pressures in the distribution system.

(6) Sizing.

The minimum volume of a hydropneumatic tank shall be sized to avoid excessive pump cycling.

Guidance: The number of allowable starts varies with the design speed of the motor and the motor size. Follow the manufacturer's recommendations to avoid excessive pump cycling.

Guidance: As a rule-of-thumb the minimum volume of the hydropneumatic tank should be at least five times the capacity of the pump(s), rated in gpm. For example, a 200 gpm pump or combination of pumps should have a 1,000 gallon pressure tank.

(7) Air-Over-Water Pressure Tanks.

(a) General.

Large air-over-water pressure tanks shall have an access manhole, a drain, a pressure gauge, a water sight glass, an automatic or manual air blow-off, a means for adding air, and pressure operated start-stop controls for the pumps.

(b) Air Supply for Pressure Tanks.

(i) Air delivered by a compressor to the pressure tank shall be adequately filtered, oil free, and be of adequate flow rate.

(ii) An air intake shall be screened and draw clean air from a point above the ground and free of possible contamination.

(iii) Discharge piping from air relief valves shall be screened and designed to eliminate the possibility of contamination.

(c) Water Seal.

(i) For air pressure tanks without an internal diaphragm the volume of water remaining in an air pressure tank at the lower pressure setting shall be sufficient to provide an adequate water seal at the outlet to prevent the leakage of air.

Guidance: To prevent the formation of a vortex, a covering baffle may be installed over a vertical bottom outlet large enough to limit the peripheral velocity of approach to the baffle to 0.5 ft/sec or less. At low absolute pressure the depth of water over the top of the baffle should be about one outlet pipe velocity head or greater.

(d) Water Seal Depth.

The minimum water seal depths shall be as follows.

(i) Horizontal outlets shall maintain sufficient depth, as measured from the centerline of the horizontal outlet pipe, such that the depth is greater than or equal to the sum of [d] and [twice the value v squared divided by 2g].
[Depth $\geq d + (2v^2/2g)$]

(ii) For vertical outlets, if unbaffled, the depth shall be the same as in (i) except measured from the pipe outlet; if baffled, the depth shall be greater than or equal to the value v squared divided by 2g. [Depth $\geq (v^2/2g)$]

Where the following values are used in the equations above:

v = the axial velocity in the pipe outlet for the peak instantaneous demand flow rate of the system.

d = the diameter of the outlet pipe in feet

g = the gravitational constant of 32.2 feet/sec/sec.

Guidance: For either horizontal or vertical outlets, the pipe outlet itself should be large enough to limit the maximum axial velocity in the pipe to 4.0 ft/sec or less. The use of anti-swirl vanes is always desirable.

KEY: drinking water, pumps, hydropneumatic systems, individual home booster pumps

Date of Enactment or Last Substantive Amendment: ~~February 15, 2009~~

Notice of Continuation: March 13, 2015

Authorizing, Implemented, or Interpreted Law: 19-4-104

R309-540. Facility Design and Operation: Pump Stations

- **DAR Version for Repeal and Re-enact**

R309. Environmental Quality, Drinking Water.

[R309-540. Facility Design and Operation: Pump Stations.]

R309-540-1. Purpose.

~~_____ The purpose of this rule is to provide specific requirements for pump stations utilized to deliver drinking water to facilities of public water systems. It is intended to be applied in conjunction with rules R309-500 through R309-550. Collectively, these rules govern the design, construction, operation and maintenance of public drinking water system facilities. These rules are intended to assure that such facilities are reliably capable of supplying adequate quantities of water which consistently meet applicable drinking water quality requirements and do not pose a threat to general public health.~~

R309-540-2. Authority.

~~_____ This rule is promulgated by the Drinking Water Board as authorized by Title 19, Environmental Quality Code, Chapter 4, Safe Drinking Water Act, Subsection 104(1)(a)(ii) of the Utah Code and in accordance with 63G-3 of the same, known as the Administrative Rulemaking Act.~~

R309-540-3. Definitions.

~~_____ Definitions for certain terms used in this rule are given in R309-110 but may be further clarified herein.~~

R309-540-4. General.

~~_____ Pumping stations shall be designed to maintain the sanitary quality of water and to provide ample quantities of water at sufficient pressure.~~

R309-540-5. Pumping Facilities.

~~_____ (1) Location.~~

~~_____ (a) The pumping station shall be designed such that:~~

~~_____ (i) the proposed site will meet the requirements for sanitary protection of water quality, hydraulics of the system, and protection against interruption of service by fire, flood or any other hazard;~~

~~_____ (ii) the access to the pump station shall be six inches above the surrounding ground and the station located at an elevation which is a minimum of three feet above the 100-year flood elevation, or three feet above the highest recorded flood elevation, which ever is higher, or protected to such elevations;~~

~~_____ (iii) the station is readily accessible at all times unless permitted to be out of service for the period of inaccessibility;~~

~~_____ (iv) surrounding ground is graded so as to lead surface drainage away from the station; and~~

~~_____ (v) the station is protected to prevent vandalism and entrance by animals or unauthorized persons.~~

~~_____ (2) Pumping Stations.~~

~~_____ (a) Building structures for both raw and drinking water shall:~~

~~_____ (i) have adequate space for the installation of additional pumping units if needed, and for the safe servicing of all equipment;~~

~~_____ (ii) be of durable construction, fire and weather resistant, with outward-opening doors;~~

~~_____ (iii) have an interior floor elevation at least six inches above the exterior finished grade;~~

~~_____ (iv) have any underground facilities, especially wet wells,~~

waterproofed;

~~(v) have all interior floors drained in such a manner that the quality of drinking water contained in any wet wells will not be endangered. All floors shall slope at least one percent (one foot every 100 feet) to a suitable drain; and~~

~~(vi) provide a suitable outlet for drainage from pump glands without discharging onto the floor.~~

~~(b) Suction wells shall:~~

~~(i) be watertight;~~

~~(ii) have floors sloped to permit removal of water and entrained solids;~~

~~(iii) be covered or otherwise protected against contamination; and~~

~~(iv) have two pumping compartments or other means to allow the suction well to be taken out of service for inspection, maintenance, or repair.~~

~~(c) Servicing equipment shall consist of:~~

~~(i) crane-ways, hoist beams, eyebolts, or other adequate facilities for servicing or removal of pumps, motors or other heavy equipment;~~

~~(ii) openings in floors, roofs or wherever else needed for removal of heavy or bulky equipment; and~~

~~(iii) a convenient tool board, or other facilities as needed, for proper maintenance of the equipment.~~

~~(d) Stairways and ladders shall:~~

~~(i) be provided between all floors, and in pits or compartments which must be entered; and~~

~~(ii) have handrails on both sides, and treads of non-slip material. They shall have risers not exceeding nine inches and treads wide enough for safety.~~

~~(e) Heating provisions shall be adequate for:~~

~~(i) the comfort of the operator; and~~

~~(ii) the safe and efficient operation of the equipment.~~

~~(f) Ventilation shall:~~

~~(i) conform to existing local and/or state codes; and~~

~~(ii) forced ventilation of at least six changes of air per hour shall be provided for all rooms, compartments, pits and other enclosures below ground floor, and any area where unsafe atmosphere may develop or where excessive heat may be built up.~~

~~(g) Lighting.~~

~~Pump stations shall be adequately lighted throughout. All electrical work shall conform to the requirements of the relevant state and/or local building codes.~~

~~(h) Sanitary and other conveniences.~~

~~Plumbing shall be so installed as to prevent contamination of a public water supply. Wastes shall be discharged in accordance with the plumbing code, R317-4, or R317-1-3.~~

~~(3) Pumps.~~

~~(a) Capacity.~~

~~Capacity shall be provided such that the pump or pumps shall be capable of providing the peak day demand of the system or the specific portion of the system serviced.~~

~~The pumping units shall:~~

~~(i) have ample capacity to supply the peak day demand against~~

~~the required distribution system pressure without dangerous overloading;~~

~~(ii) be driven by prime movers able to meet the maximum horsepower condition of the pumps without use of service factors;~~

~~(iii) be provided readily available spare parts and tools; and~~

~~(iv) be served by control equipment that has proper heater and overload protection for air temperature encountered.~~

~~(b) Suction Lift.~~

~~Suction lift, where possible, shall be avoided. If suction lift is necessary, the required lift shall be within the pump manufacturer's recommended limits and provision shall be made for priming the pumps.~~

~~(c) Priming.~~

~~Prime water shall not be of lesser sanitary quality than that of the water being pumped. Means shall be provided to prevent back siphonage. When an air-operated ejector is used, the screened intake shall draw clean air from a point at least 10 feet above the ground or other source.~~

~~(4) Booster Pumps.~~

~~(a) Booster pumps shall be located or controlled so that:~~

~~(i) they will not produce negative pressure in their suction lines;~~

~~(ii) automatic cutoff pressure shall be at least 10 psi in the suction line;~~

~~(iii) automatic or remote control devices shall have a range between the start and cutoff pressure which will prevent excessive cycling; and~~

~~(iv) a bypass is available.~~

~~(b) Inline booster pumps (pumps withdrawing water directly from distribution lines without the benefit of storage and feeding such water directly into other distribution lines rather than storage), in addition to the other requirements of this section, shall have at least two pumping units (such that with any one pump out of service, the remaining pump or pumps shall be capable of providing the peak day demand of the specific portion of the system serviced), shall be accessible for servicing and repair and located or controlled so that the intake pressure shall be at least 20 psi when the pump or pumps are in normal operation.~~

~~(c) Individual home booster pumps shall not be allowed for any individual service from the public water supply main.~~

~~(5) Automatic and remote controlled stations.~~

~~All remote controlled stations shall be electrically operated and controlled and shall have signaling apparatus of proven performance. Installation of electrical equipment shall conform with the applicable state and local electrical codes and the National Electrical Code.~~

~~(6) Appurtenances.~~

~~(a) Valves.~~

~~Valves shall be used to permit satisfactory operation, maintenance, and repair of the equipment. If foot valves are necessary, they shall have a net valve area of at least 2 1/2 times the area of the suction pipe and they shall have a positive-acting check valve on the discharge side between the pump and the shut-off valve.~~

~~(b) Piping.~~

~~— Piping within and near pumping stations shall:~~

~~— (i) be designed so that the friction losses will be minimized;~~

~~— (ii) not be subject to contamination;~~

~~— (iii) have watertight joints;~~

~~— (iv) be protected against surge or water hammer; and~~

~~— (v) be such that each pump has an individual suction line or that the lines shall be so manifolded that they will insure similar hydraulic and operating conditions.~~

~~— (c) Gauges and Meters.~~

~~— Each pump shall:~~

~~— (i) have a standard pressure gauge on its discharge line;~~

~~— (ii) have a compound gauge (capable of indicating negative pressure or vacuum as well as positive pressure) on its suction line; and~~

~~— (iii) have recording gauges in the larger stations.~~

~~— (d) Water Seal.~~

~~— Where pumps utilize water seals, the seals shall:~~

~~— (i) not be supplied with water of a lesser sanitary quality than that of the water being pumped; and~~

~~— (ii) when pumps are sealed with potable water and are pumping water of lesser sanitary quality, the seal shall be provided with a break tank open to atmospheric pressure, and have an air gap of at least six inches or two pipe diameters, whichever is greater, between the feeder line and the spill line of the tank.~~

~~— (e) Controls.~~

~~— Controls shall be designed in such a manner that they will operate their prime movers, and accessories, at the rated capacity without dangerous overload. Where two or more pumps are installed, provision shall be made for alternation. Provision shall be made to prevent energizing the motor in the event of a backspin cycle. Electrical controls shall be protected against flooding. Equipment shall be provided or other arrangements made to prevent surge pressures from activating controls which switch on pumps or activate other equipment outside the normal design cycle of operation.~~

~~— (f) Standby Power.~~

~~— Standby power, to ensure continuous service when the primary power has been interrupted, shall be provided from at least two independent sources or a standby or an auxiliary source shall be provided. If standby power is provided by onsite generators or engines, the fuel storage and fuel line must be designed to protect the water supply from contamination.~~

~~— (g) Water Pre-Lubrication.~~

~~— When automatic pre-lubrication of pump bearings is necessary and an auxiliary direct drive power supply is provided, the pre-lubrication line shall be provided with a valved bypass around the automatic control so that the bearings can, if necessary, be lubricated manually before the pump is started or the pre-lubrication controls shall be wired to the auxiliary power supply.~~

~~R309-540-6. Hydropneumatic Systems.~~

~~— (1) General.~~

~~— Hydropneumatic systems shall comply with all appropriate sections of R309-540-5 except as otherwise indicated herein.~~

~~— Unpressurized ground level or elevated storage, designed in~~

accordance with R309-545, shall be provided for community type public water systems or non-transient non-community systems where a demand in excess of the capacity of the source(s) is required, in addition to the diaphragm or air tanks. Diaphragm or air pressure tank storage shall not be considered for fire protection purposes or effective system storage for community type systems.

~~(2) Location.~~

~~If diaphragm or air tanks and appurtenances are located below ground, adequate provisions for drainage, ventilation, maintenance, and flood protection shall be made and the electrical controls shall be located above grade so as to be protected from flooding as required by R309-540-5(6)(e). Any discharge piping from combination air release/vacuum relief valves(air/vac's) or pressure relief valves located in below ground chambers shall comply with all the pertinent requirements of R309-550-6(6).~~

~~(3) Operating Pressures.~~

~~The system shall be designed to provide minimum pressures in R309-105-9 at all points in the distribution system. A pressure gauge shall be installed on the pressure tank inlet line.~~

~~(4) Piping.~~

~~In addition to the bypass required by R309-540-5(4)(iv) on the pumps, the diaphragm or air tanks shall have sufficient bypass piping to permit operation of the hydropneumatic system while one or more of the tanks are being repaired, replaced or painted.~~

~~(5) Pumps.~~

~~At least two pumping units shall be provided except for those type systems not requiring unpressurized storage in R309-540-6(1); they may use the pump within their groundwater source to pressurize the diaphragm or air tanks. With any pump out of service the remaining pump or pumps shall be capable of providing the peak instantaneous demand of the system as described in R309-510-9(2), while recharging the pressure tank at 115 percent of the upper pressure setting. Pump cycling shall not exceed 15 starts per hour, with a maximum of ten starts per hour preferred.~~

~~(6) Pressure Tanks.~~

~~(a) Pressure tanks shall meet the requirement of state and local laws and regulations for the manufacture and installation of unfired pressure vessels. Interior coatings or diaphragms used in pressure tanks that will come into contact with the drinking water shall comply with ANSI/NSF Standard 61. Non diaphragm pressure tanks shall have an access manhole, a drain, control equipment consisting of pressure gauge, water sight glass, automatic or manual air blow-off, means for adding air, and pressure operated start-stop controls for the pumps.~~

~~(b) The minimum volume of the pressure tank or combination of tanks shall be greater than or equal to the sum of S and the value of CX divided by 4W.~~

~~where the following values are used in the equation above:~~

~~C = minutes per operating cycle, four minutes to meet the requirements of R309-540-6(5) above or preferably six minutes, and is equal to pump ON time plus pump OFF time.~~

~~X = output capacity rating of the pump(s) at the high pressure condition in the tank(s), in gpm.~~

~~W = percent of volume withdrawn during a given drop in tank~~

pressure: specifically, between P_h and P_l . $W = 100(P_h - P_l)/P_h$ where P_h = high pressure in tank in psia (high absolute pressure) and P_l = low pressure in tank in psia (low absolute pressure). Values of W range typically from 0.26 to 0.31 for pressure differentials of 15 to 30 psi and high system pressures of 45 to 85 psi at elevations of approximately 5,000 feet.

S = water seal volume in gallons, the volume of inactive water remaining in tank at low pressure condition.

(7) Air Volume.

The method of adjusting the air volume shall be acceptable to the Director. Air delivered by compressors to the pressure tank shall be adequately filtered, oil free, and be of adequate volume. Any intake shall be screened and draw clean air from a point at least 10 feet above the ground or other source of possible contamination, unless the air is filtered by an apparatus approved by the Director. Discharge piping from air relief valves shall be designed and installed with screens to eliminate the possibility of contamination from this source.

(8) Water Seal.

For air pressure tanks without an internal diaphragm the volume of water remaining in a air pressure tank at the lower pressure setting shall be sufficient to provide an adequate water seal at the outlet to prevent the leakage of air.

The following water seal depths shall be considered as minimum requirements.

(a) Horizontal outlets shall maintain sufficient depth, as measured from the centerline of the horizontal outlet pipe, such that the depth is greater than or equal to the sum of d and twice the value v^2 divided by $2G$.

(b) Vertical outlets, if unbaffled, the depth shall be the same as in (a) except measured from the pipe outlet; if baffled, the depth shall be greater than or equal to the value v^2 divided by $2G$.

where the following values are used in the equations above:

v = the axial velocity in the pipe outlet for the peak instantaneous demand flow rate of the system.

d = the diameter of the outlet pipe in ft.

G = the gravitational constant of 32.2 ft/sec/sec.

(9) Standby Power Supply.

Where a hydropneumatic system is intended to serve a public water system, categorized as a community water system as defined in R309-110, a standby source of power shall be provided.]

R309-540. Facility Design and Operation: Pumping Facilities.

R309-540-1. Purpose.

The purpose of this rule is to provide specific requirements for the design and operation of drinking water pumping facilities. It is intended to be applied in conjunction with rules R309-500 through R309-550. Collectively, these rules govern the design, construction, operation and maintenance of public drinking water system facilities. These rules are intended to assure that such facilities are reliably capable of supplying adequate quantities of water which consistently meet applicable drinking water quality requirements and do not pose a threat to general public health.

R309-540-2. Authority.

This rule is promulgated by the Drinking Water Board as authorized by Title 19, Environmental Quality Code, Chapter 4, Safe Drinking Water Act, Subsection 104(1)(a)(ii) of the Utah Code and in accordance with 63G-3 of the same, known as the Administrative Rulemaking Act.

R309-540-3. Definitions.

Definitions for certain terms used in this rule are given in R309-110 but may be further clarified in this rule.

R309-540-4. General.

The following requirements apply to all pumping facilities including pumps, pump stations, and hydropneumatic systems. Pumping facilities shall be adequately sized and be designed to maintain the quality of the water and to meet minimum pressure requirements.

(1) Location and Accessibility.

(a) A pumping facility shall be designed and operated to meet the following requirements:

(i) The facility may not be located at a site that negatively affects drinking water quality.

(ii) The site shall be compatible with the hydraulics of the water system.

(iii) The site shall be graded to direct surface runoff away from the facility.

(iv) The facility shall be accessible at all times unless the facility can be taken out of service during periods of inaccessibility.

(v) The facility shall be protected from vandalism and unauthorized entry.

(2) Appurtenances.

(a) Valves.

Valves for pumping facilities shall be designed and operated to meet the following requirements.

(i) Isolation valves shall be included for operation, maintenance, and repair of the pumping equipment.

(ii) Foot valves in wet wells shall have a net valve area of at least 2 1/2 times the area of the suction pipe and there shall be a positive-acting check valve on the discharge side between the pump and the shut-off valve.

(iii) The open end of a vent on an air relief valve shall be downturned and covered with a #14 mesh non-corrodible screen. The

end of a vent shall terminate in the following location:

(A) At least six inches above the floor, if the valve is located in a building

(B) At least 12 inches above the top of the water line, if the valve is located in a below grade chamber that is not subject to flooding

(C) At least 12 inches above grade, if the valve is located in a below grade chamber that is subject to flooding

(b) Piping.

Piping for pumping facilities shall be designed to meet the following requirements:

(i) Friction losses shall be minimized.

(ii) Piping shall not be subject to contamination.

(iii) Watertight joints shall be provided.

(iv) Protection against surge or water hammer shall be provided along with suitable restraints if necessary.

(c) Controls.

Controls for pumping facilities shall be designed and operated to meet the following requirements:

(i) The pump and accessories shall operate at the rated capacity.

(ii) Where two or more pumps are installed, provisions shall be made for alternation of the pumps.

(iii) Provisions shall be made to prevent energizing the pump motor in the event of a backspin cycle.

(iv) Electrical controls shall be protected against flooding.

(v) Provisions shall be made to prevent surge pressures from activating controls that switch on pumps or activate other equipment outside the normal design cycle of operation.

(vi) Pump control equipment shall have proper overload protection for the air temperature encountered.

(d) Standby Power.

A community water system that relies solely on a pump to supply water to the distribution system shall provide a redundant power supply. A redundant power supply may include a transfer switch for auxiliary power such as a generator or a power supply service with coverage from two independent substations.

(e) Water Pre-Lubrication.

If automatic pre-lubrication of pump bearings is needed and an auxiliary direct drive power supply is provided, the pre-lubrication line shall be provided with a valved bypass around the automatic control so that the bearings can, if necessary, be lubricated manually before the pump is started or the pre-lubrication controls shall be wired to the auxiliary power supply.

(f) Gauges.

Each pump station shall be designed to include the following gauges:

(i) The discharge line shall have a standard pressure gauge or an alternative means of measuring pressure on the discharge line.

(ii) The suction line shall have a compound gauge (capable of indicating negative pressure or vacuum as well as positive pressure) or an alternative means of measuring pressure.

R309-540-5. Pumps.

(a) Capacity.

Pumping facility shall be sized to meet the peak day demand of the specific portion of the distribution system served, or it shall meet the operating conditions if not serving the distribution system.

(b) Pump Motor.

Pump motors shall meet the following requirements:

(i) The pump motor shall be sized to meet the operating conditions without dangerous overloading.

(ii) The pump shall be driven by prime movers able to meet the maximum horsepower condition of the pumps without use of service factors.

(c) Suction Lift.

Suction lift, where possible, should be avoided. If suction lift is necessary, it shall be within the pump manufacturer's recommended limits and provisions shall be made for priming the pumps.

(d) Priming.

Where pumps require priming, the following requirements shall be met:

(i) Priming water shall not be of lesser sanitary quality than that of the water being pumped.

(ii) A means shall be provided to prevent back siphonage.

(iii) When an air-operated ejector is used for vacuum priming, the screened intake shall draw clean air from a point at least 10 feet above the ground or other source of possible contamination.

(e) Water Seal.

Where pumps use water seals, the seals shall meet the following requirements:

(i) They may not be supplied with water of a lesser sanitary quality than that of the water being pumped.

(ii) When pumps are sealed with potable water and are pumping water of lesser sanitary quality, the water for the seal shall be provided with a break tank open to atmospheric pressure, and have an air gap of at least six inches or two pipe diameters, whichever is greater, between the feeder line and the spill line of the tank.

R309-540-6. Booster Pumps Serving the Distribution System.

(a) Booster pumps shall be designed and operated to meet the following requirements:

(i) Negative pressure may not be produced in suction lines.

(ii) The automatic cutoff pressure shall be at least 10 psi in the suction line.

(iii) Automatic or remote control devices shall have a range between the start and cutoff pressure that will prevent excessive cycling.

(iv) A bypass shall be available.

(b) Inline booster pumps (pumps withdrawing water directly from distribution lines without the benefit of storage and feeding such water directly into other distribution lines rather than storage) shall be designed and operated to meet the following requirements:

(i) At least two pumping units shall be provided with each pump capable of meeting the peak day demand of the specific portion of the system served.

(ii) The pumps shall be accessible for servicing and repair.

(iii) The intake pressure shall be at least 20 psi when the pump or pumps are in normal operation.

(c) A public water system may not rely on individual service connection booster pumps to meet minimum pressure requirements.

R309-540-7. Pump Stations.

(a) If a building structure is provided for pumping facilities it shall be designed to meet the following requirements:

(i) Adequate space shall be provided for the safe servicing of all equipment and, if needed, the installation of additional pumps.

(ii) The building shall be durable.

(iii) Access to the pump station shall be six inches above the surrounding ground and the station located at an elevation which is a minimum of three feet above the 100-year flood elevation, or three feet above the highest recorded flood elevation, whichever is higher, or protected to such elevations.

(iv) Underground facilities shall be waterproof.

(v) Interior floors shall be drained in such a manner that the quality of drinking water contained in a wet well will not be endangered.

(vi) A means shall be provided for handling drainage from pump glands.

(b) Wet wells shall be designed to meet the following requirements:

(i) Construction shall be watertight.

(ii) Floors shall be sloped to permit removal of water and sediment.

(iii) Openings shall be covered and protected against contamination.

(c) Provisions shall be made for servicing or removal of heavy or bulky equipment.

(d) Stairways and ladders shall be designed to meet the following requirements:

(i) Safe access shall be provided between all floors and in pits or compartments that must be entered.

(ii) Added features shall provide for the safety of the operator, for example, by providing handrails on stairways and non-slip treads on steps.

(e) Adequate heating and lighting shall be provided for the safety and comfort of the operator and the safe and efficient operation of the equipment.

(f) Ventilation shall meet the following requirements:

(i) Forced ventilation of at least six changes of air per hour shall be provided for rooms, compartments, pits and other enclosures below ground floor and for any area where unsafe conditions may develop.

(ii) Existing local and state codes shall be followed.

(g) Automatic and remote-controlled stations shall meet the following requirements:

(i) Remote-controlled stations shall have signaling apparatus of proven performance.

(ii) Installation of electrical equipment shall conform with the applicable state and local electrical codes and the National Electrical Code.

R309-540-8. Hydropneumatic Systems.

(1) General.

(a) Pressure tanks shall comply with ANSI/NSF Standard 61.

(b) Community water systems shall not use hydropneumatic tanks to meet the water storage sizing requirements in R309-510-8.

(2) Location.

(a) A hydropneumatic pressure tank shall be located above ground if possible.

(b) If pressure tanks and appurtenances are located below ground, adequate provisions for drainage, ventilation, access, maintenance, and flood protection shall be provided, and the electrical controls shall be located above grade so as to be protected from flooding.

(3) Operating Pressures.

A means of monitoring the operating pressures of a hydropneumatic tank shall be provided.

(4) Bypass Piping.

The hydropneumatic system design shall include bypass piping and isolation valves to allow one or more of the pressure tanks to be serviced without affecting the availability of the remaining units.

(5) Redundancy.

(a) When used to maintain minimum pressures within the distribution system, a community water system shall have a means of providing redundancy to allow the tanks to be taken off line or serviced.

(b) At least two units shall be provided for community water systems if the hydropneumatic system is the only means to maintain minimum pressures in the distribution system.

(6) Sizing.

The minimum volume of a hydropneumatic tank shall be sized to avoid excessive pump cycling.

(7) Air-Over-Water Pressure Tanks.

(a) General.

Large air-over-water pressure tanks shall have an access manhole, a drain, a pressure gauge, a water sight glass, an automatic or manual air blow-off, a means for adding air, and pressure operated start-stop controls for the pumps.

(b) Air Supply for Pressure Tanks.

(i) Air delivered by a compressor to the pressure tank shall be adequately filtered, oil free, and be of adequate flow rate.

(ii) An air intake shall be screened and draw clean air from a point above the ground and free of possible contamination.

(iii) Discharge piping from air relief valves shall be screened and designed to eliminate the possibility of contamination.

(c) Water Seal.

(i) For air pressure tanks without an internal diaphragm the volume of water remaining in an air pressure tank at the lower pressure setting shall be sufficient to provide an adequate water seal at the outlet to prevent the leakage of air.

(d) Water Seal Depth.

The minimum water seal depths shall be as follows.

(i) Horizontal outlets shall maintain sufficient depth, as

measured from the centerline of the horizontal outlet pipe, such that the depth is greater than or equal to the sum of (d) and (twice the value v squared divided by 2g). (Depth $\geq d + (2v^2/2g)$)

(ii) For vertical outlets, if unbaffled, the depth shall be the same as in (i) except measured from the pipe outlet; if baffled, the depth shall be greater than or equal to the value v squared divided by 2g. (Depth $\geq (v^2/2g)$)

Where the following values are used in the equations above:

v = the axial velocity in the pipe outlet for the peak instantaneous demand flow rate of the system.

d = the diameter of the outlet pipe in feet

g = the gravitational constant of 32.2 feet/sec/sec.

KEY: drinking water, pumps, hydropneumatic systems, individual home booster pumps

Date of Enactment or Last Substantive Amendment: [~~February 15, 2009~~]

Notice of Continuation: March 13, 2015

Authorizing, and Implemented or Interpreted Law: 19-4-104