

ATTACHMENT 12

**WASTE FEED CUTOFF SYSTEMS
TESTING PROCEDURE**

Attachment 12
Waste Feed Cutoff Systems Testing Procedure

The testing of the automatic waste feed cutoff system will be done on a weekly basis (once every 168 hours on waste). The test initiation will shut off waste feed (effects) as each "cause" is electronically checked.

1. The control board operator is responsible to initiate the weekly waste feed cutoff test.

Once the test is started, a total waste feed cutoff is initiated by a simulated "cause." The "effects" of this condition will be field verified and recorded on forms. Once this occurs the control system will simulate signals internally for each of the waste feed cutoff causes and generate an alarm printout to indicate that each one operated.

2. The control system is programmed such that one coil (programming loop) will cause all the associated effects. Also, all of the associated waste feed causes will energize the one coil.

The waste feed cutoff test is conducted in two parts. The first part consists of testing that the one coil causes all the associated "effects" which are field verified and initialed by the operator performing the verification. The second part tests that all of the associated "causes" energize the one coil. In doing this, it is inferred that any of the "causes" will cause the "effects."

3. The following cutoffs (effects) will occur:

| | | |
|---|----------|-------------|
| a) Apron Feeder | SV 1036 | on/off |
| Upper Flop Gate | SV 1035B | open/shut |
| Lower Flop Gate | SV 1034B | open/shut |
| b) Kiln Elevator Container | | |
| Feed Gate | SV 1033B | open/shut |
| c) Direct Burn (A-101) | | |
| Block Valve | SV 1170 | open/closed |
| Control Valve | FV 1171 | open/closed |
| d) Kiln Liquid Waste Feed (A-104A) | | |
| Block Valve | SV 1120 | open/closed |
| Control Valve | FV 1121 | open/closed |
| e) North ABC Liquid Waste Feed (A-106A) | | |
| Block Valve | SV 1183 | open/closed |

| | | | |
|----|---|---------|-------------|
| | Control Valve | FV 1184 | open/closed |
| f) | South ABC Cylinder Waste Feed (A-106B-3) | | |
| | Block Valve | SV 1103 | open/closed |
| | Control Valve | SV 1104 | open/closed |
| g) | North ABC Aqueous Waste Feed (A-105A) | | |
| | Aqueous Block Valve | SV 1252 | open/closed |
| | Aqueous Control Valve | FV 1253 | open/closed |
| h) | South ABC Liquid Waste Feed (A-106B-1) | | |
| | Block Valve | SV 1220 | open/closed |
| | Control Valve | FV 1221 | open/closed |
| i) | South ABC Aqueous Waste Feed (A-105B) | | |
| | Aqueous Block Valve | SV 1262 | open/closed |
| | Aqueous Control Valve | FV 1263 | open/closed |
| j) | Kiln Sludge Feed (A-103) | | |
| | Kiln Sludge Control Valve | PV 4021 | open/closed |
| | Kiln Sludge Block Valve | SV 4022 | open/closed |
| k) | Kiln Aqueous Waste Feed (A-102) | | |
| | Aqueous Block Valve | SV 1150 | open/closed |
| | Aqueous Control Valve | FV 1151 | open/closed |
| l) | Drum Pumping Station | | |
| | Block Valve | SV3016 | open/closed |
| m) | South ABC Corrosive Waste Feed (A-106B-5) | | |
| | Block Valve | SV 3364 | open/closed |
| | Control Valve | FV 3365 | open/closed |

4. When the waste feed cutoff test is initiated, waste feed ceases. The liquid burners are put on clean fuel to maintain temperature. A field check verifies that the effect occurred. This is done by a person who will physically check that the cutoff occurred and record the results on the form at the end of this attachment.
5. Once the waste feed ceases, the following list of waste feed cutoff causes will be simulated internally in the control system. Alarms will be recorded to verify operation (signal sent, signal received). The following causes will be simulated:

TOTAL WASTE FEED CUTOFF CAUSES (1)

- a) ABC low temperature, TALL-1009
< 2018°F, HRA
- b) ABC high pressure, PAH-1006
≥ 0.0" H₂O, 5 sec
- c) ABC low oxygen
< 3%, 2 min, AAL-1010
< 2%, 15 sec, AALL-1010
- d) Spray dryer high exit temperature
> 400°F, HRA, TAH-2001R
> 520°F, TAH-2001
- e) Spray dryer low exit temperature
< 350°F, 15 minutes, TAL-2001
< 250°F, TALL-2001
- f) Spray dryer upper nozzle low brine pressure, PAL-2044
< 300 psi
- g) Spray dryer lower nozzle low brine pressure, PAL-2045
< 300 psi
- h) Baghouse low differential pressure, PDAL 2020
< 1.8" H₂O
- i) Baghouse minimum compartments on-line, ZAL2020
<7 compartments
- j) Baghouse high broken bag detector, AAH2020B
>50% of the instrument span
- k) Saturator high exit temperature, TAHH-2082
> 225°F
- l) Saturator low brine flow, FALL-2081
< 300 gpm, HRA
- m) 1st stage scrubber feed low pH, AAL-2104
< 5.47, HRA

- n) 1st stage scrubber low brine flow, FALL-2092
< 1882 gpm, HRA
- o) 1st stage scrubber low pressure drop, PAL-2093A
< 0.5" H₂O, HRA
- p) 2nd stage scrubber feed low pH, AAL-2130
< 6.23, HRA
- q) 2nd stage scrubber rundown low pH, AAL-2129
< 5.8, HRA
- r) 2nd stage scrubber low brine flow, FALL-2095
< 1996 gpm, HRA
- s) 2nd stage scrubber low pressure drop, PAL-2093B
< 0.5" H₂O HRA
- t) Activated carbon feed rate WT-2037RL
< 25 lb/hr, HRA
- u) Stack gas high flow, FAH-2195
> 77,800 ACFM, HRA
- v) Stack high CO
> 100 ppm, HRA, AHH-2199
> 500 ppm for more than 60 sec, AAH-2199
- w) ABC burners BMS trip, A106AM and A106BM,
both simultaneously
- x) Emergency waste feed stop red button, PB-0004
- y) WDPF waste feed cutoff, PB-0005
- z) Loss of utility power, UA-0001
- aa) ABC safety vent open, ZAO-1017
- bb) Baghouse on bypass, ZAL-2021
- cc) Induced draft fan off, K-201

TOTAL KILN WASTE FEED CUTOFFS CAUSES (2)

- a) Kiln outlet temperature, TAL 1005
 - < 1800°F, HRA (two pyrometers on-line)
 - < 1940°F, HRA (one pyrometer on-line)

- b) Low kiln rotation, SAL-1003
 - < .15 RPM

- c) Kiln Burner Management System, A104M
 - Loss of Flame
 - Low Combustion Air Pressure
 - Low Differential Pressure (atomizing air to waste liquid or fuel) on all enabled fuels and waste liquids
 - Low Liquid Pressure on all enabled fuels and waste liquids
 - Disabling all fuels and waste liquids
 - Manual shutdown of BMS

KILN CONTAINERS, SOLIDS, AND SLUDGE CUTOFF CAUSES (3)

- a) Kiln low secondary combustion air pressure, PAL-1018
 - < 2" H₂O

COMBINED BULK SOLIDS AND CONTAINERS WASTE FEED CUTOFF CAUSES (4)

- a) Bulk Solids and Kiln Barrel Feed
 - High hourly combined container and bulk solids feed rate, WQAH-1040, >18,600 lb/hr, HRA

WASTE FEED CUTOFF TO THE AFFECTED GUN/LANCE/FEED MECHANISM CAUSES (5)

- a) Kiln Blend Liquid Lance (A-104)
 - Kiln blend liquid low pressure switch PSL-1119A
 - Kiln atomizing air/waste liquid differential low pressure switch, PDSL-1124
 - High Kiln blend liquid flow rate, FAH-1121, >3090 lb/hr, HRA or >90 lb/min for 15 sec
 - Low Kiln blend liquid flow rate (turndown), <1.125 gpm for 15 sec (except during 3 minute gun startup)

- b) Direct Burn Lance (A-101)
 - Direct burn atomizing air low pressure switch PSL-1162
 - High hourly direct burn feed rate, FQAH-1171, >1710 lb/hr, HRA

- c) Sludge Feed (A-103)
 - High hourly sludge feed rate, FQAH-4042, >2170 lb/hr, HRA or >200 lb/min for 15 sec

- d) North ABC Blend Liquid Lance (A-106A)
 - North ABC blend liquid low pressure switch PSL-1119B
 - North ABC atomizing air/waste liquid differential low pressure switch, PDSL-1187
 - Low North ABC blend liquid flow rate (turndown), <1.125 gpm for 15 sec (except during 3 minute gun startup)
 - High North ABC blend liquid flow rate, FAH-1184D, >90 lb/min for 15 sec

- e) South ABC Blend Liquid Lance (A-106B)
 - South ABC blend liquid low pressure switch PSL-1196
 - South ABC atomizing air/waste liquid differential low pressure switch, PDSL-1224
 - Low South ABC blend liquid flow rate (turndown), <1.125 gpm for 15 sec (except during 3 minute gun startup)
 - High South ABC blend liquid/gas flow rate, FAH-1221D, >90 lb/min for 15 sec

- f) South ABC Cylinder Lance (A-106B-3)
 - South ABC cylinder eductor nitrogen low pressure switch, PSL-1107

- g) North ABC Aqueous Lance (A-105A)
 - North ABC aqueous low pressure switch, PSL-1165B
 - North ABC aqueous atomizing air low pressure switch, PSL-1256
 - High North ABC aqueous flow rate, FAH-1253D, >60 lb/min for 15 sec

- h) South ABC Aqueous Lance (A-105B)
 - South ABC aqueous low pressure switch, PSL-1165C
 - South ABC aqueous atomizing air low pressure switch, PSL-1266
 - High South ABC aqueous flow rate, FAH-1263D, >60 lb/min for 15 sec

- i) North ABC Burner Management System, A106AM
 - Loss of Flame
 - Low Combustion Air Pressure
 - Low Differential Pressure (atomizing air to waste liquid or fuel) on all enabled fuels and waste liquids
 - Low Liquid Pressure on all enabled fuels and waste liquids
 - Disabling all fuels and waste liquids

Manual shutdown of BMS

- j) South ABC Burner Management System, A106BM
 - Loss of Flame
 - Low Combustion Air Pressure
 - Low Differential Pressure (atomizing air to waste liquid or fuel) on all enabled fuels and waste liquids
 - Low Liquid Pressure on all enabled fuels and waste liquids
 - Disabling all fuels and waste liquids
 - Manual shutdown of BMS

- k) Kiln Aqueous Lance (A-102)
 - Kiln aqueous low pressure switch, PSL-1157A
 - Kiln aqueous atomizing air low pressure switch, PSL-1156A
 - High Kiln aqueous flow rate, FAH-1151, >1350 lb/hr, HRA or > 60 lb/min for 15 sec

- l) South ABC Corrosive Lance (A-106B-5)
 - South ABC corrosive atomizing air low pressure switch, PSL-3382
 - Loss of both blend liquid feed to A-106B-1 and fuel oil to A-106B-2

COMBINED A-106A AND A-106B WASTE FEED CUTOFF CAUSES (6)

- a) North and South ABC Blend Liquid Guns (A-106A and A-106B-1), South ABC Cylinder Feed (A-106B-3), and Corrosive Direct Burn Feed (A-106B-5) (when the waste has a heat content equal to or greater than 5000 Btu per pound)
 - High combined North and South ABC blend liquid/gas/corrosive direct burn (when the waste has a heat content equal to or greater than 5000 Btu per pound) flow rate, FAH-1290, >3720 lb/hr, HRA

COMBINED A-105A AND A-105B WASTE FEED CUTOFF CAUSES (7)

- a) North and South ABC Aqueous Lances (A-105A and A-105B) and Corrosive Direct Burn burner (A-106B-5) (when the waste being fed has a heat content less than 5000 Btu per pound)
 - High combined North and South ABC aqueous flow rate, and Corrosive Direct Burn flow rate (when the waste being fed has a heat content less than 5000 Btu per pound), FAH-1270, >6440 lb/hr, HRA

COMBINED SOUTH ABC BURNER (A-106B) WASTE FEED CUTOFF CAUSES (8)

- a) South ABC Blend Liquid Guns (A-106B-1, A-106B-3 and A-106B-5 (when the waste being fed from the drive through corrosive direct burn system has a heat content equal to or greater than 5000 Btu per pound))
 - South ABC blend liquid low pressure switch PSL-1196
 - South ABC atomizing air/waste liquid differential low pressure switch, PDSL-1224
 - High South ABC blend liquid/gas/corrosive direct burn (when the waste being fed from the drive through corrosive direct burn system has a heat content equal to or greater than 5000 Btu per pound) flow rate, FAH-1221D, >90 lb/min for 15 sec
- b) South ABC Blend Liquid Guns (A-106B-1 and A-106B-5 (when the waste being fed from the drive through corrosive direct burn system has a heat content equal to or greater than 5000 Btu per pound))
 - Low South ABC blend liquid and corrosive direct burn flow rate (turndown), <1.125 gpm for 15 sec (except during 3 minute gun startup)

COMBINED A-105B AND A-106B WASTE FEED CUTOFF CAUSES (9)

- a) South ABC Aqueous Lance (A-105B) and ABC Blend Liquid Gun (A-106B-5 (when the waste being fed from the drive through corrosive direct burn system has a heat content less than 5000 Btu per pound))
 - High South ABC aqueous and corrosive direct burn (when the waste being fed from the drive through corrosive direct burn system has a heat content less than 5000 Btu per pound) flow rate, FAH-1263D, >60 lb/min for 15 sec
6. The six signals (loss of flame, low combustion air pressure, low atomizing air pressure, low waste liquid pressure, disabling all fuels, and manual shutdown of the BMS) which will cause the Burner Management System on each burner to shut down, causing a waste feed cutoff, are not tested during the weekly waste feed cutoff test. These signals shall be tested periodically in the field at a frequency at least that recommended by the manufacturer. However, the minimum frequency shall be at least quarterly. Documentation of these tests shall be maintained in the facility's operating record.
7. Some causes in section 5 do not create all the effects in section 3. The list of causes with their limited effects follows.

| <u>Cause</u> | <u>Effect</u> |
|--|----------------------------|
| 1) total waste feed cutoff causes | All effects occur |
| 2) total kiln waste feed cutoff causes | 3a, 3b, 3c, 3d, 3j, 3k, 3l |

- | | | |
|-----|--|---|
| 3) | kilo containers, solids, and sludge waste feed cutoff causes | 3a, 3b, 3j, 3l |
| 4) | combined bulk solids and containers waste feed cutoff causes | 3a, 3b |
| 5) | waste feed cutoff to the affected gun/lance/feed mechanism causes | Affected individual waste stream only |
| 6) | combined A-106A, A-106B-1, A-106B-3, and A-106B-5 (when the waste being fed from the drive through corrosive direct burn system has a heat content equal to or greater than 5000 Btu per pound) waste feed cutoff causes | 3e, 3f, 3h, 3m* * when the waste being fed from the drive through corrosive direct burn system has a heat content ≥ 5000 Btu/lb |
| 7) | combined A-105A and A-105B and burner A-106B-5 (when the waste being fed from the drive through corrosive direct burn system has a heat content < 5000 Btu/lb) waste feed cutoff causes | 3g, 3i, 3m* * when the waste being fed from the drive through corrosive direct burn system has a heat content < 5000 Btu/lb |
| 8a) | combined A-106B-1, A-106B-3 and A-106B-5 (when the waste being fed from the drive through corrosive direct burn system has a heat content equal to or greater than 5000 Btu per pound) waste feed cutoff causes | 3f, 3h, 3m* * when the waste being fed from the drive through corrosive direct burn system has a heat content ≥ 5000 Btu/lb |
| 8b) | combined A-106B-1 and A-106B-5 (when the waste being fed from the drive through corrosive direct burn system has a heat content equal to or greater than 5000 Btu per pound) waste feed cutoff causes | 3h, 3m* * when the waste being fed from the drive through corrosive direct burn system has a heat content ≥ 5000 Btu/lb |
| 9) | combined A-105B and A-106B-5 (when the waste being fed from the drive through corrosive direct burn system has a heat content less than 5000 Btu per pound) waste feed cutoff causes | 3i, 3m* * when the waste being fed from the drive through corrosive direct burn system has a heat content < 5000 Btu/lb |
8. Waste feed not operating at the time of the test will not be tested. That is, if the direct burn system is not in use, it will not be set up just for the test. Clean Harbors Aragonite will verify all valves are still shut.

Waste Feed Cutoff Test

Date: _____

Time: _____

| EQUIPMENT | TAG# | STATUS | INITIALS |
|-------------------------------------|----------|--------|----------|
| Bulk Solids: | | | |
| Apron Feeder | SV-1036 | | |
| Upper Flop Gate | SV-1035B | | |
| Lower Flop Gate | SV-1034B | | |
| Kiln Elevator: | | | |
| Slide Gate | SV-1033B | | |
| Direct Burn: | | | |
| Block Valve | SV-1170 | | |
| Control Valve | FV-1171 | | |
| Kiln Liquid Waste Feed: | | | |
| Blended Waste Block Valve | SV-1120 | | |
| Blended Waste Control Valve | FV-1121 | | |
| North ABC Liquid Waste Feed: | | | |
| Blended Waste Block Valve | SV-1183 | | |
| Blended Waste Control Valve | FV-1184 | | |
| Aqueous Block Valve | SV-1252 | | |
| Aqueous Control Valve | FV-1253 | | |
| South ABC Liquid Waste Feed: | | | |
| Blended Waste Block Valve | SV-1220 | | |
| Blended Waste Control Valve | FV-1221 | | |
| Aqueous Block Valve | SV-1262 | | |
| Aqueous Control Valve | FV-1263 | | |
| Cylinder Block Valve | SV-1103 | | |
| Cylinder Control Valve | SV-1104 | | |
| Corrosive Waste Block Valve | SV-3364 | | |
| Corrosive Waste Control Valve | FV-3365 | | |
| Kiln Sludge Feed: | | | |
| Sludge Control Valve | PV-4021 | | |
| Sludge Block Valve | SV-4022 | | |
| Drum Pumping Station: | | | |
| Drum Pumping Station Block Valve | SV-3016 | | |
| Kiln Aqueous Feed: | | | |
| Aqueous Block Valve | SV-1150 | | |
| Aqueous Control Valve | FV-1151 | | |