



State of Utah

GARY R. HERBERT
Governor

SPENCER J. COX
Lieutenant Governor

Department of
Environmental Quality

Alan Matheson
Executive Director

DIVISION OF WATER QUALITY
Walter L. Baker, P.E.
Director

April 13, 2016

DIVISION OF WATER QUALITY
UTAH DEPARTMENT OF ENVIRONMENTAL QUALITY
PUBLIC NOTICE TO REISSUE A UPDES PERMIT

PURPOSE OF PUBLIC NOTICE

The purpose of this public notice is to declare the state of Utah's intention to modify a Utah Pollutant Discharge Elimination System (UPDES) permit under authority of the Utah Water Pollution Control Act, Section 19-5-104(9) and 107(2), Utah Code Annotated 1953, as amended. Said "permit" refers to the UPDES permit and the statement of basis (including total maximum daily loads (TMDL's) if applicable, as per section 303(d) of the Federal Clean Water Act (CWA).

PERMIT INFORMATION

PERMITTEE NAME: Fresenius Medical Care
MAILING ADDRESS: 475 West 13th Street, Ogden, UT 84404
TELEPHONE NUMBER: 801-626-4515
FACILITY LOCATION: 475 West 13th Street, Ogden, UT 84404
UPDES PERMIT NO.: UT0023752
PERMITTED OUTFALLS 001
RECEIVING WATER: Mill Creek

BACKGROUND

The plant was remodeled in 2006 to its current standards. FMC has a Standard Industrial Classification (SIC) code of 3841 for Surgical and Medical Instruments and 2834 for Pharmaceutical Preparations. FMC's discharge is located at latitude 41° 14' 32.38" and longitude 111° 59' 22.42", in Weber County, Utah. It has STORET number 492306 and one discharge point, Outfall 001. All water discharged by FMC is derived from the Ogden City culinary water system. The approximately 21,500 gallons per day of non-contact cooling water from the production heat exchanger, along with storm water from the roof, is discharged to the storm drain which flows to Mill Creek. Five years of self-monitoring shows that FMC has had one violation of their effluent limits with one BOD₅ exceedance measured at 47.5 mg/L.

PUBLIC COMMENTS

Public comments are invited any time prior to the deadline of the close of business on May 16, 2016. Written public comments can be submitted to: Ken Hoffman, UPDES Surface Water Section, Utah Division of Water Quality, P.O. Box 144870, Salt Lake City, Utah 84114-4870 or by email at: kenhoffman@utah.gov. After considering public comment the Director of the Division of Water Quality may execute the modified permit issuance, revise it, or abandon it. The permit is available for public review under "Public Notices" at www.waterquality.utah.gov/info/notices. If internet access is not available, a copy may be obtained by calling Ken Hoffman at 801-536-4313.