

**ATTACHMENT 6**

**PREPAREDNESS AND PREVENTION MEASURES**



## **Contents**

---

<b>1.0</b>	<b>Design and Operation of Facility .....</b>	<b>6-1</b>
<b>2.0</b>	<b>Required Equipment .....</b>	<b>6-1</b>
<b>3.0</b>	<b>Testing and Maintenance of Equipment .....</b>	<b>6-1</b>



**1.0 Design and Operation of Facility [R315-8-3.2]**

**1.0.1** The facility shall be designed, constructed, maintained, and operated to minimize the potential for fire, explosion, or discharge of hazardous wastes to the environment.

**2.0 Required Equipment [R315-8-3.3]**

**2.0.1** The facility shall be equipped with an internal communication or alarm system, a device capable of summoning external emergency assistance, portable fire extinguishers, and water at adequate volume and pressure.

**2.1 Internal Communications [R315-8-3.3(a)]**

**2.1.1** Employees involved with the pouring, mixing, or otherwise handling of hazardous waste shall have immediate access to an internal alarm or emergency communication device. If there is only one employee at the Hazardous Waste Storage Facility (HWSF) during operation, that employee shall have access to a telephone that is immediately available or a hand-held two-way radio or cell phone capable of summoning external emergency assistance.

**2.2 External Communications [R315-8-3.3(b)]**

**2.2.1** Access to communications equipment shall be provided during normal operating hours by the Hill AFB telephone system. The closest phones are located at Building 888 on the west side and at Building 898 on both the east and west sides. During non-operating hours, surveillance and emergency communications are provided by Hill AFB two-way radio system or a cell phone.

**2.3 Emergency Equipment [R315-8-3.3(c)]**

**2.3.1** Fire, spill control, and decontamination equipment, as described in Attachment 7 of this Permit, shall be maintained at the HWSF. Fire extinguishers shall be located at each exit of Buildings 888 and 898. Building 888 shall be equipped with an automated fire suppression system.

**2.4 Water for Fire Control [R315-8-3.3(d)]**

**2.4.1** Water for fire control shall have adequate volume and pressure. One fire hydrant is located within the fenced area of the HWSF to the north of the main gate and another located outside of the fenced perimeter to the south of the main gate.

**3.0 Testing and Maintenance of Equipment [R315-8-3.4]**

**3.0.1** HWSF communications or alarm systems, fire protection equipment, safety equipment, discharge control equipment, and decontamination equipment, shall be inspected and tested according to Attachment 4 of this Permit and maintained to assure its proper operation in time of emergency.