



State of Utah

GARY R. HERBERT
Governor

GREG BELL
Lieutenant Governor

Department of
Environmental Quality

Amanda Smith
Executive Director

DIVISION OF WATER QUALITY
Walter L. Baker, P.E.
Director

SEP 30 2013

CERTIFIED MAIL
(Return Receipt Requested)

Shane Paddock
Jordanelle Special Service District Water Reclamation Facility
P.O. Box 519
Heber City, UT 84032

Dear Mr. Paddock:

Subject: UPDES Permit UT0025747, Jordanelle Special Service District Water
Reclamation Facility

Enclosed is a draft copy of the UPDES Permit No. UT0025747, the Statement of Basis, and the
Public Notice for your facility.

If you have any questions with regards to this matter, please contact Matthew Garn at
mgarn@utah.gov or at (801) 536-4381.

Sincerely,

John Kennington, P.E., Manager
UPDES Engineering Section

JK:MG:ev:mc

- Enclosures (6):
1. Letter to Newspaper, (DWQ-2013-006592)
 2. Public Notice, (DWQ-2013-006593)
 3. Fact Sheet Statement of Basis, (DWQ-2013-006405)
 4. Waste Load Analysis, (DWQ-2013-006407)
 5. Antidegradation Level, (DWQ-2013-006404)
 6. Permit, (DWQ-2013-006406)

cc: Amy Clark, EPA Region VIII (via e-mail) (w/ encl)

Robert Swensen, Summit County Public Health Department (w/o encl)

Jim Karpowitz, Utah Division of Wildlife Resources (w/o encl)

Chris Cline, U.S. Fish & Wildlife Services (w/o encl)

Michael Duggin, Mayor, Town of Daniel (w/o encl)

Richard Bay, General Manager, Jordan Valley Water Conservancy District (w/o encl)

Michael L. Wilson, General Manager, Metropolitan Water District (w/o encl)

Don Christiansen, General Manager, Central Utah Water Conservancy District w/o encl)

Jesse Stewart, Water Quality and Treatment, Salt Lake City Corporation (w/o encl)



State of Utah

GARY R. HERBERT
Governor

GREG BELL
Lieutenant Governor

Department of
Environmental Quality

Amanda Smith
Executive Director

DIVISION OF WATER QUALITY
Walter L. Baker, P.E.
Director

September 30, 2013

Wasatch Wave
675 West 100 South
P.O. Box 128
Heber City, UT 84032-2001

Email: legals@wasatchwave.com

ATTN: Legal Advertising Department

This letter will confirm authorization to publish the attached NOTICE in The Wasatch Wave in the first available edition. Please mail the invoice and affidavit of publication to:

Department of Environmental Quality
Division of Water Quality
Attn: Stacy Carroll
P.O. Box 144870
Salt Lake City, Utah 84114-4870

If there are any questions, please contact Edith Van Vleet at (801) 536-4397. Thank you for your assistance.

Sincerely,

A handwritten signature in blue ink, appearing to read "John Kennington".

John Kennington, P.E., Manager
UPDES Engineering Section

JK:MG:ev:mc



State of Utah

GARY R. HERBERT
Governor

GREG BELL
Lieutenant Governor

Department of
Environmental Quality

Amanda Smith
Executive Director

DIVISION OF WATER QUALITY
Walter L. Baker, P.E.
Director

OCTOBER 2, 2013

DIVISION OF WATER QUALITY
UTAH DEPARTMENT OF ENVIRONMENTAL QUALITY
PUBLIC NOTICE OF RENEWAL OF UPDES PERMIT

PURPOSE OF PUBLIC NOTICE

THE PURPOSE OF THIS PUBLIC NOTICE IS TO DECLARE THE STATE OF UTAH'S INTENTION TO REISSUE A UTAH POLLUTANT DISCHARGE ELIMINATION SYSTEM (UPDES) PERMIT UNDER AUTHORITY OF THE UTAH WATER POLLUTION CONTROL ACT, SECTION 19-5-104(9) AND 107(2), UTAH CODE ANNOTATED 1953, AS AMENDED. SAID "PERMIT" REFERS TO THE UPDES PERMIT AND THE STATEMENT OF BASIS (INCLUDING TOTAL MAXIMUM DAILY LOADS (TMDL'S)) IF APPLICABLE, AS PER SECTION 303(D) OF THE FEDERAL CLEAN WATER ACT (CWA)].

PERMIT INFORMATION

PERMITTEE NAME:	Jordanelle Special Service District Water Reclamation Facility
MAILING ADDRESS:	P.O. Box 519, Heber City, UT 84032
TELEPHONE NUMBER:	435-330-0475
FACILITY LOCATION:	5400 North Old Hwy 40, Heber City, UT 84032
UPDES PERMIT NO.:	UT0025747
PERMITTED OUTFALLS	001, 002, 003, 004
RECEIVING WATERS:	Provo River, Provo River Return Canal, Timpanogos Canal, Wasatch Canal

BACKGROUND

Jordanelle Special Service District Water Reclamation Facility has a design flowrate of 1.0 million gallons per day (MGD). The facility serves the developments in the area of Jordanelle Reservoir north of Heber City in Wasatch County, UT. The facility's flow passes through; fine screens, and then through a series of anaerobic and aerobic tanks (which is a biological aid in the removal of phosphorous), then through a membrane bio-reactor (which will include the addition of alum for further phosphorous removal), then through an ultra violet (UV) disinfection system. The solids handling consist of an aerated solids handling basin and a belt press for dewatering.

PUBLIC COMMENTS

Public comments are invited any time prior to the deadline of the close of business on November 4, 2013. Written public comments can be submitted to: Matthew Garn, UPDES Engineering Section, Utah Division of Water Quality, P.O. Box 144870, Salt Lake City, Utah 84114-4870 or by email at: mgarn@utah.gov. After considering public comment the Director of the Division of Water Quality may execute the permit issuance, revise it, or abandon it.

FURTHER INFORMATION

The permit is available for public review under "Public Participation" at www.waterquality.utah.gov/. If internet access is not available, a copy may be obtained by calling Matthew Garn at 801-536-4381.

Official Draft Public Notice Version: October 2, 2013

The findings, determinations, and assertions contained in this document are not final and subject to change following the public comment period.

**FACT SHEET STATEMENT OF BASIS
JORDANELLE SPECIAL SERVICE DISTRICT WATER RECLAMATION FACILITY
PERMIT: DISCHARGE, BIOSOLIDS & STORM WATER
UPDES PERMIT NUMBER: UT0025747
UPDES BIOSOLIDS PERMIT NUMBER: UTL-025747
UPDES MULTI-SECTOR STORM WATER GENERAL PERMIT NUMBER: UTR000000
MAJOR MUNICIPAL**

FACILITY CONTACTS

Person Name:	Dan Matthews
Position:	General Manager
Facility Name:	Jordanelle SSD WRF
Mailing Address:	P.O. Box 519 Heber City, UT 84032
Telephone:	(435) 333-0475
Actual Address:	5400 North Old Hwy 40 Heber City, UT 84032

DESCRIPTION OF FACILITY

Jordanelle Special Service District Water Reclamation Facility (JSSDWRF) has a design flowrate of 1.0 million gallons per day (MGD). The facility serves the developments in the area of Jordanelle Reservoir north of Heber City in Wasatch County, UT. The facility's flow passes through; fine screens, and then through a series of anaerobic and aerobic tanks (which is a biological aid in the removal of phosphorous), then through a membrane bio-reactor (which will include the addition of alum for further phosphorous removal), then through an ultra violet (UV) disinfection system. The solids handling consists of an aerated solids handling basin and a belt press for dewatering.

SUMMARY OF CHANGES FROM PREVIOUS PERMIT

The effluent limit for ammonia has been removed from this permit. The previous permit had an ammonia limit only because JSSDWRF elected not to complete an Antidegradation Level II Review for the previous permit cycle. With the application of the permit renewal, DWQ required JSSDWRF to complete an Antidegradation Level II Review. The Antidegradation Level II review was found to be complete by DWQ staff. With the treatment process that is used at JSSDWRF and the water quality standard for ammonia as calculated in the wasteload analysis, there is no reasonable potential that the water quality standard for ammonia will be violated. However, JSSDWRF will continue to monitor for ammonia.

NARRATIVE

JSSDWRF is located near the Provo River, which is a drinking water source and classified as a blue ribbon fishery. The discharge of JSSDWRF is located in the Provo River Watershed, which has an approved TMDL for a Phosphorous based beneficial use impairment. The total phosphorous calculation in the permit is flow proportioned based on Central Utah Water Conservancy District (CUWCD) flow data of water from the Timpanogos and Wasatch canals that return to the Provo River. The flow proportioned data from CUWCD will be reevaluated every permit cycle.

There is also a signed memorandum of agreement between Jordanelle Special Service District, CUWCD, and the Department of Interior (DOI) which allows JSSDWRF to discharge to the DOI owned canals that are operated by CUWCD. This agreement prohibits a discharge to the Provo River, but does allow for a direct discharge option in the event of the termination of the agreement.

There is also a memorandum signed by the Heber Valley Special Service District (HVSSD) board members, which allows JSSDWRF to divert the discharge in emergency situations or times when the effluent quality does not meet discharge standards to HVSSD.

DISCHARGE

DESCRIPTION OF DISCHARGES

Discharge Points		
Outfall Number	Location of Discharge Points	Receiving Waters
001	Latitude 40°34'24" Longitude 111°25'28"	Timpanogos Canal
002	Latitude 40°34'04" Longitude 111°25'39"	Wasatch Canal
003	Latitude 40°34'24" Longitude 111°25'40"	Provo River Return Canal
004	Latitude 40°34'20" Longitude 111°25'42"	Provo River

RECEIVING WATERS AND STREAM CLASSIFICATION

The final discharge flows into the Provo River. The Provo River has been classified as Class 1C, 2B, 3A, and 4 according to *Utah Administrative Code (UAC) R317-2-13*.

- Class 1C -Protected for domestic purposes with prior treatment by treatment processes as required by the Utah Division of Drinking Water.
- Class 2B -Protected for secondary contact recreation such as boating, wading, or similar uses.
- Class 3A -Protected for cold water species of game fish and other cold water aquatic life, including the necessary aquatic organisms in their food chain.

Class 4 -Protected for agricultural uses including irrigation of crops and stock watering.

BASIS FOR EFFLUENT LIMITATIONS

Limitations on total suspended solids (TSS), and biochemical oxygen demand (BOD₅) that are more restrictive than secondary standards are incorporated because the Provo River is designated as a blue ribbon fishery and a drinking water source. Limitations for E. Coli, pH, total dissolved solids (TDS), and percent removal for BOD₅ and TSS are based on current Utah Secondary Treatment Standards, *UAC R317-1-3.2*. The Dissolved oxygen limit and WET limit are based on the Waste Load Analysis (WLA). The total phosphorous limitation is based on a Total Maximum Daily Load (TMDL) study that has been approved by EPA and is based upon best available treatment technology. The oil and grease is based on best professional judgment (BPJ). The permit limitations are:

Effluent Limitations (Outfalls 001, 002, 003, 004) a/						
Parameter	Yearly Maximum	90 Day Average	Monthly Average	Maximum Weekly Average	Daily Minimum	Daily Maximum
Total Flow, MGD	NA	NA	1.0	NA	NA	NA
BOD ₅ , mg/L	NA	NA	10	10	NA	NA
BOD ₅ , Minimum % Removal	NA	NA	85	NA	NA	NA
TSS, mg/L	NA	NA	10	10	NA	NA
TSS, Minimum % Removal	NA	NA	85	NA	NA	NA
E. Coli, no./100mL	NA	NA	126	157	NA	NA
Dissolved Oxygen, mg/L	NA	NA	NA	NA	5.0	NA
TDS, mg/L	NA	NA	NA	NA	NA	1200
Total Phosphorous, mg/L (Interim) e/	NA	NA	NA	NA	NA	0.15
Total Phosphorous, mg/L (May-Oct), (Final)	NA	0.03	NA	NA	NA	0.08
Total Phosphorous, mg/L (Nov-April), (Final)	NA	0.06	NA	NA	NA	0.10
Total Phosphorous, lbs/year h/	91	NA	NA	NA	NA	NA
Oil & Grease, mg/L	NA	NA	NA	NA	NA	10.0
pH, Standard Units	NA	NA	NA	NA	6.5	9.0
WET, Acute Biomonitoring g/	NA	NA	NA	NA	NA	LC ₅₀ > 8.3% effluent
WET, Chronic Biomonitoring g/	NA	NA	NA	NA	NA	IC ₂₅ > 1.2% effluent

NA – Not Applicable.

SELF-MONITORING AND REPORTING REQUIREMENTS

The permit will require reports to be submitted monthly and quarterly, as applicable, on Discharge Monitoring Report (DMR) forms due 28 days after the end of the monitoring period. Lab sheets for biomonitoring must be attached to the biomonitoring DMR.

Self-Monitoring and Reporting Requirements a/			
Parameter	Frequency	Sample Type	Units
Total Flow b/ c/	Continuous	Recorder	MGD
BOD ₅ , Influent d/	2 x Week	Composite	mg/L
BOD ₅ , Effluent	2 x Week	Composite	mg/L
BOD ₅ , Minimum % Removal	2 x Week	Calculation	%
TSS, Influent d/	2 x Week	Composite	mg/L
TSS, Effluent	2 x Week	Composite	mg/L
TSS, Minimum % Removal	2 x Week	Calculation	%
E. Coli f/	2 x Week	Grab	mg/L
Dissolved Oxygen	2 x Week	Grab	mg/L
TDS	2 x Week	Grab	mg/L
Total Phosphorus h/	2 x Week	Grab	mg/L
Ammonia	2 x Week	Grab	mg/L
Oil & Grease	Monthly If Sheen is Observed	Grab	mg/L
pH	2 x Week	Grab	SU
WET, Acute Biomonitoring g/	Quarterly	Composite	Pass/Fail
WET, Chronic Biomonitoring g/	Quarterly	Composite	Pass/Fail
Metals, Influent	2 x Year	Composite	mg/L
Metals, Effluent	2 x Year	Composite	mg/L
Organic Toxics	2 nd & 4 th Year	Grab	mg/L

a/ See Definitions, *Part VIII*, for definition of terms.

b/ Flow measurements of influent/effluent volume shall be made in such a manner that JSSDWRF can affirmatively demonstrate that representative values are being obtained.

c/ If the rate of discharge is controlled, the rate and duration of discharge shall be reported.

d/ In addition to monitoring the final discharge, influent samples shall be taken and analyzed for this constituent at the same frequency as required for this constituent in the discharge.

- e/ The interim limit is provided to allow a period of time to optimize the process upon start-up of the facility. The interim limit will expire 2 years after the start-up of the facility. Prior to start-up, JSSDWRF must submit documentation of anticipated initial discharge date, to DWQ.
- f/ In order to ensure multiple treatment barriers for the removal of pathogens for human health protection, JSSDWRF will be required to continually operate the Ultra Violet (UV) disinfection system at the manufacturers recommended intensity.
- g/ Discharges to either outfall 001 or outfall 002 are not required to monitor or report for WET if there is no discharge during the reporting period, however if any discharge occurs to either outfall 003 or outfall 004 for any duration during the reporting period JSSDWRF is required to sample, monitor, and report for WET.
- h/ For calculating the yearly Total Phosphorous load use the following equation: Total load for outfall 001*0.05 + total load for outfall 002*0.50 + total load for outfall 003 + total load for outfall 004. This flow proportioned data is based on average flow data from CUWCD, who operate the canals.

Should JSSDWRF not comply with permit conditions, including but not limited to the yearly maximum load for phosphorous, JSSDWRF will divert the effluent discharge to the Heber Valley SSD lagoons by pipeline in accordance with the agreement between JSSDWRF and Heber Valley SSD. This option would be considered an approved and the preferred option for any bypass or upset condition of the treatment facilities as stated in Part VI.G and Part VI.H of this permit.

BIOSOLIDS

DESCRIPTION OF BIOSOLIDS TREATMENT AND DISPOSAL

JSSDWRF screens the influent to remove the larger pieces of debris and the solids are stabilized with activated sludge treatment with a mean cell residence time of approximately 14 days with a new, state of the art membrane bioreactor plant. After stabilization, the biosolids are de-watered with a belt press and loaded into a hopper trailer to be hauled elsewhere for disposal. Since this is a new water reclamation facility, the biosolids will probably be disposed in a landfill; or may be hauled to a composting site at another location for further treatment¹, or may be hauled to a soil regeneration facility such as ET Technologies for final landfill cover at the Salt Lake County Landfill.

¹If the biosolids are hauled to another facility to meet land application requirements for sale or giveaway to the public, that facility must have a valid UPDES biosolids permit and will be responsible for meeting all requirements of *40 CFR 503*.

BIOSOLIDS MONITORING REQUIREMENTS

Under *40 CFR 503* biosolids are not required to be monitored for heavy metals content or pathogen reduction if the biosolids are disposed in a landfill.

LANDFILL MONITORING

Under 40 CFR 258, landfill monitoring requirements, the biosolids will need to pass a paint filter test before the biosolids are disposed of in a landfill. If the biosolids do not pass a paint filter test, the biosolids cannot be disposed in a landfill.

Under 40 CFR 503.33, the biosolids need to meet a method of vector attraction reduction (VAR). Since the biosolids will be disposed of at a landfill, JSSDWRF will need to insure that the biosolids are covered daily with soil or another approved material. If the biosolids are not covered daily, the biosolids cannot be disposed in the landfill.

LIMITATIONS AND SELF-MONITORING REQUIREMENTS

Under 40 CFR 503.16(a)(1), the self-monitoring requirements are based upon the amount of biosolids disposed per year and shall be monitored according to the chart below.

Minimum Frequency of Monitoring Based Upon Dry Metric Tons (DMT)	
Amount of Biobiosolids Disposed Per Year	Monitoring Frequency
> 0 to < 290 DMT	Once Per Year

Accordingly, JSSDWRF needs to monitor at least once per year.

MONITORING DATA

Since this is new facility there is not any monitoring data.

RECORD KEEPING

The record keeping requirements from 40 CFR 503.17 are included under Part III.I. of the permit. Since the biosolids are disposed in a landfill the disposal records need to be retained for a minimum of five years.

REPORTING

The JSSDWRF needs to report annually as required in 40 CFR 503.18. This report is to include the results of all monitoring performed in accordance with Part III.G. of the permit, information on management practices, biosolids treatment, and certifications. This report is due no later than February 19 of each year. Each report is for the previous calendar year.

WASTE LOAD ANALYSIS AND ANTIDegradation REVIEW

Effluent limitations are also derived using a waste load analysis (WLA), which is appended to this statement of basis as ADDENDUM. The WLA incorporates Secondary Treatment Standards, Water Quality Standards, Antidegradation Reviews (ADR), as appropriate and designated uses into a water quality model that projects the effects of discharge concentrations on receiving water quality. Effluent limitations are those that the model demonstrates are sufficient to meet State water quality standards in the receiving waters. During the UPDES permit development, a WLA and ADR were performed. An ADR Level I review was performed and the conclusion was that an ADR level II review was required, because the receiving water or downstream water is a 1C drinking water source. A copy of the ADR Level II is appended to this document.

STORM WATER

STORMWATER REQUIREMENTS

Storm water provisions are included in this combined UPDES permit.

The storm water requirements are based on the UPDES Multi-Sector General Permit for Storm Water Discharges for Industrial Activity, General Permit No. UTR000000 (MSGP). All sections of the MSGP that pertain to discharges from wastewater treatment plants have been included and sections which are redundant or do not pertain have been deleted.

The permit requires the preparation and implementation of a storm water pollution prevention plan for all areas within the confines of the plant. Elements of this plan are required to include:

1. The development of a pollution prevention team.
2. Development of drainage maps and materials stockpiles.
3. An inventory of exposed materials
4. Spill reporting and response procedures.
5. A preventative maintenance program.
6. Employee training.
7. Certification that storm water discharges are not mixed with non-storm water discharges.
8. Compliance site evaluations and potential pollutant source identification, and
9. Visual examinations of storm water discharges.

PRETREATMENT REQUIREMENTS

Although JSSDWRF does not have to develop a State-approved pretreatment program, any wastewater discharges to the sanitary sewer are subject to Federal, State and local regulations. Pursuant to *Section 307 of the Clean Water Act*, the permittee shall comply with all applicable Federal General Pretreatment Regulations promulgated, found in *40 CFR 403* and the State Pretreatment Requirements found in *UAC R317-8-8*.

The permittee has not been designated for pretreatment program development because it does not meet conditions which necessitate a full program. The flow through the plant is less than five (5) MGD, there are no categorical industries discharging to the treatment facility, industrial discharges comprise less than 1 percent of the flow through the treatment facility, and there is no indication of pass through or interference with the operation of the treatment facility such as upsets or violations of the POTW's UPDES permit limits. Authority to require a pretreatment program is provided for in *19-5-108 UCA, 1953 ann.* and *UAC R317-8-8*.

JSSDWRF shall perform an annual evaluation of the need to develop technically based local limits to implement the general and specific prohibitions of 40 CFR Part 403.5(a) and Part 403.5(b). As part of this evaluation, the permit requires 2 x year influent and effluent monitoring for metals and organic toxics listed in R317-8-7.5 in the 2nd and 4th year of the permit, and sludge monitoring for potential pollutants listed in 40 CFR 503.

BIOMONITORING REQUIREMENTS

As part of a nationwide effort to control toxic discharges, biomonitoring requirements are being included in permits for facilities where effluent toxicity is an existing or potential concern. In Utah, this is done in accordance with the *State of Utah Permitting and Enforcement Guidance Document for Whole Effluent Toxicity Control (Biomonitoring (2/1991))*. Authority to require effluent biomonitoring is provided in *Utah Pollutant Discharge Elimination System UAC R317-8*, and *Water Quality Standards UAC R317-2*.

Since JSSDWRf is a major municipal discharger, the permit will require whole effluent toxicity (WET) testing for outfalls 003 and 004. Acute and chronic toxicity testing will be conducted quarterly using both the Ceriodaphnia dubia and Pimephales promelas (fathead minnows) species. The permit will contain the standard requirements for accelerated testing upon failure of a WET test, a Preliminary Toxicity Investigation (PTI) and Toxicity Reduction Evaluation (TRE) as necessary, and a toxicity limitation re-opener provision.

PERMIT DURATION

It is recommended that this permit be effective for a duration of five (5) years.

Drafted by
Matthew Garn
Utah Division of Water Quality
September 16, 2013

PUBLIC NOTICE

Began:
Ended:
Public Noticed in

Utah Division of Water Quality
Salt Lake City, Utah

**WASTELOAD ANALYSIS [WLA]
Addendum: Statement of Basis
SUMMARY**

Discharging Facility: JSSD - WWTP
UPDES No: UT-0025747
Current Flow: 1.00 MGD Design Flow
Design Flow 1.00 MGD

Receiving Water: Provo River
Stream Classification: 1C, 2B, 3A, 4
Stream Flows [cfs]:
125.0 Summer (July-Sept) Minimum Flow
125.0 Fall (Oct-Dec) Minimum Flow
125.0 Winter (Jan-Mar) Minimum Flow
125.0 Spring (Apr-June) Minimum Flow
288.6 Average
Stream TDS Values:
126.4 Summer (July-Sept) Average
139.3 Fall (Oct-Dec) Average
154.2 Winter (Jan-Mar) Average
128.1 Spring (Apr-June) Average

Effluent Limits:	WQ Standard:		
Flow, MGD:	1.00 MGD	Design Flow	
BOD, mg/l:	25.0 Summer	5.0	Indicator
Dissolved Oxygen, mg/l	5.0 Summer	6.5	30 Day Average
TNH3, Chronic, mg/l:	312.1 Summer	Varies Function of pH and Temperature	
TDS, mg/l:	87948.5 Summer	1200.0	

Modeling Parameters:
Acute River Width: 50.0%
Chronic River Width: 100.0%

Level 1 Antidegradation Level Completed: Level II Review required. 1C drinking water source.

Date: 8/6/2013

Permit Writer: _____
WLA by: _____
WQM Sec. Approval: _____
TMDL Sec. Approval: _____

Utah Division of Water Quality
Salt Lake City, Utah

WASTELOAD ANALYSIS [WLA]
Addendum: Statement of Basis

6-Aug-13
4:00 PM

Facilities: JSSD - WWTP
Discharging to: Provo River

UPDES No: UT-0025747

THIS IS A DRAFT DOCUMENT

I. Introduction

Wasteload analyses are performed to determine point source effluent limitations necessary to maintain designated beneficial uses by evaluating projected effects of discharge concentrations on in-stream water quality. The wasteload analysis also takes into account downstream designated uses [R317-2-8, UAC]. Projected concentrations are compared to numeric water quality standards to determine acceptability. The anti-degradation policy and procedures are also considered. The primary in-stream parameters of concern may include metals (as a function of hardness), total dissolved solids (TDS), total residual chlorine (TRC), un-ionized ammonia (as a function of pH and temperature, measured and evaluated in terms of total ammonia), and dissolved oxygen.

Mathematical water quality modeling is employed to determine stream quality response to point source discharges. Models aid in the effort of anticipating stream quality at future effluent flows at critical environmental conditions (e.g., low stream flow, high temperature, high pH, etc).

The numeric criteria in this wasteload analysis may always be modified by narrative criteria and other conditions determined by staff of the Division of Water Quality.

II. Receiving Water and Stream Classification

Provo River:	1C, 2B, 3A, 4
Antidegradation Review:	Level I review completed. Level II review required. 1C Drinking water source.

III. Numeric Stream Standards for Protection of Aquatic Wildlife

Total Ammonia (TNH3)	Varies as a function of Temperature and pH Rebound. See Water Quality Standards
Chronic Total Residual Chlorine (TRC)	0.011 mg/l (4 Day Average) 0.019 mg/l (1 Hour Average)
Chronic Dissolved Oxygen (DO)	6.50 mg/l (30 Day Average) 5.00 mg/l (7Day Average) 4.00 mg/l (1 Day Average)
Maximum Total Dissolved Solids	1200.0 mg/l

**Utah Division of Water Quality
Salt Lake City, Utah**

Acute and Chronic Heavy Metals (Dissolved)

Parameter	4 Day Average (Chronic) Standard		1 Hour Average (Acute) Standard		
	Concentration	Load*	Concentration		Load*
Aluminum	87.00 ug/l**	0.725 lbs/day	750.00	ug/l	6.254 lbs/day
Arsenic	190.00 ug/l	1.584 lbs/day	340.00	ug/l	2.835 lbs/day
Cadmium	0.27 ug/l	0.002 lbs/day	2.09	ug/l	0.017 lbs/day
Chromium III	84.83 ug/l	0.707 lbs/day	1774.73	ug/l	14.798 lbs/day
ChromiumVI	11.00 ug/l	0.092 lbs/day	16.00	ug/l	0.133 lbs/day
Copper	9.18 ug/l	0.077 lbs/day	13.75	ug/l	0.115 lbs/day
Iron			1000.00	ug/l	8.338 lbs/day
Lead	3.10 ug/l	0.026 lbs/day	79.66	ug/l	0.664 lbs/day
Mercury	0.0120 ug/l	0.000 lbs/day	2.40	ug/l	0.020 lbs/day
Nickel	51.32 ug/l	0.428 lbs/day	461.56	ug/l	3.849 lbs/day
Selenium	4.60 ug/l	0.038 lbs/day	20.00	ug/l	0.167 lbs/day
Silver	N/A ug/l	N/A lbs/day	3.66	ug/l	0.031 lbs/day
Zinc	117.87 ug/l	0.983 lbs/day	117.87	ug/l	0.983 lbs/day

* Allowed below discharge

**Chronic Aluminum standard applies only to waters with a pH < 7.0 and a Hardness < 50 mg/l as CaCO3

Metals Standards Based upon a Hardness of 98.09 mg/l as CaCO3

Organics [Pesticides]

Parameter	4 Day Average (Chronic) Standard		1 Hour Average (Acute) Standard		
	Concentration	Load*	Concentration		Load*
Aldrin			1.500	ug/l	0.013 lbs/day
Chlordane	0.004 ug/l	2.933 lbs/day	1.200	ug/l	0.010 lbs/day
DDT, DDE	0.001 ug/l	0.682 lbs/day	0.550	ug/l	0.005 lbs/day
Dieldrin	0.002 ug/l	1.296 lbs/day	1.250	ug/l	0.010 lbs/day
Endosulfan	0.056 ug/l	38.197 lbs/day	0.110	ug/l	0.001 lbs/day
Endrin	0.002 ug/l	1.569 lbs/day	0.090	ug/l	0.001 lbs/day
Guthion			0.010	ug/l	0.000 lbs/day
Heptachlor	0.004 ug/l	2.592 lbs/day	0.260	ug/l	0.002 lbs/day
Lindane	0.080 ug/l	54.567 lbs/day	1.000	ug/l	0.008 lbs/day
Methoxychlor			0.030	ug/l	0.000 lbs/day
Mirex			0.010	ug/l	0.000 lbs/day
Parathion			0.040	ug/l	0.000 lbs/day
PCB's	0.014 ug/l	9.549 lbs/day	2.000	ug/l	0.017 lbs/day
Pentachlorophenol	13.00 ug/l	8867.148 lbs/day	20.000	ug/l	0.167 lbs/day
Toxephene	0.0002 ug/l	0.136 lbs/day	0.7300	ug/l	0.006 lbs/day

**Utah Division of Water Quality
Salt Lake City, Utah**

IV. Numeric Stream Standards for Protection of Agriculture

	4 Day Average (Chronic) Standard		1 Hour Average (Acute) Standard	
	Concentration	Load*	Concentration	Load*
Arsenic			100.0 ug/l	lbs/day
Boron			750.0 ug/l	3.13 lbs/day
Cadmium			10.0 ug/l	0.04 lbs/day
Chromium			100.0 ug/l	lbs/day
Copper			200.0 ug/l	lbs/day
Lead			100.0 ug/l	lbs/day
Selenium			50.0 ug/l	lbs/day
TDS, Summer			1200.0 mg/l	5.00 tons/day

V. Numeric Stream Standards for Protection of Human Health (Class 1C Waters)

Metals	4 Day Average (Chronic) Standard		1 Hour Average (Acute) Standard	
	Concentration	Load*	Concentration	Load*
Arsenic			50.0 ug/l	34.104 lbs/day
Barium			1000.0 ug/l	682.088 lbs/day
Cadmium			10.0 ug/l	6.821 lbs/day
Chromium			50.0 ug/l	34.104 lbs/day
Lead			50.0 ug/l	34.104 lbs/day
Mercury			2.0 ug/l	1.364 lbs/day
Selenium			10.0 ug/l	6.821 lbs/day
Silver			50.0 ug/l	34.104 lbs/day
Fluoride (3)			1.4 ug/l	0.955 lbs/day
to			2.4 ug/l	1.637 lbs/day
Nitrates as N			10.0 ug/l	6.821 lbs/day

Chlorophenoxy Herbicides

2,4-D	100.0 ug/l	68.209 lbs/day
2,4,5-TP	10.0 ug/l	6.821 lbs/day
Endrin	0.2 ug/l	0.136 lbs/day
γ-cyclohexane (Lindane)	4.0 ug/l	2.728 lbs/day
Methoxychlor	100.0 ug/l	68.209 lbs/day
Toxaphene	5.0 ug/l	3.410 lbs/day

VI. Numeric Stream Standards the Protection of Human Health from Water & Fish Consumption [Toxics]

Toxic Organics	Maximum Conc., ug/l - Acute Standards			
	Class 1C [2 Liters/Day for 70 Kg Person over 70 Yr.]		Class 3A, 3B [6.5 g for 70 Kg Person over 70 Yr.]	
Acenaphthene	1200.00 ug/l	818.51 lbs/day	2700.0 ug/l	1841.64 lbs/day
Acrolein	320.00 ug/l	218.27 lbs/day	780.0 ug/l	532.03 lbs/day
Acrylonitrile	0.06 ug/l	0.04 lbs/day	0.7 ug/l	0.45 lbs/day
Benzene	1.20 ug/l	0.82 lbs/day	71.0 ug/l	48.43 lbs/day
Benzidine	0.00012 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
Carbon tetrachloride	0.25 ug/l	0.17 lbs/day	4.4 ug/l	3.00 lbs/day
Chlorobenzene	680.00 ug/l	463.82 lbs/day	21000.0 ug/l	14323.85 lbs/day
1,2,4-Trichlorobenzene				
Hexachlorobenzene	0.00075 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
1,2-Dichloroethane	0.38 ug/l	0.26 lbs/day	99.0 ug/l	67.53 lbs/day

**Utah Division of Water Quality
Salt Lake City, Utah**

1,1,1-Trichloroethane				
Hexachloroethane	1.90 ug/l	1.30 lbs/day	8.9 ug/l	6.07 lbs/day
1,1-Dichloroethane				
1,1,2-Trichloroethane	0.61 ug/l	0.42 lbs/day	42.0 ug/l	28.65 lbs/day
1,1,2,2-Tetrachloroethane	0.17 ug/l	0.12 lbs/day	11.0 ug/l	7.50 lbs/day
Chloroethane			0.0 ug/l	0.00 lbs/day
Bis(2-chloroethyl) ether	0.03 ug/l	0.02 lbs/day	1.4 ug/l	0.95 lbs/day
2-Chloroethyl vinyl ether	0.00 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
2-Chloronaphthalene	1700.00 ug/l	1159.55 lbs/day	4300.0 ug/l	2932.98 lbs/day
2,4,6-Trichlorophenol	2.10 ug/l	1.43 lbs/day	6.5 ug/l	4.43 lbs/day
p-Chloro-m-cresol			0.0 ug/l	0.00 lbs/day
Chloroform (HM)	5.70 ug/l	3.89 lbs/day	470.0 ug/l	320.58 lbs/day
2-Chlorophenol	120.00 ug/l	81.85 lbs/day	400.0 ug/l	272.84 lbs/day
1,2-Dichlorobenzene	2700.00 ug/l	1841.64 lbs/day	17000.0 ug/l	11595.50 lbs/day
1,3-Dichlorobenzene	400.00 ug/l	272.84 lbs/day	2600.0 ug/l	1773.43 lbs/day
1,4-Dichlorobenzene	400.00 ug/l	272.84 lbs/day	2600.0 ug/l	1773.43 lbs/day
3,3'-Dichlorobenzidine	0.04 ug/l	0.03 lbs/day	0.1 ug/l	0.05 lbs/day
1,1-Dichloroethylene	0.06 ug/l	0.04 lbs/day	3.2 ug/l	2.18 lbs/day
1,2-trans-Dichloroethylene	700.00 ug/l	477.46 lbs/day	0.0 ug/l	0.00 lbs/day
2,4-Dichlorophenol	93.00 ug/l	63.43 lbs/day	790.0 ug/l	538.85 lbs/day
1,2-Dichloropropane	0.52 ug/l	0.35 lbs/day	39.0 ug/l	26.60 lbs/day
1,3-Dichloropropylene	10.00 ug/l	6.82 lbs/day	1700.0 ug/l	1159.55 lbs/day
2,4-Dimethylphenol	540.00 ug/l	368.33 lbs/day	2300.0 ug/l	1568.80 lbs/day
2,4-Dinitrotoluene	0.11 ug/l	0.08 lbs/day	9.1 ug/l	6.21 lbs/day
2,6-Dinitrotoluene	0.00 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
1,2-Diphenylhydrazine	0.04 ug/l	0.03 lbs/day	0.5 ug/l	0.37 lbs/day
Ethylbenzene	3100.00 ug/l	2114.47 lbs/day	29000.0 ug/l	19780.56 lbs/day
Fluoranthene	300.00 ug/l	204.63 lbs/day	370.0 ug/l	252.37 lbs/day
4-Chlorophenyl phenyl ether				
4-Bromophenyl phenyl ether				
Bis(2-chloroisopropyl) ether	1400.00 ug/l	954.92 lbs/day	170000.0 ug/l	115955.02 lbs/day
Bis(2-chloroethoxy) methane	0.00 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
Methylene chloride (HM)	4.70 ug/l	3.21 lbs/day	1600.0 ug/l	1091.34 lbs/day
Methyl chloride (HM)	0.00 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
Methyl bromide (HM)	0.00 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
Bromoform (HM)	4.30 ug/l	2.93 lbs/day	360.0 ug/l	245.55 lbs/day
Dichlorobromomethane	0.27 ug/l	0.18 lbs/day	22.0 ug/l	15.01 lbs/day
Chlorodibromomethane	0.41 ug/l	0.28 lbs/day	34.0 ug/l	23.19 lbs/day
Hexachlorobutadiene(c)	0.44 ug/l	0.30 lbs/day	50.0 ug/l	34.10 lbs/day
Hexachlorocyclopentadiene	240.00 ug/l	163.70 lbs/day	17000.0 ug/l	11595.50 lbs/day
Isophorone	8.40 ug/l	5.73 lbs/day	600.0 ug/l	409.25 lbs/day
Naphthalene				
Nitrobenzene	17.00 ug/l	11.60 lbs/day	1900.0 ug/l	1295.97 lbs/day
2-Nitrophenol	0.00 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
4-Nitrophenol	0.00 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
2,4-Dinitrophenol	70.00 ug/l	47.75 lbs/day	14000.0 ug/l	9549.24 lbs/day
4,6-Dinitro-o-cresol	13.00 ug/l	8.87 lbs/day	765.0 ug/l	521.80 lbs/day
N-Nitrosodimethylamine	0.00069 ug/l	0.00 lbs/day	8.1 ug/l	5.52 lbs/day
N-Nitrosodiphenylamine	5.00 ug/l	3.41 lbs/day	16.0 ug/l	10.91 lbs/day
N-Nitrosodi-n-propylamine	0.01 ug/l	0.00 lbs/day	1.4 ug/l	0.95 lbs/day
Pentachlorophenol	0.28 ug/l	0.19 lbs/day	8.2 ug/l	5.59 lbs/day

**Utah Division of Water Quality
Salt Lake City, Utah**

Phenol	2.10E+04 ug/l	1.43E+04 lbs/day	4.6E+06 ug/l	3.14E+06 lbs/day
Bis(2-ethylhexyl)phthala	1.80 ug/l	1.23 lbs/day	5.9 ug/l	4.02 lbs/day
Butyl benzyl phthalate	3000.00 ug/l	2046.26 lbs/day	5200.0 ug/l	3546.86 lbs/day
Di-n-butyl phthalate	2700.00 ug/l	1841.64 lbs/day	12000.0 ug/l	8185.06 lbs/day
Di-n-octyl phthlate				
Diethyl phthalate	23000.00 ug/l	15688.03 lbs/day	120000.0 ug/l	81850.60 lbs/day
Dimethyl phthlate	3.13E+05 ug/l	2.13E+05 lbs/day	2.9E+06 ug/l	1.98E+06 lbs/day
Benzo(a)anthracene (P/	0.0028 ug/l	0.00 lbs/day	0.0 ug/l	0.02 lbs/day
Benzo(a)pyrene (PAH)	0.0028 ug/l	0.00 lbs/day	0.0 ug/l	0.02 lbs/day
Benzo(b)fluoranthene (F	0.0028 ug/l	0.00 lbs/day	0.0 ug/l	0.02 lbs/day
Benzo(k)fluoranthene (F	0.0028 ug/l	0.00 lbs/day	0.0 ug/l	0.02 lbs/day
Chrysene (PAH)	0.0028 ug/l	0.00 lbs/day	0.0 ug/l	0.02 lbs/day
Acenaphthylene (PAH)				
Anthracene (PAH)	9600.00 ug/l	6548.05 lbs/day	0.0 ug/l	0.00 lbs/day
Dibenzo(a,h)anthracene	0.0028 ug/l	0.00 lbs/day	0.0 ug/l	0.02 lbs/day
Indeno(1,2,3-cd)pyrene	0.0028 ug/l	0.00 lbs/day	0.0 ug/l	0.02 lbs/day
Pyrene (PAH)	960.00 ug/l	654.80 lbs/day	11000.0 ug/l	7502.97 lbs/day
Tetrachloroethylene	0.80 ug/l	0.55 lbs/day	8.9 ug/l	6.07 lbs/day
Toluene	6800.00 ug/l	4638.20 lbs/day	200000 ug/l	136417.67 lbs/day
Trichloroethylene	2.70 ug/l	1.84 lbs/day	81.0 ug/l	55.25 lbs/day
Vinyl chloride	2.00 ug/l	1.36 lbs/day	525.0 ug/l	358.10 lbs/day
			0.0	0.00 lbs/day
Pesticides			0.0	0.00 lbs/day
Aldrin	0.0001 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
Dieldrin	0.0001 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
Chlordane	0.0006 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
4,4'-DDT	0.0006 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
4,4'-DDE	0.0006 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
4,4'-DDD	0.0008 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
alpha-Endosulfan	0.9300 ug/l	0.63 lbs/day	2.0 ug/l	1.36 lbs/day
beta-Endosulfan	0.9300 ug/l	0.63 lbs/day	2.0 ug/l	1.36 lbs/day
Endosulfan sulfate	0.9300 ug/l	0.63 lbs/day	2.0 ug/l	1.36 lbs/day
Endrin	0.7600 ug/l	0.52 lbs/day	0.8 ug/l	0.55 lbs/day
Endrin aldehyde	0.7600 ug/l	0.52 lbs/day	0.8 ug/l	0.55 lbs/day
Heptachlor	0.0002 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
Heptachlor epoxide				
PCB's				
PCB-1242 (Arochlor 124	0.000044 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
PCB-1254 (Arochlor 124	0.000044 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
PCB-1221 (Arochlor 122	0.000044 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
PCB-1232 (Arochlor 123	0.000044 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
PCB-1248 (Arochlor 124	0.000044 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
PCB-1260 (Arochlor 126	0.000044 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
PCB-1016 (Arochlor 10	0.000044 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
Pesticide				
Toxaphene	0.000750 ug/l	0.00	0.0 ug/l	0.00 lbs/day
Dioxin				
Dioxin (2,3,7,8-TCDD)	1.30E-08 ug/l	0.00 lbs/day	1.40E-08	0.00

**Utah Division of Water Quality
Salt Lake City, Utah**

Metals

Antimony	14.0 ug/l	9.55 lbs/day		
Arsenic	50.0 ug/l	34.10 lbs/day	4300.00 ug/l	2932.98 lbs/day
Asbestos	7.00E+06 ug/l	4.77E+06 lbs/day		
Beryllium				
Cadmium				
Chromium (III)				
Chromium (VI)				
Copper				
Cyanide	1.30E+03 ug/l	886.71 lbs/day	2.2E+05 ug/l	150059.43 lbs/day
Lead	700.0 ug/l	477.46 lbs/day		
Mercury			0.15 ug/l	0.10 lbs/day
Nickel			4600.00 ug/l	3137.61 lbs/day
Selenium	0.1 ug/l	0.10 lbs/day		
Silver	610.0 ug/l	416.07 lbs/day		
Thallium			6.30 ug/l	4.30 lbs/day
Zinc				

There are additional standards that apply to this receiving water, but were not considered in this modeling/waste load allocation analysis.

VII. Mathematical Modeling of Stream Quality

Model configuration was accomplished utilizing standard modeling procedures. Data points were plotted and coefficients adjusted as required to match observed data as closely as possible.

The modeling approach used in this analysis included one or a combination of the following models.

(1) The Utah River Model, Utah Division of Water Quality, 1992. Based upon STREAMDO IV (Region VIII) and Supplemental Ammonia Toxicity Models; EPA Region VIII, Sept. 1990 and QUAL2E (EPA, Athens, GA).

(2) Utah Ammonia/Chlorine Model, Utah Division of Water Quality, 1992.

(3) AMMTOX Model, University of Colorado, Center of Limnology, and EPA Region 8

(4) Principles of Surface Water Quality Modeling and Control. Robert V. Thomann, et.al. Harper Collins Publisher, Inc. 1987, pp. 644.

Coefficients used in the model were based, in part, upon the following references:

(1) Rates, Constants, and Kinetics Formulations in Surface Water Quality Modeling. Environmental Research Laboratory, Office of Research and Development, U.S. Environmental Protection Agency, Athens Georgia. EPA/600/3-85/040 June 1985.

**Utah Division of Water Quality
Salt Lake City, Utah**

(2) Principles of Surface Water Quality Modeling and Control. Robert V. Thomann, et.al.
Harper Collins Publisher, Inc. 1987, pp. 644.

VIII. Modeling Information

The required information for the model may include the following information for both the upstream conditions at low flow and the effluent conditions:

Flow, Q, (cfs or MGD)	D.O. mg/l
Temperature, Deg. C.	Total Residual Chlorine (TRC), mg/l
pH	Total NH3-N, mg/l
BOD5, mg/l	Total Dissolved Solids (TDS), mg/l
Metals, ug/l	Toxic Organics of Concern, ug/l

Other Conditions

In addition to the upstream and effluent conditions, the models require a variety of physical and biological coefficients and other technical information. In the process of actually establishing the permit limits for an effluent, values are used based upon the available data, model calibration, literature values, site visits and best professional judgement.

Model Inputs

The following is upstream and discharge information that was utilized as inputs for the analysis. Dry washes are considered to have an upstream flow equal to the flow of the discharge.

Current Upstream Information

		Stream							
		Critical Low							
		Flow	Temp.	pH	T-NH3	BOD5	DO	TRC	TDS
		cfs	Deg. C		mg/l as N	mg/l	mg/l	mg/l	mg/l
Summer (Irrig. Season)		125.0	12.1	8.0	0.01	1.00	7.81	0.00	126.4
	Fall	125.0	8.1	8.1	0.01	1.00	---	0.00	139.3
	Winter	125.0	3.2	8.1	0.01	1.00	---	0.00	154.2
	Spring	125.0	7.4	8.0	0.01	1.00	---	0.00	128.1
Dissolved	Al	As	Cd	CrIII	CrVI	Copper	Fe	Pb	
Metals	ug/l	ug/l	ug/l	ug/l	ug/l	ug/l	ug/l	ug/l	ug/l
All Seasons	1.59*	0.53*	0.053*	0.53*	2.65*	0.53*	0.83*	0.53*	
Dissolved	Hg	Ni	Se	Ag	Zn	Boron			
Metals	ug/l	ug/l	ug/l	ug/l	ug/l	ug/l			
All Seasons	0.0000	0.53*	1.06*	0.1*	0.053*	10.0			* 1/2 MDL

**Utah Division of Water Quality
Salt Lake City, Utah**

Projected Discharge Information

Season	Flow, MGD	Temp.	TDS mg/l	TDS tons/day
Summer	1.00000	NA	250.00	1.04229
Fall	1.00000	NA		
Winter	1.00000	NA		
Spring	1.00000	NA		

All model numerical inputs, intermediate calculations, outputs and graphs are available for discussion, inspection and copy at the Division of Water Quality.

IX. Effluent Limitations

Current State water quality standards are required to be met under a variety of conditions including in-stream flows targeted to the 7-day, 10-year low flow (R317-2-9).

Other conditions used in the modeling effort coincide with the environmental conditions expected at low stream flows.

Effluent Limitation for Flow based upon Water Quality Standards

In-stream criteria of downstream segments will be met with an effluent flow maximum value as follows:

Season	Daily Average	
Summer	1.000 MGD	1.547 cfs
Fall	1.000 MGD	1.547 cfs
Winter	1.000 MGD	1.547 cfs
Spring	1.000 MGD	1.547 cfs

Flow Requirement or Loading Requirement

The calculations in this wasteload analysis utilize the maximum effluent discharge flow of 1 MGD. If the discharger is allowed to have a flow greater than 1 MGD during 7Q10 conditions, and effluent limit concentrations as indicated, then water quality standards will be violated. In order to prevent this from occurring, the permit writers must include the discharge flow limitation as indicated above; or, include loading effluent limits in the permit.

Effluent Limitation for Whole Effluent Toxicity (WET) based upon WET Policy

Effluent Toxicity will not occur in downstream segments if the values below are met.

WET Requirements	LC50 >	8.3% Effluent	[Acute]
	IC25 >	1.2% Effluent	[Chronic]

**Utah Division of Water Quality
Salt Lake City, Utah**

Effluent Limitation for Biological Oxygen Demand (BOD) based upon Water Quality Standards or Regulations

In-stream criteria of downstream segments for Dissolved Oxygen will be met with an effluent BOD limitation as follows:

Season	Concentration	
Summer	25.0 mg/l as BOD5	208.5 lbs/day
Fall	25.0 mg/l as BOD5	208.5 lbs/day
Winter	25.0 mg/l as BOD5	208.5 lbs/day
Spring	25.0 mg/l as BOD5	208.5 lbs/day

Effluent Limitation for Dissolved Oxygen (DO) based upon Water Quality Standards

In-stream criteria of downstream segments for Dissolved Oxygen will be met with an effluent D.O. limitation as follows:

Season	Concentration
Summer	5.00
Fall	5.00
Winter	5.00
Spring	5.00

Effluent Limitation for Total Ammonia based upon Water Quality Standards

In-stream criteria of downstream segments for Total Ammonia will be met with an effluent limitation (expressed as Total Ammonia as N) as follows:

Season		Concentration	Load
Summer	4 Day Avg. - Chronic	312.1 mg/l as N	2,602.8 lbs/day
	1 Hour Avg. - Acute	1098.7 mg/l as N	9,161.5 lbs/day
Fall	4 Day Avg. - Chronic	312.1 mg/l as N	2,602.8 lbs/day
	1 Hour Avg. - Acute	1096.3 mg/l as N	9,141.0 lbs/day
Winter	4 Day Avg. - Chronic	311.6 mg/l as N	2,598.5 lbs/day
	1 Hour Avg. - Acute	1094.1 mg/l as N	9,123.0 lbs/day
Spring	4 Day Avg. - Chronic	312.1 mg/l as N	2,602.8 lbs/day
	1 Hour Avg. - Acute	1096.3 mg/l as N	9,141.0 lbs/day

Acute limit calculated with an Acute Zone of Initial Dilution (ZID) to be equal to 50.0%.

**Utah Division of Water Quality
Salt Lake City, Utah**

Effluent Limitation for Total Residual Chlorine based upon Water Quality Standards

In-stream criteria of downstream segments for Total Residual Chlorine will be met with an effluent limitation as follows:

Season		Concentration		Load	
Summer	4 Day Avg. - Chronic	0.892	mg/l	7.44	lbs/day
	1 Hour Avg. - Acute	0.783	mg/l	6.53	lbs/day
Fall	4 Day Avg. - Chronic	0.892	mg/l	7.44	lbs/day
	1 Hour Avg. - Acute	0.783	mg/l	6.53	lbs/day
Winter	4 Day Avg. - Chronic	0.892	mg/l	7.44	lbs/day
	1 Hour Avg. - Acute	0.783	mg/l	6.53	lbs/day
Spring	4 Day Avg. - Chronic	0.892	mg/l	0.00	lbs/day
	1 Hour Avg. - Acute	0.783	mg/l	0.00	lbs/day

Effluent Limitations for Total Dissolved Solids based upon Water Quality Standards

Season		Concentration		Load	
Summer	Maximum, Acute	87948.5	mg/l	366.67	tons/day
Fall	Maximum, Acute	86906.2	mg/l	362.33	tons/day
Winter	Maximum, Acute	85702.3	mg/l	357.31	tons/day
Spring	4 Day Avg. - Chronic	87811.2	mg/l	366.10	tons/day

Colorado Salinity Forum Limits Determined by Permitting Section

Effluent Limitations for Total Recoverable Metals based upon Water Quality Standards

In-stream criteria of downstream segments for Dissolved Metals will be met with an effluent limitation as follows (based upon a hardness of 98.09 mg/l):

	4 Day Average		1 Hour Average		Load
	Concentration	Load	Concentration	Load	
Aluminum	N/A	N/A	30,954.2	ug/l	258.1 lbs/day
Arsenic	15,478.06 ug/l	83.4 lbs/day	14,044.1	ug/l	117.1 lbs/day
Cadmium	15.40 ug/l	0.1 lbs/day	83.4	ug/l	0.7 lbs/day
Chromium III	6,874.68 ug/l	37.1 lbs/day	73,443.0	ug/l	612.4 lbs/day
Chromium VI	578.63 ug/l	3.1 lbs/day	501.8	ug/l	4.2 lbs/day
Copper	686.38 ug/l	3.7 lbs/day	537.0	ug/l	4.5 lbs/day
Iron	N/A	N/A	41,350.3	ug/l	344.8 lbs/day
Lead	189.70 ug/l	1.0 lbs/day	3,265.9	ug/l	27.2 lbs/day
Mercury	0.98 ug/l	0.0 lbs/day	99.4	ug/l	0.8 lbs/day
Nickel	4,133.58 ug/l	22.3 lbs/day	19,077.0	ug/l	159.1 lbs/day
Selenium	247.81 ug/l	1.3 lbs/day	763.8	ug/l	6.4 lbs/day
Silver	N/A ug/l	N/A lbs/day	151.6	ug/l	1.3 lbs/day

**Utah Division of Water Quality
Salt Lake City, Utah**

Zinc	9,635.54 ug/l	51.9 lbs/day	4,876.7	ug/l	40.7 lbs/day
Cyanide	425.37 ug/l	2.3 lbs/day	910.8	ug/l	7.6 lbs/day

**Effluent Limitations for Heat/Temperature based upon
Water Quality Standards**

Summer	100.0 Deg. C.	212.0 Deg. F
Fall	100.0 Deg. C.	212.0 Deg. F
Winter	100.0 Deg. C.	212.0 Deg. F
Spring	100.0 Deg. C.	212.0 Deg. F

**Effluent Limitations for Organics [Pesticides]
Based upon Water Quality Standards**

In-stream criteria of downstream segments for Organics [Pesticides] will be met with an effluent limit as follows:

	4 Day Average		1 Hour Average		Load
	Concentration	Load	Concentration	Load	
Aldrin			1.5E+00	ug/l	1.93E-02 lbs/day
Chlordane	4.30E-03 ug/l	3.59E-02 lbs/day	1.2E+00	ug/l	1.55E-02 lbs/day
DDT, DDE	1.00E-03 ug/l	8.34E-03 lbs/day	5.5E-01	ug/l	7.09E-03 lbs/day
Dieldrin	1.90E-03 ug/l	1.58E-02 lbs/day	1.3E+00	ug/l	1.61E-02 lbs/day
Endosulfan	5.60E-02 ug/l	4.67E-01 lbs/day	1.1E-01	ug/l	1.42E-03 lbs/day
Endrin	2.30E-03 ug/l	1.92E-02 lbs/day	9.0E-02	ug/l	1.16E-03 lbs/day
Guthion	0.00E+00 ug/l	0.00E+00 lbs/day	1.0E-02	ug/l	1.29E-04 lbs/day
Heptachlor	3.80E-03 ug/l	3.17E-02 lbs/day	2.6E-01	ug/l	3.35E-03 lbs/day
Lindane	8.00E-02 ug/l	6.67E-01 lbs/day	1.0E+00	ug/l	1.29E-02 lbs/day
Methoxychlor	0.00E+00 ug/l	0.00E+00 lbs/day	3.0E-02	ug/l	3.87E-04 lbs/day
Mirex	0.00E+00 ug/l	0.00E+00 lbs/day	1.0E-02	ug/l	1.29E-04 lbs/day
Parathion	0.00E+00 ug/l	0.00E+00 lbs/day	4.0E-02	ug/l	5.16E-04 lbs/day
PCB's	1.40E-02 ug/l	1.17E-01 lbs/day	2.0E+00	ug/l	2.58E-02 lbs/day
Pentachlorophenol	1.30E+01 ug/l	1.08E+02 lbs/day	2.0E+01	ug/l	2.58E-01 lbs/day
Toxephene	2.00E-04 ug/l	1.67E-03 lbs/day	7.3E-01	ug/l	9.42E-03 lbs/day

**Utah Division of Water Quality
Salt Lake City, Utah**

**Effluent Targets for Pollution Indicators
Based upon Water Quality Standards**

In-stream criteria of downstream segments for Pollution Indicators will be met with an effluent limit as follows:

	1 Hour Average	
	Concentration	Loading
Gross Beta (pCi/l)	50.0 pCi/L	
BOD (mg/l)	5.0 mg/l	41.7 lbs/day
Nitrates as N	4.0 mg/l	33.4 lbs/day
Total Phosphorus as P	0.05 mg/l	0.4 lbs/day
Total Suspended Solids	90.0 mg/l	750.4 lbs/day

Note: Pollution indicator targets are for information purposes only.

**Effluent Limitations for Protection of Human Health [Toxics Rule]
Based upon Water Quality Standards (Most stringent of 1C or 3A & 3B as appropriate.)**

In-stream criteria of downstream segments for Protection of Human Health [Toxics] will be met with an effluent limit as follows:

	Maximum Concentration	
	Concentration	Load
Toxic Organics		
Acenaphthene	9.82E+04 ug/l	8.19E+02 lbs/day
Acrolein	2.62E+04 ug/l	2.18E+02 lbs/day
Acrylonitrile	4.83E+00 ug/l	4.02E-02 lbs/day
Benzene	9.82E+01 ug/l	8.19E-01 lbs/day
Benzidine	ug/l	lbs/day
Carbon tetrachloride	2.05E+01 ug/l	1.71E-01 lbs/day
Chlorobenzene	5.56E+04 ug/l	4.64E+02 lbs/day
1,2,4-Trichlorobenzene		
Hexachlorobenzene	6.14E-02 ug/l	5.12E-04 lbs/day
1,2-Dichloroethane	3.11E+01 ug/l	2.59E-01 lbs/day
1,1,1-Trichloroethane		
Hexachloroethane	1.55E+02 ug/l	1.30E+00 lbs/day
1,1-Dichloroethane		
1,1,2-Trichloroethane	4.99E+01 ug/l	4.16E-01 lbs/day
1,1,2,2-Tetrachloroethane	1.39E+01 ug/l	1.16E-01 lbs/day
Chloroethane		
Bis(2-chloroethyl) ether	2.54E+00 ug/l	2.11E-02 lbs/day
2-Chloroethyl vinyl ether		
2-Chloronaphthalene	1.39E+05 ug/l	1.16E+03 lbs/day
2,4,6-Trichlorophenol	1.72E+02 ug/l	1.43E+00 lbs/day
p-Chloro-m-cresol		
Chloroform (HM)	4.66E+02 ug/l	3.89E+00 lbs/day
2-Chlorophenol	9.82E+03 ug/l	8.19E+01 lbs/day
1,2-Dichlorobenzene	2.21E+05 ug/l	1.84E+03 lbs/day
1,3-Dichlorobenzene	3.27E+04 ug/l	2.73E+02 lbs/day

**Utah Division of Water Quality
Salt Lake City, Utah**

1,4-Dichlorobenzene	3.27E+04 ug/l	2.73E+02 lbs/day
3,3'-Dichlorobenzidine	3.27E+00 ug/l	2.73E-02 lbs/day
1,1-Dichloroethylene	4.66E+00 ug/l	3.89E-02 lbs/day
1,2-trans-Dichloroethylene1		
2,4-Dichlorophenol	7.61E+03 ug/l	6.34E+01 lbs/day
1,2-Dichloropropane	4.25E+01 ug/l	3.55E-01 lbs/day
1,3-Dichloropropylene	8.18E+02 ug/l	6.82E+00 lbs/day
2,4-Dimethylphenol	4.42E+04 ug/l	3.68E+02 lbs/day
2,4-Dinitrotoluene	9.00E+00 ug/l	7.50E-02 lbs/day
2,6-Dinitrotoluene		
1,2-Diphenylhydrazine	3.27E+00 ug/l	2.73E-02 lbs/day
Ethylbenzene	2.54E+05 ug/l	2.11E+03 lbs/day
Fluoranthene	2.45E+04 ug/l	2.05E+02 lbs/day
4-Chlorophenyl phenyl ether		
4-Bromophenyl phenyl ether		
Bis(2-chloroisopropyl) ether	1.15E+05 ug/l	9.55E+02 lbs/day
Bis(2-chloroethoxy) methane		
Methylene chloride (HM)	3.84E+02 ug/l	3.21E+00 lbs/day
Methyl chloride (HM)		
Methyl bromide (HM)		
Bromoform (HM)	3.52E+02 ug/l	2.93E+00 lbs/day
Dichlorobromomethane(HM)	2.21E+01 ug/l	1.84E-01 lbs/day
Chlorodibromomethane (HM)	3.35E+01 ug/l	2.80E-01 lbs/day
Hexachlorocyclopentadiene	1.96E+04 ug/l	1.64E+02 lbs/day
Isophorone	6.87E+02 ug/l	5.73E+00 lbs/day
Naphthalene		
Nitrobenzene	1.39E+03 ug/l	1.16E+01 lbs/day
2-Nitrophenol		
4-Nitrophenol		
2,4-Dinitrophenol	5.73E+03 ug/l	4.77E+01 lbs/day
4,6-Dinitro-o-cresol	1.06E+03 ug/l	8.87E+00 lbs/day
N-Nitrosodimethylamine	5.64E-02 ug/l	4.71E-04 lbs/day
N-Nitrosodiphenylamine	4.09E+02 ug/l	3.41E+00 lbs/day
N-Nitrosodi-n-propylamine	4.09E-01 ug/l	3.41E-03 lbs/day
Pentachlorophenol	2.29E+01 ug/l	1.91E-01 lbs/day
Phenol	1.72E+06 ug/l	1.43E+04 lbs/day
Bis(2-ethylhexyl)phthalate	1.47E+02 ug/l	1.23E+00 lbs/day
Butyl benzyl phthalate	2.45E+05 ug/l	2.05E+03 lbs/day
Di-n-butyl phthalate	2.21E+05 ug/l	1.84E+03 lbs/day
Di-n-octyl phthlate		
Diethyl phthalate	1.88E+06 ug/l	1.57E+04 lbs/day
Dimethyl phthlate	2.56E+07 ug/l	2.13E+05 lbs/day
Benzo(a)anthracene (PAH)	2.29E-01 ug/l	1.91E-03 lbs/day
Benzo(a)pyrene (PAH)	2.29E-01 ug/l	1.91E-03 lbs/day
Benzo(b)fluoranthene (PAH)	2.29E-01 ug/l	1.91E-03 lbs/day
Benzo(k)fluoranthene (PAH)	2.29E-01 ug/l	1.91E-03 lbs/day
Chrysene (PAH)	2.29E-01 ug/l	1.91E-03 lbs/day
Acenaphthylene (PAH)		
Anthracene (PAH)		
Dibenzo(a,h)anthracene (PAH)	2.29E-01 ug/l	1.91E-03 lbs/day
Indeno(1,2,3-cd)pyrene (PAH)	2.29E-01 ug/l	1.91E-03 lbs/day

**Utah Division of Water Quality
Salt Lake City, Utah**

Pyrene (PAH)	7.85E+04 ug/l	6.55E+02 lbs/day
Tetrachloroethylene	6.54E+01 ug/l	5.46E-01 lbs/day
Toluene	5.56E+05 ug/l	4.64E+03 lbs/day
Trichloroethylene	2.21E+02 ug/l	1.84E+00 lbs/day
Vinyl chloride	1.64E+02 ug/l	1.36E+00 lbs/day

Pesticides

Aldrin	1.06E-02 ug/l	8.87E-05 lbs/day
Dieldrin	1.15E-02 ug/l	9.55E-05 lbs/day
Chlordane	4.66E-02 ug/l	3.89E-04 lbs/day
4,4'-DDT	4.83E-02 ug/l	4.02E-04 lbs/day
4,4'-DDE	4.83E-02 ug/l	4.02E-04 lbs/day
4,4'-DDD	6.79E-02 ug/l	5.66E-04 lbs/day
alpha-Endosulfan	7.61E+01 ug/l	6.34E-01 lbs/day
beta-Endosulfan	7.61E+01 ug/l	6.34E-01 lbs/day
Endosulfan sulfate	7.61E+01 ug/l	6.34E-01 lbs/day
Endrin	6.22E+01 ug/l	5.18E-01 lbs/day
Endrin aldehyde	6.22E+01 ug/l	5.18E-01 lbs/day
Heptachlor	1.72E-02 ug/l	1.43E-04 lbs/day
Heptachlor epoxide		

PCB's

PCB 1242 (Arochlor 1242)	3.60E-03 ug/l	3.00E-05 lbs/day
PCB-1254 (Arochlor 1254)	3.60E-03 ug/l	3.00E-05 lbs/day
PCB-1221 (Arochlor 1221)	3.60E-03 ug/l	3.00E-05 lbs/day
PCB-1232 (Arochlor 1232)	3.60E-03 ug/l	3.00E-05 lbs/day
PCB-1248 (Arochlor 1248)	3.60E-03 ug/l	3.00E-05 lbs/day
PCB-1260 (Arochlor 1260)	3.60E-03 ug/l	3.00E-05 lbs/day
PCB-1016 (Arochlor 1016)	3.60E-03 ug/l	3.00E-05 lbs/day

Pesticide

Toxaphene	5.97E-02 ug/l	4.98E-04 lbs/day
-----------	---------------	------------------

Metals

Antimony	1145.22 ug/l	9.55 lbs/day
Arsenic	4025.84 ug/l	33.57 lbs/day
Asbestos	5.73E+08 ug/l	4.77E+06 lbs/day
Beryllium		
Cadmium		
Chromium (III)		
Chromium (VI)		
Copper	106342.02 ug/l	886.71 lbs/day
Cyanide	57261.09 ug/l	477.46 lbs/day
Lead	0.00	0.00
Mercury	11.45 ug/l	0.10 lbs/day
Nickel	49898.95 ug/l	416.07 lbs/day
Selenium	0.00	0.00
Silver	0.00	0.00
Thallium	139.06 ug/l	1.16 lbs/day
Zinc		

**Utah Division of Water Quality
Salt Lake City, Utah**

Cyanide	910.8	425.4	
Iron	41350.3		
Lead	3265.9	189.7	
Mercury	11.452	0.981	
Nickel	19077.0	4134	
Selenium	763.8	247.8	
Silver	151.6	N/A	
Thallium	139.1		
Zinc	4876.7	9635.5	Acute Controls
Boron	61351.16		

Other Effluent Limitations are based upon R317-1.

E. coli 126.0 organisms per 100 ml

X. Antidegradation Considerations

The Utah Antidegradation Policy allows for degradation of existing quality where it is determined that such lowering of water quality is necessary to accommodate important economic or social development in the area in which the waters are protected [R317-2-3]. It has been determined that certain chemical parameters introduced by this discharge will cause an increase of the concentration of said parameters in the receiving waters. Under no conditions will the increase in concentration be allowed to interfere with existing instream water uses.

The antidegradation rules and procedures allow for modification of effluent limits less than those based strictly upon mass balance equations utilizing 100% of the assimilative capacity of the receiving water. Additional factors include considerations for "Blue-ribbon" fisheries, special recreational areas, threatened and endangered species, and drinking water sources.

An Antidegradation Level I Review was conducted on this discharge and its effect on the receiving water. Based upon that review, it has been determined that an Antidegradation Level II Review is required, because the receiving water is a Class 1C drinking water source.

XI. Colorado River Salinity Forum Considerations

Discharges in the Colorado River Basin are required to have their discharge at a TDS loading of less than 1.00 tons/day unless certain exemptions apply. Refer to the Forum's Guidelines for additional information allowing for an exceedence of this value.

XII. Summary Comments

The mathematical modeling and best professional judgement indicate that violations of receiving water beneficial uses with their associated water quality standards, including important downstream segments, will not occur for the evaluated parameters of concern as discussed above if the effluent limitations indicated above are met.

Utah Division of Water Quality
Salt Lake City, Utah

XIII. Notice of UPDES Requirement

This Addendum to the Statement of Basis does not authorize any entity or party to discharge to the waters of the State of Utah. That authority is granted through a UPDES permit issued by the Utah Division of Water Quality. The numbers presented here may be changed as a function of other factors. Dischargers are strongly urged to contact the Permits Section for further information. Permit writers may utilize other information to adjust these limits and/or to determine other limits based upon best available technology and other considerations provided that the values in this wasteload analysis [TMDL] are not compromised. See special provisions in Utah Water Quality Standards for adjustments in the Total Dissolved Solids values based upon background concentration.

THIS IS A DRAFT DOCUMENT

Utah Division of Water Quality
801-538-6052
File Name: JSSD_WWTP_WLA_8-7-13

**Utah Division of Water Quality
Salt Lake City, Utah**

APPENDIX - Coefficients and Other Model Information

CBOD Coeff. (Kd)20 1/day 0.830	CBOD Coeff. FORCED (Kd)/day 0.000	CBOD Coeff. (Ka)T 1/day 0.577	REAER. Coeff. (Ka)20 (Ka)/day 3.571	REAER. Coeff. FORCED 1/day 0.000	REAER. Coeff. (Ka)T 1/day 2.961	NBOD Coeff. (Kn)20 1/day 0.250	NBOD Coeff. (Kn)T 1/day 0.136
Open Coeff. (K4)20 1/day 0.000	Open Coeff. (K4)T 1/day 0.000	NH3 LOSS (K5)20 1/day 4.000	NH3 LOSS (K5)T 1/day 2.783	NO2+NO3 LOSS (K6)20 1/day 0.000	NO2+NO3 LOSS (K6)T 1/day 0.000	TRC Decay K(Cl)20 1/day 32.000	TRC K(Cl)(T) 1/day 20.195
BENTHIC DEMAND (SOD)20 gm/m2/day 1.000	BENTHIC DEMAND (SOD)T gm/m2/day 0.608						
K1 CBOD {theta} 1.0	K2 Reaer. {theta} 1.0	K3 NH3 {theta} 1.1	K4 Open {theta} 1.0	K5 NH3 Loss {theta} 1.0	K6 NO2+3 {theta} 1.0	K(Cl) TRC {theta} 1.1	S Benthic {theta} 1.1

Antidegradation Review Form

Part A: Applicant Information

Facility Name: Jordanelle Special Service District Water Reclamation Facility

Facility Owner: Jordanelle Special Service District

Facility Location: 5780 North Old Hwy 40 Heber City Utah

Form Prepared By: Shane D. Paddock

Outfall Number: 001

Receiving Water: Provo River

What Are the Designated Uses of the Receiving Water (R317-2-6)?

Domestic Water Supply: 1C
Recreation: 2A - Primary Contact
Aquatic Life: 3A - Cold Water Aquatic Life
Agricultural Water Supply: 4
Great Salt Lake: None

Category of Receiving Water (R317-2-3.2, -3.3, and -3.4): Category 3

UPDES Permit Number (if applicable): UT0025747

Effluent Flow Reviewed: 2mgd

Typically, this should be the maximum daily discharge at the design capacity of the facility. Exceptions should be noted.

What is the application for? (check all that apply)

- A UPDES permit for a new facility, project, or outfall.
- A UPDES permit renewal with an expansion or modification of an existing wastewater treatment works.
- A UPDES permit renewal requiring limits for a pollutant not covered by the previous permit and/or an increase to existing permit limits.
- A UPDES permit renewal with no changes in facility operations.

Part B. Is a Level II ADR required?

This section of the form is intended to help applicants determine if a Level II ADR is required for specific permitted activities. In addition, the Executive Secretary may require a Level II ADR for an activity with the potential for major impact on the quality of waters of the state (R317-2-3.5a.1).

B1. The receiving water or downstream water is a Class 1C drinking water source.

Yes A Level II ADR is required (Proceed to Part C of the Form)

No (Proceed to Part B2 of the Form)

B2. The UPDES permit is new or is being renewed and the proposed effluent concentration and loading limits are higher than the concentration and loading limits in the previous permit and any previous antidegradation review(s).

Yes (Proceed to Part B3 of the Form)

No No Level II ADR is required and there is no need to proceed further with review questions.

B3. Will any pollutants use assimilative capacity of the receiving water, i.e. do the pollutant concentrations in the effluent exceed those in the receiving waters at critical conditions? For most pollutants, effluent concentrations that are higher than the ambient concentrations require an antidegradation review? For a few pollutants such as dissolved oxygen, an antidegradation review is required if the effluent concentrations are less than the ambient concentrations in the receiving water. (Section 3.3.3 of Implementation Guidance)

Yes (Proceed to Part B4 of the Form)

No No Level II ADR is required and there is no need to proceed further with review questions.

B4. Are water quality impacts of the proposed project temporary and limited (Section 3.3.4 of Implementation Guidance)? Proposed projects that will have temporary and limited effects on water quality can be exempted from a Level II ADR.

- Yes** Identify the reasons used to justify this determination in Part B4.1 and proceed to Part G. No Level II ADR is required.
- No** A Level II ADR is required (Proceed to Part C)

B4.1 Complete this question only if the applicant is requesting a Level II review exclusion for temporary and limited projects (see R317-2-3.5(b)(3) and R317-2-3.5(b)(4)). For projects requesting a temporary and limited exclusion please indicate the factor(s) used to justify this determination (check all that apply and provide details as appropriate) (Section 3.3.4 of Implementation Guidance):

- Water quality impacts will be temporary and related exclusively to sediment or turbidity and fish spawning will not be impaired.

Factors to be considered in determining whether water quality impacts will be temporary and limited:

- a) The length of time during which water quality will be lowered:
- b) The percent change in ambient concentrations of pollutants:
- c) Pollutants affected:
- d) Likelihood for long-term water quality benefits:
- e) Potential for any residual long-term influences on existing uses:
- f) Impairment of fish spawning, survival and development of aquatic fauna excluding fish removal efforts:

Additional justification, as needed:

Level II ADR

Part C, D, E, and F of the form constitute the Level II ADR Review. The applicant must provide as much detail as necessary for DWQ to perform the antidegradation review. Questions are provided for the convenience of applicants; however, for more complex permits it may be more effective to provide the required information in a separate report. Applicants that prefer a separate report should record the report name here and proceed to Part G of the form.

Optional Report Name:

Part C. Is the degradation from the project socially and economically necessary to accommodate important social or economic development in the area in which the waters are located? *The applicant must provide as much detail as necessary for DWQ to concur that the project is socially and economically necessary when answering the questions in this section. More information is available in Section 6.2 of the Implementation Guidance.*

C1. Describe the social and economic benefits that would be realized through the proposed project, including the number and nature of jobs created and anticipated tax revenues.

The facility will provide sanitary waste water treatment to the Central and Northern parts of Wasatch County. At the time of commission, there will be approximately 8 jobs created by this facility (management operations, maintenance, clerical)

C2. Describe any environmental benefits to be realized through implementation of the proposed project.

The facility will be beneficial for the environment, and will remove any eliments that would be deemed harmful to the receiving water and the environment.

C3. Describe any social and economic losses that may result from the project, including impacts to recreation or commercial development.

N/A

C4. Summarize any supporting information from the affected communities on preserving assimilative capacity to support future growth and development.

N/A

C5. Please describe any structures or equipment associated with the project that will be placed within or adjacent to the receiving water.

2mgd water relamation facility.

Part D. Identify and rank (from increasing to decreasing potential threat to designated uses) the parameters of concern. *Parameters of concern are parameters in the effluent at concentrations greater than ambient concentrations in the receiving water. The applicant is responsible for identifying parameter concentrations in the effluent and DWQ will provide parameter concentrations for the receiving water. More information is available in Section 3.3.3 of the Implementation Guidance.*

Parameters of Concern:

Rank	Pollutant	Ambient Concentration	Effluent Concentration
1	BOD, mg/L	N/A	N/A
2	TSS, mg/L	/	/
3	E Coli, no./100ml	/	/
4	Dissolved Oxygen, mg/L		
5	PH/TSS/Total Phosphorous		

Pollutants Evaluated that are not Considered Parameters of Concern:

Pollutant	Ambient Concentration	Effluent Concentration	Justification

Part E. Alternative Analysis Requirements of a Level II

Antidegradation Review. *Level II ADRs require the applicant to determine whether there are feasible less-degrading alternatives to the proposed project. More information is available in Section 5.5 and 5.6 of the Implementation Guidance.*

E1. The UPDES permit is being renewed without any changes to flow or concentrations. Alternative treatment and discharge options including changes to operations and maintenance were considered and compared to the current processes. No economically feasible treatment or discharge alternatives were identified that were not previously considered for any previous antidegradation review(s).

Yes (Proceed to Part F)

No or Does Not Apply (Proceed to E2)

E2. Attach as an appendix to this form a report that describes the following factors for all alternative treatment options (see 1) a technical description of the treatment process, including construction costs and continued operation and maintenance expenses, 2) the mass and concentration of discharge constituents, and 3) a description of the reliability of the system, including the frequency where recurring operation and maintenance may lead to temporary increases in discharged pollutants. Most of this information is typically available from a Facility Plan, if available.

Report Name:

E3. Describe the proposed method and cost of the baseline treatment alternative. The baseline treatment alternative is the minimum treatment required to meet water quality based effluent limits (WQBEL) as determined by the preliminary or final wasteload analysis (WLA) and any secondary or categorical effluent limits.

E4. Were any of the following alternatives feasible and affordable?

Alternative	Feasible	Reason Not Feasible/Affordable
Pollutant Trading	Yes	
Water Recycling/Reuse	Yes	
Land Application	Yes	
Connection to Other Facilities	Yes	
Upgrade to Existing Facility	Yes	
Total Containment	Yes	
Improved O&M of Existing Systems	Yes	
Seasonal or Controlled Discharge	Yes	
New Construction	Yes	
No Discharge	Yes	

E5. From the applicant's perspective, what is the preferred treatment option?

E6. Is the preferred option also the least polluting feasible alternative?

Yes

No

If no, what were less degrading feasible alternative(s)?

If no, provide a summary of the justification for not selecting the least polluting feasible alternative and if appropriate, provide a more detailed justification as an attachment.

Part F. Optional Information

F1. Does the applicant want to conduct optional public review(s) in addition to the mandatory public review? Level II ADRs are public noticed for a thirty day comment period. More information is available in Section 3.7.1 of the Implementation Guidance.

No

Yes

F2. Does the project include an optional mitigation plan to compensate for the proposed water quality degradation?

No

Yes

Report Name:


Part G. Certification of Antidegradation Review

G1. Applicant Certification

The form should be signed by the same responsible person who signed the accompanying permit application or certification.

Based on my inquiry of the person(s) who manage the system or those persons directly responsible for gathering the information, the information in this form and associated documents is, to the best of my knowledge and belief, true, accurate, and complete.

Print Name: Shane D. Paddock

Signature: 

Date: 04-29-13

G2. DWQ Approval

To the best of my knowledge, the ADR was conducted in accordance with the rules and regulations outlined in UAC R-317-2-3.

Water Quality Management Section

Print Name: _____

Signature: _____

Date: _____

Official Draft Public Notice Version October 2, 2013

The findings, determinations, and assertions contained in this document are not final and subject to change following the public comment period.

STATE OF UTAH
DIVISION OF WATER QUALITY
DEPARTMENT OF ENVIRONMENTAL QUALITY
SALT LAKE CITY, UTAH

UTAH POLLUTANT DISCHARGE ELIMINATION SYSTEM (UPDES) PERMITS

Major Municipal Permit No. **UT0025747**
Biosolids Permit No. **UTL025747**
Storm Water Permit No. **UTR000000**

In compliance with provisions of the Utah *Water Quality Act, Title 19, Chapter 5, Utah Code Annotated ("UCA") 1953, as amended (the "Act")*,

JORDANELLE SPECIAL SERVICE DISTRICT WATER RECLAMATION FACILITY

is hereby authorized to discharge from its wastewater treatment facility to the outfalls located at the following:

<u>Outfall</u>	<u>Latitude</u>	<u>Longitude</u>	<u>To receiving waters</u>
001	40°34'24"	111°25'28"	Timpanogos Canal
002	40°34'04"	111°25'39"	Wasatch Canal
003	40°34'24"	111°25'40"	Provo River Return Canal
004	40°34'20"	111°25'42"	Provo River

to dispose of biosolids,

and to discharge storm water,

in accordance with specific limitations, outfalls, and other conditions set forth herein.

This permit shall become effective on December 01, 2013

This permit expires at midnight on November 30, 2018.

Signed this _____ day of November, 2013.

Walter L. Baker, P.E.
Director

Table of Contents

<u>Outline</u>	<u>Page Number</u>
I. DISCHARGE LIMITATIONS AND REPORTING REQUIREMENTS.....	4
A. Description of Discharge Point	4
B. Narrative Standard.....	4
C. Specific Limitations and Self-Monitoring Requirements.....	4
D. Reporting of Wastewater Monitoring Results	11
II. INDUSTRIAL PRETREATMENT PROGRAM.....	12
A. Self-Monitoring and Reporting Requirements.	12
B. Industrial Wastes.	12
III. BIOSOLIDS REQUIREMENTS	15
A. Biosolids Treatment and Disposal.....	15
B. Specific Limitations and Self-Monitoring Requirements.....	15
C. Management Practices of Biosolids.	15
D. Special Conditions on Biosolids Storage	16
E. Monitoring Procedures.	16
F. Penalties for Tampering	16
G. Reporting of Monitoring Results.....	16
H. Additional Monitoring by the Permittee.....	16
I. Record keeping.....	16
J. Twenty-Four Hour Notice of Noncompliance Reporting.....	17
K. Other Noncompliance Reporting.....	18
L. Inspection and Entry.....	18
IV. STORM WATER REQUIREMENTS	19
A. Coverage of This Section	19
B. Prohibition of Non-Storm Water Discharges	19
C. Storm Water Pollution Prevention Plan Requirements	19
D. Monitoring and Reporting Requirements.....	25
V. MONITORING, RECORDING & GENERAL REPORTING REQUIREMENTS	27
A. Representative Sampling.....	27
B. Monitoring Procedures.....	27
C. Penalties for Tampering	27
D. Compliance Schedules	27
E. Additional Monitoring by the Permittee.....	27
F. Records Contents.....	27
G. Retention of Records	27
H. Twenty-four Hour Notice of Noncompliance Reporting.	27
I. Other Noncompliance Reporting.....	28
J. Inspection and Entry.....	28
VI. COMPLIANCE RESPONSIBILITIES	30
A. Duty to Comply	30
B. Penalties for Violations of Permit Conditions.....	30
C. Need to Halt or Reduce Activity not a Defense	30
D. Duty to Mitigate	30
E. Proper Operation and Maintenance	30
F. Removed Substances.....	30
G. Bypass of Treatment Facilities.	30
H. Upset Conditions.	32
VII. GENERAL REQUIREMENTS.....	34
A. Planned Changes	34
B. Anticipated Noncompliance	34
C. Permit Actions.....	34
D. Duty to Reapply.....	34

**Major Municipal
Discharge Permit UT0025747**

E.	Duty to Provide Information	34
F.	Other Information.....	34
G.	Signatory Requirements	34
H.	Penalties for Falsification of Reports	35
I.	Availability of Reports	35
J.	Oil and Hazardous Substance Liability	35
K.	Property Rights.....	36
L.	Severability.....	36
M.	Transfers	36
N.	State or Federal Laws	36
O.	Water Quality - Reopener Provision	36
P.	Biosolids – Reopener Provision	37
Q.	Toxicity Limitation - Reopener Provision.....	37
R.	Storm Water-Reopener Provision.....	37
VIII.	DEFINITIONS	39
A.	Wastewater.....	39
B.	Biosolids.....	40
C.	Storm Water.....	42

P/N DRAFT

I. DISCHARGE LIMITATIONS AND REPORTING REQUIREMENTS

A. Description of Discharge Point. The authorization to discharge wastewater provided under this part is limited to those outfalls specifically designated below as discharge locations. Discharges at any location not authorized under a UPDES permit are violations of the *Act* and may be subject to penalties under the *Act*. Knowingly discharging from an unauthorized location or failing to report an unauthorized discharge may be subject to criminal penalties as provided under the *Act*.

Discharge Points		
Outfall Number	Location of Discharge Points	Receiving Waters
001	Latitude 40°34'24" Longitude 111°25'28"	Timpanogos Canal
002	Latitude 40°34'04" Longitude 111°25'39"	Wasatch Canal
003	Latitude 40°34'24" Longitude 111°25'40"	Provo River Return Canal
004	Latitude 40°34'20" Longitude 111°25'42"	Provo River

B. Narrative Standard. It shall be unlawful, and a violation of this permit, for Jordanelle Special Service District Water Reclamation Facility (JSSDWRF) to discharge or place any waste or other substance in such a way as will be or may become offensive such as unnatural deposits, floating debris, oil, scum, or other nuisances such as color, odor or taste, or cause conditions which produce undesirable aquatic life or which produce objectionable tastes in edible aquatic organisms; or result in concentrations or combinations of substances which produce undesirable physiological responses in desirable resident fish, or other desirable aquatic life, or undesirable human health effects, as determined by a bioassay or other tests performed in accordance with standard procedures.

C. Specific Limitations and Self-Monitoring Requirements.

1. Effective immediately, and lasting through the life of this permit, there shall be no acute or chronic toxicity in outfall 003 or outfall 004 as defined in *Part VIII*, and determined by test procedures described in *Part I. C.3.a & b* of this permit.
2. Effective immediately and lasting the duration of this permit, JSSDWRF is authorized to discharge from outfall 001, 002, 003, and 004. Such discharges shall be limited and monitored by JSSDWRF as specified below:

PART I
DISCHARGE PERMIT NO. UT0025747

Effluent Limitations (Outfalls 001, 002, 003, 004) a/

Parameter	Yearly Maximum	90 Day Average	Monthly Average	Maximum Weekly Average	Daily Minimum	Daily Maximum
Total Flow, MGD	NA	NA	1.0	NA	NA	NA
BOD ₅ , mg/L	NA	NA	10	10	NA	NA
BOD ₅ , Minimum % Removal	NA	NA	85	NA	NA	NA
TSS, mg/L	NA	NA	10	10	NA	NA
TSS, Minimum % Removal	NA	NA	85	NA	NA	NA
E. Coli, no./100mL	NA	NA	126	157	NA	NA
Dissolved Oxygen, mg/L	NA	NA	NA	NA	5.0	NA
TDS, mg/L	NA	NA	NA	NA	NA	1200
Total Phosphorous, mg/L (Interim) e/	NA	NA	NA	NA	NA	0.15
Total Phosphorous, mg/L (May-Oct), (Final)	NA	0.03	NA	NA	NA	0.08
Total Phosphorous, mg/L (Nov-April), (Final)	NA	0.06	NA	NA	NA	0.10
Total Phosphorous, lbs/year h/	91	NA	NA	NA	NA	NA
Oil & Grease, mg/L	NA	NA	NA	NA	NA	10.0
pH, Standard Units	NA	NA	NA	NA	6.5	9.0
WET, Acute Biomonitoring g/	NA	NA	NA	NA	NA	LC ₅₀ > 8.3% effluent
WET, Chronic Biomonitoring g/	NA	NA	NA	NA	NA	IC ₂₅ > 1.2% effluent

NA – Not Applicable

PART I
DISCHARGE PERMIT NO. UT0025747

Self-Monitoring and Reporting Requirements a/			
Parameter	Frequency	Sample Type	Units
Total Flow b/ c/	Continuous	Recorder	MGD
BOD5, Influent d/	2 x Week	Composite	mg/L
BOD5, Effluent	2 x Week	Composite	mg/L
BOD5, Minimum % Removal	2 x Week	Calculation	%
TSS, Influent d/	2 x Week	Composite	mg/L
TSS, Effluent	2 x Week	Composite	mg/L
TSS, Minimum % Removal	2 x Week	Calculation	%
E. Coli f/	2 x Week	Grab	mg/L
Dissolved Oxygen	2 x Week	Grab	mg/L
TDS	2 x Week	Grab	mg/L
Total Phosphorus h/	2 x Week	Grab	mg/L
Ammonia	2 x Week	Grab	mg/L
Oil & Grease	Monthly If Sheen is Observed	Grab	mg/L
pH	2 x Week	Grab	SU
WET, Acute Biomonitoring g/	Quarterly	Composite	Pass/Fail
WET, Chronic Biomonitoring g/	Quarterly	Composite	Pass/Fail
Metals, Influent	2 x Year	Composite	mg/L
Metals, Effluent	2 x Year	Composite	mg/L
Organic Toxics	2 nd & 4 th Year	Grab	mg/L

- a/ See Definitions, *Part VIII*, for definition of terms.
- b/ Flow measurements of influent/effluent volume shall be made in such a manner that JSSDWRF can affirmatively demonstrate that representative values are being obtained.
- c/ If the rate of discharge is controlled, the rate and duration of discharge shall be reported.
- d/ In addition to monitoring the final discharge, influent samples shall be taken and analyzed for this constituent at the same frequency as required for this constituent in the discharge.
- e/ The interim limit is provided to allow a period of time to optimize the process upon start-up of the facility. The interim limit will expire 2 years after the start-up of the facility. Prior to start-up, JSSDWRF must submit documentation of anticipated initial discharge date, to DWQ.
- f/ In order to ensure multiple treatment barriers for the removal of pathogens for human health protection, JSSDWRF will be required to continually operate the Ultra Violet (UV) disinfection system at the manufacturers recommended intensity.

PART I
DISCHARGE PERMIT NO. UT0025747

g/ Discharges to either outfall 001 or outfall 002 are not required to monitor or report for WET if there is no discharge during the reporting period, however if any discharge occurs to either outfall 003 or outfall 004 for any duration during the reporting period JSSDWRF is required to sample, monitor, and report for WET.

h/ For calculating the yearly Total Phosphorous load use the following equation: Total load for outfall 001*0.05 + total load for outfall 002*0.50 + total load for outfall 003 + total load for outfall 004.

Should JSSDWRF not comply with permit conditions, including but not limited to the yearly maximum load for phosphorous, JSSDWRF will divert the effluent discharge to the Heber Valley SSD lagoons by pipeline in accordance with the agreement between JSSDWRF and Heber Valley SSD. This option would be considered an approved and the preferred option for any bypass or upset condition of the treatment facilities as stated in Part VI.G and Part VI.H of this permit.

3. Acute/Chronic Whole Effluent Toxicity (WET) Testing.

- a. *Whole Effluent Testing – Acute Toxicity.* Starting immediately, JSSDWRF shall conduct quarterly acute static replacement toxicity tests on a composite sample of the final effluent. The sample shall be collected at outfall 003 and/or outfall 004.

The monitoring frequency for acute tests shall be quarterly unless a sample is found to be acutely toxic during a routine test. If that occurs, the monitoring frequency shall become weekly (See *Part I.C.3.c, Accelerated Testing*). Samples shall be collected on a two day progression; i.e., if the first sample is on a Monday, during the next sampling period, the sampling shall begin on a Wednesday, etc.

The replacement static acute toxicity tests shall be conducted in general accordance with the procedures set out in the latest revision of *Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms, 5th Edition, (EPA 821/R/02/012), October 2002*, as per 40 CFR 136.3(a) TABLE 1A-LIST OF APPROVED BIOLOGICAL METHODS, and the *Region VIII EPA NPDES Acute Test Conditions – Static Renewal Whole Effluent Toxicity Test (August, 1997)*. JSSDWRF shall conduct the 48-hour static replacement toxicity test using Ceriodaphnia dubia and the acute 96-hour static replacement toxicity test using Pimephales promelas (fathead minnow).

Acute toxicity occurs when 50 percent or more mortality is observed for either species at any effluent concentration. Mortality in the control must simultaneously be 10 percent or less for the results to be considered valid. If more than 10 percent control mortality occurs, the test shall be repeated until satisfactory control mortality is achieved. A variance to this requirement may be granted by the Director if a mortality of less than 10 percent was observed in higher effluent dilutions.

If the permit contains a total residual chlorine limitation greater than 0.20 mg/L, JSSDWRF may request from the Director approval to de-chlorinate the sample, or collect the sample prior to chlorination.

PART I
DISCHARGE PERMIT NO. UT0025747

Quarterly test results shall be reported along with the Discharge Monitoring Report (DMR) submitted for the end of the reporting calendar quarter e.g., biomonitoring results for the calendar quarter ending March 31 shall be reported with the DMR due April 28, with the remaining biomonitoring reports submitted with DMRs due each July 28, October 28, and January 28). All test results shall be reported along with the DMR submitted for that reporting period. The format for the report shall be consistent with the latest revision of the *Region VIII Guidance for Acute Whole Effluent Reporting (August, 1997)* and shall include all chemical and physical data as specified.

If the results for a minimum of ten consecutive tests indicate no acute toxicity, JSSDWRP may request a reduction in testing frequency and/or reduction to one species. The Director may approve, partially approve, or deny the request based on results and other available information. If approval is given, the modification will take place without a public notice.

- b. *Whole Effluent Testing – Chronic Toxicity.* Starting immediately JSSDWRP shall quarterly, conduct chronic short-term toxicity tests on a composite sample of the final effluent. The sample shall be collected at outfall 003 and/or 004.

The monitoring frequency shall be quarterly. Samples shall be collected on a two-day progression; i.e., if the first sample is on a Monday, during the next sampling period, sampling shall be on a Wednesday. If chronic toxicity is detected, the test shall be repeated in less than four weeks from the date the initial sample was taken. The need for any additional samples, and/or a Toxicity Reduction Evaluation (TRE, see *Part I.C.3.c.*, shall be determined by the Director. If the second test shows no chronic toxicity, routine monitoring shall be resumed.

The chronic toxicity tests shall be conducted in general accordance with the procedures set out in the latest revision of *Short-Term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Water to Freshwater Organisms, 4th Edition, (EPA 821/R-02-13), October 2002* as per 40 CFR 136.3(a) *TABLE 1A-LIST OF APPROVED BIOLOGICAL METHODS*, and the *Region VIII EPA NPDES Chronic Test Conditions - Static Renewal Whole Effluent Toxicity Test (August, 1997)*. Test species shall consist of *Ceriodaphnia dubia* and *Pimephales promelas* (fathead minnow).

Chronic toxicity occurs when the survival, growth, or reproduction for either test species, when exposed to a dilution of 25 percent effluent or lower, is significantly less (at 95% confidence level) than that of the control specimens. Dilutions of 1.2 percent only will be required, plus the control. If any of the acceptable control performance criteria are not met, the test shall be considered invalid.

Quarterly test results shall be reported along with the Discharge Monitoring Report (DMR) submitted for the end of the reporting calendar quarter (e.g., biomonitoring results for the calendar quarter ending March 31 shall be reported with the DMR due April 28, with the remaining biomonitoring reports submitted with DMRs due each July 28, October 28, and January 28). All test results shall be reported along with the DMR submitted for that

PART I
DISCHARGE PERMIT NO. UT0025747

reporting period. The format for the report shall be consistent with the latest revision of the *Region VIII Guidance for Chronic Whole Effluent Reporting (August, 1997)* and shall include all the physical testing as specified.

If the results for a minimum of ten consecutive tests indicate no chronic toxicity, JSSDWRF may request a reduction in testing frequency and/or reduction to one species. The Director may approve, partially approve, or deny the request based on results and other available information. If approval is given, the modification will take place without a public notice.

The current Utah whole effluent toxicity (WET) policy is in the process of being updated and revised to assure its consistency with the Environmental Protection Agency's national and regional WET policy. When said revised WET policy has been finalized and officially adopted, this permit will be reopened and modified to incorporate satisfactory follow-up chronic toxicity language (chronic pattern of toxicity, PTI and/or TIE/TRE, etc.) without a public notice, as warranted and appropriate.

- c. *Accelerated Testing.* When acute toxicity is indicated during routine biomonitoring as specified in this permit, JSSDWRF shall notify the Director in writing within five (5) days after becoming aware of the test result. JSSDWRF shall perform an accelerated schedule of biomonitoring to establish whether a pattern of toxicity exists. Accelerated testing will begin within seven (7) days after JSSDWRF becomes aware of the test result. Accelerated testing shall be conducted as specified under *Part I.C3.d, Pattern of Toxicity*. If the accelerated testing demonstrates no pattern of toxicity, routine monitoring shall be resumed.
- d. *Pattern of Toxicity.* A pattern of toxicity is defined by the results of a series of up to five (5) biomonitoring tests pursuant to the accelerated testing requirements using 100 percent effluent on the single species found to be more sensitive, once every week for up to five (5) consecutive weeks.

If two (2) consecutive tests (not including the scheduled quarterly or monthly test which triggered the search for a pattern of toxicity) do not result in acute toxicity, no further accelerated testing will be required and no pattern of toxicity will be found to exist. JSSDWRF will provide written verification to the Director within five (5) days, and resume routine monitoring.

A pattern of toxicity is established if one of the following occurs:

- (1) If two (2) consecutive test results (not including the scheduled quarterly or monthly test, which triggered the search for a pattern of toxicity) indicate acute toxicity, this constitutes an established pattern of toxicity.
- (2) If consecutive tests continue to yield differing results each time, JSSDWRF will be required to conduct up to a maximum of five (5) acute tests (not including the scheduled quarterly or monthly test which triggered the search for a pattern of toxicity). If three out of five test results indicate acute toxicity, this will constitute an established pattern of toxicity.

e. *Preliminary Toxicity Investigation.*

- (1) When a pattern of toxicity is detected JSSDWRF will notify the Director in writing within five (5) days and begin an evaluation of the possible causes of the toxicity. JSSDWRF will have fifteen (15) working days from demonstration of the pattern to complete a Preliminary Toxicity Investigation (PTI) and submit a written report of the results to the Director. The PTI may include, but is not limited to, additional chemical and biological monitoring, examination of pretreatment program records, examination of discharge monitoring reports, a thorough review of the testing protocol, evaluation of treatment processes and chemical use, inspection of material storage and transfer areas to determine if a spill may have occurred, and similar procedures.
- (2) If the PTI identifies a probable toxicant and/or a probable source of toxicity JSSDWRF shall submit, as part of its final results written notification of that effect to the Director. Within thirty (30) days of completing the PTI JSSDWRF shall submit for approval a control program to control effluent toxicity and shall proceed to implement such a plan within seven (7) days following approval. The control program, as submitted to or revised by the Director, may be incorporated into the permit.
- (3) If no probable explanation for toxicity is identified in the PTI, JSSDWRF shall notify the Director as part of its final report, along with a schedule for conducting a Phase I Toxicity Reduction Evaluation (TRE) (See *Part I.C.3.f, Toxicity Reduction Evaluation*).
- (4) If toxicity spontaneously disappears during the PTI, JSSDWRF shall submit written notification to that effect to the Director as part of the reporting requirements of paragraph a of this section.

f. *Toxicity Reduction Evaluation (TRE).* If toxicity is detected during the life of this permit and it is determined by the Director that a TRE is necessary, JSSDWRF shall be so notified and shall initiate a TRE immediately thereafter. The purpose of the TRE will be to establish the cause of toxicity, locate the source(s) of the toxicity, and control or provide treatment for the toxicity.

A TRE may include but is not limited to one, all, or a combination of the following:

- (1) Phase I – Toxicity Characterization
- (2) Phase II – Toxicity Identification Procedures
- (3) Phase III – Toxicity Control Procedures
- (4) Any other appropriate procedures for toxicity source elimination and control.

PART I
DISCHARGE PERMIT NO. UT0025747

If the TRE establishes that the toxicity cannot be immediately eliminated, JSSDWRF shall submit a proposed compliance plan to the Director. The plan shall include the proposed approach to control toxicity and a proposed compliance schedule for achieving control. If the approach and schedule are acceptable to the Director, this permit may be reopened and modified.

If the TRE shows that the toxicity is caused by a toxicant(s) that may be controlled with specific numerical limitations, JSSDWRF may:

- (a) Submit an alternative control program for compliance with the numerical requirements.
- (b) If necessary, provide a modified biomonitoring protocol, which compensates for the pollutant(s) being controlled numerically.

If acceptable to the Director, this permit may be reopened and modified to incorporate any additional numerical limitations, a modified compliance schedule if judged necessary by the Director, and/or a modified biomonitoring protocol.

Failure to conduct an adequate TRE, or failure to submit a plan or program as described above, or the submittal of a plan or program judged inadequate by the Director, shall be considered a violation of this permit.

- D. Reporting of Wastewater Monitoring Results. Monitoring results obtained during the previous month shall be summarized for each month and reported on a Discharge Monitoring Report Form (EPA No. 3320-1), post-marked no later than the 28th day of the month following the completed reporting period. If no discharge occurs during the reporting period, "no discharge" shall be reported. Legible copies of these, and all other reports including whole effluent toxicity (WET) test reports required herein, shall be signed and certified in accordance with the requirements of *Signatory Requirements (see Part VII.G)*, and submitted to the Division of Water Quality at the following address:

Department of Environmental Quality
Division of Water Quality
PO Box 144870
Salt Lake City, Utah 84114-4870

**PART II
INDUSTRIAL PRETREATMENT**

II. INDUSTRIAL PRETREATMENT PROGRAM

A. Self-Monitoring and Reporting Requirements.

1. Because the design capacity of this municipal wastewater treatment facility is less than 5 MGD, JSSDWRF will not be required to develop a State-approved industrial pretreatment program at this time. However, in order to determine if development of an industrial pretreatment program is warranted, the JSSDWRF shall conduct an **industrial waste survey**, as described in *Part II.B.1*, and submit it to the Division of Water Quality within **sixty (60) calendar days** of the effective date of this permit and shall sample and analyze both the influent and effluent 2 x Year, for the following parameters.

Metals Monitoring for Pretreatment Program			
Parameter	Sample Type	Frequency	Units
Total Arsenic	Composite	2 x Year	mg/L
Total Cadmium			
Total Chromium			
Total Copper			
Total Cyanide			
Total Lead			
Total Mercury	Composite/Grab	2 x Year	mg/L
Total Molybdenum	Composite		
Total Nickel			
Total Selenium			
Total Silver			
Total Zinc			

The results of these analyses shall be submitted along with the Discharge Monitoring Report (DMR) at the end of that reporting period.

B. Industrial Wastes.

1. The "Industrial Waste Survey" as required by *Part II.A.1*. consists of; identifying each significant industrial user (SIU), determination of the qualitative and quantitative characteristics of each discharge, and appropriate production data. A (SIU) is defined as an industrial user discharging to a publicly-owned treatment works (POTW) that satisfies any of the following: (1) has a process wastewater flow of 25,000 gallons or more per average work day; (2) has a flow greater than five percent of the flow carried by the municipal system receiving the waste; (3) is subject to Categorical Pretreatment Standards, or (4) has a reasonable potential for adversely affecting the POTW's operation or for violating any pretreatment standard or requirement.
2. JSSDWRF must notify the Director of any new introductions by new or existing SIUs or any substantial change in pollutants from any major industrial source. Such notice must contain the information described in 1. above and be forwarded no later than sixty (60) days following the introduction or change.
3. Pretreatment Standards (*40 CFR 403.5*) developed pursuant to *Section 307 of The Water Quality Act of 1987* require that under no circumstances shall JSSDWRF allow

PART II
INDUSTRIAL PRETREATMENT

introduction of the following pollutants into the waste treatment system from any source of non-domestic discharge:

- a. Pollutants which create a fire or explosion hazard in the publicly owned treatment works (POTW), including, but not limited to, wastestreams with a closed cup flashpoint of less than 140°F (60°C);
 - b. Pollutants, which will cause corrosive structural damage to the POTW, but in no case, discharges with a pH lower than 5.0;
 - c. Solid or viscous pollutants in amounts which will cause obstruction to the flow in the POTW resulting in interference;
 - d. Any pollutant, including oxygen demanding pollutants (BOD, etc.) released in a discharge at such volume or strength as to cause interference in the POTW;
 - e. Heat in amounts, which will inhibit biological activity in the POTW, resulting in interference, but in no case, heat in such quantities that the influent to the sewage treatment works exceeds 104°F (40°C);
 - f. Petroleum oil, nonbiodegradable cutting oil, or products of mineral oil origin in amounts that will cause interference or pass through;
 - g. Pollutants which result in the presence of toxic gases, vapor, or fumes within the POTW in a quantity that may cause worker health or safety problems; or,
 - h. Any trucked or hauled pollutants, except at discharge points designated by the POTW.
 - i. Any pollutant that causes pass through or interference at the POTW.
4. In addition to the general and specific limitations expressed above, more specific pretreatment limitations have been and will be promulgated for specific industrial categories under *Section 307 of the Water Quality Act of 1987 as amended (WQA)*. (See *40 CFR, Subchapter N, Parts 400 through 500*, for specific information).
5. JSSDWRF shall provide adequate notice to the Director and the Division of Water Quality Industrial Pretreatment Coordinator of;
- a. Any new introduction of pollutants into the treatment works from an indirect discharger (i.e., industrial user) which would be subject to *Sections 301 or 306 of the WQA* if it were directly discharging those pollutants;
 - b. Any substantial change in the volume or character of pollutants being introduced into the treatment works by a source introducing pollutants into the treatment works at the time of issuance of the permit; and
 - c. For the purposes of this section, adequate notice shall include information on:
 - (1) The quality and quantity of effluent to be introduced into such treatment works; and,

PART II
INDUSTRIAL PRETREATMENT

- (2) Any anticipated impact of the change on the quantity or quality of effluent to be discharged from such publicly owned treatment works.
6. At such time as a specific pretreatment limitation becomes applicable to an industrial user of JSSDWRF, the Director may, as appropriate, do the following:
- a. Amend JSSDWRF's UPDES discharge permit to specify the additional pollutant(s) and corresponding effluent limitation(s) consistent with the applicable national pretreatment limitation;
 - b. Require JSSDWRF to specify, by ordinance, contract, or other enforceable means, the type of pollutant(s) and the maximum amount which may be discharged to JSSDWRF's facility for treatment. Such requirement shall be imposed in a manner consistent with the POTW program development requirements of the *General Pretreatment Regulations* at 40 CFR 403; and/or,
 - c. Require JSSDWRF to monitor its discharge for any pollutant, which may likely be discharged from the JSSDWRF's facility, should the industrial user fail to properly pretreat its waste.
7. The Director retains, at all times, the right to take legal action against the industrial user and/or the treatment works, in those cases where a permit violation has occurred because of the failure of an industrial user to discharge at an acceptable level. If JSSDWRF has failed to properly delineate maximum acceptable industrial contributor levels, the Director will look primarily to JSSDWRF as the responsible party.

III. BIOSOLIDS REQUIREMENTS

A. Biosolids Treatment and Disposal. The authorization to dispose of treated sewage provided under this permit is limited to those biosolids produced from the treatment works owned and operated by JSSDWRF. The treatment methods and disposal practices are specifically designated below.

1. Treatment. Biosolids produced at the JSSDWRF are stabilized with the activated sludge process with a retention time for approximately 14 days with an average temperature of 53°F (12°C). The biosolids are dewatered with a belt press.
2. Description of Biosolids Disposal Method. The biosolids will probably be disposed in a landfill; or may be hauled to a composting site at another location for further treatment¹, or may be hauled to a soil regeneration facility such as ET Technologies for final landfill cover at the Salt Lake County Landfill.
3. Changes in Treatment Systems and Disposal Practices. Should the JSSDWRF change their disposal methods or the biosolids generation and handling processes of the plant, JSSDWRF must notify the Director at least 180 days in advance. This includes, but is not limited to, the addition or removal of any biosolids treatment units (i.e., digesters, drying beds, belt presses, etc.) and/or any other change, which would require a major modification of the permit, and the permit would need to go through another public notice and public comment period.

For any biosolids that are land filled, the requirements in *Section 2.12* of the latest version of the *EPA Region VIII Biosolids Management Handbook* must be followed.

B. Specific Limitations and Self-Monitoring Requirements.

Minimum Frequency of Monitoring Based on Dry Metric Tons (DMT)	
Amount of Biosolids Disposed Per Year	Monitoring Frequency
> 0 to < 290 DMT	Once Per Year

Accordingly, JSSDWRF needs to monitor at least once per year.

1. All biosolids generated by this facility, that are disposed of in a landfill shall pass a paint filter test.
2. Vector Attraction Reduction Limitations
 - a. The mass of volatile solids in the biosolids shall be reduced by a minimum of 38 percent prior to disposal at the landfill.
 - b. The biosolids shall be covered daily with soil or another approved material.

C. Management Practices of Biosolids.

JSSDWRF shall inspect the disposal sites to prevent malfunctions and deterioration, operator errors and discharges which may cause or lead to the release of biosolids to the environment or a threat to human health. JSSDWRF must conduct these inspections often enough to identify problems in time to correct them before they harm human health or the environment. JSSDWRF shall keep an inspection log or summary including at least the date and time of inspection, the printed name and the handwritten signature of the inspector, a notation of observations made and the date and nature of any repairs or corrective action.

PART III
BIOSOLIDS PERMIT NO. UTL-025747

- D. Special Conditions on Biosolids Storage. Permanent storage of biosolids is prohibited. Biosolids shall not be temporarily stored for more than two years. Written permission to store biosolids for more than two years must be obtained from the Director. Storage of biosolids for more than two years will be allowed only if it is determined that significant treatment is occurring.

For biosolids or material derived from biosolids that are stored in piles for one year or longer, measures shall be taken to ensure that erosion (whether by wind or water) does not occur. However, best management practices should also be used for piles used for biosolids treatment. If a treatment pile is considered to have caused a problem, best management practices could be added as a requirement in the next permit renewal.

- E. Monitoring Procedures. Monitoring must be conducted according to test procedures approved under *40 CFR Part 503* unless other test procedures have been specified in this permit.
- F. Penalties for Tampering. The *Act* provides that any person who falsifies, tampers with, or knowingly renders inaccurate, any monitoring device or method required to be maintained under this permit shall, upon conviction, be punished by a fine of not more than \$10,000 per violation, or by imprisonment for not more than six months per violation, or by both.
- G. Reporting of Monitoring Results. JSSDWRF shall provide the results of all monitoring performed in accordance with Part III.B., and information on management practices, land application sites, site restrictions and certifications shall be provided no later than **February 19** of each year. Each report is for the previous calendar year. If no biosolids were applied to the land during the reporting period, "no biosolids were applied" shall be reported. Legible copies of these, and all other reports required herein, shall be signed and certified in accordance with the Signatory Requirements (see Part VII.G), and submitted to the Utah Division of Water Quality and the EPA at the following addresses:

Original to: Utah Division of Water Quality
Division of water Quality
P. O. Box 144870
Salt Lake City Utah, 84114-4870

Copy to: Biosolids Coordinator, 8P-W-P
U. S. Environmental Protection Agency
Region VIII
1595 Wynkoop St.
Denver, Colorado 80202-1129

- H. Additional Monitoring by the Permittee. If JSSDWRF monitors any pollutant more frequently than required by this permit, using test procedures approved under *40 CFR 503* or as specified in this permit, the results of this monitoring shall be included in the calculation and reporting of the data submitted on the Biosolids Report form. Such increased frequency shall also be indicated.
- I. Record keeping

If so notified by the Director JSSDWRF may be required to add additional record keeping if information provided indicates that this is necessary to protect public health and the environment.

2. JSSDWRF is required to keep the following information for at least 5 years:

- a. A description of how the vector attraction reduction requirements were met.
- b. The following certification statement:

"I certify under the penalty of law, the management practices in Part I.D. (if necessary) have been met. This determination has been made under my direction and supervision in accordance with the system designed to assure that qualified personnel properly gather and evaluate the information used to determine that the attraction reduction requirements were met. I am aware that there are significant penalties for false certification including the possibility of imprisonment."

3. Records of monitoring information shall include:

- a. The date, exact place, and time of sampling or measurements;
- b. The initials or name(s) of the individual(s) who performed the sampling or measurements;
- c. The date(s) analyses were performed;
- d. The time(s) analyses were initiated;
- e. The initials or name(s) of individual(s) who performed the analyses;
- f. References and written procedures, when available, for the analytical techniques or methods used; and,
- g. The results of such analyses, including the bench sheets, instrument readouts, computer disks or tapes, etc., used to determine these results.

4. JSSDWRF shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by this permit and records of all data used to complete the application for this permit for the life of the permit. Data collected on site, copies of Biosolids Report forms, and a copy of this UPDES biosolids-only permit must be maintained on site during the duration of activity at the permitted location.

J. Twenty-Four Hour Notice of Noncompliance Reporting.

1. JSSDWRF shall report any noncompliance including transportation accidents, spills, and uncontrolled runoff from biosolids transfer or land application sites which may seriously endanger health or the environment as soon as possible, but no later than 24 hours from the time JSSDWRF first became aware of the circumstances. The report shall be made to the State of Utah at (801) 538-6146 or (801) 536-4123 (24-hour answering machine).

PART III
BIOSOLIDS PERMIT NO. UTL-025747

2. A written submission shall also be provided within five days of the time that JSSDWRF becomes aware of the circumstances. The written submission shall contain:
 - a. A description of the noncompliance and its cause;
 - b. The period of noncompliance, including exact dates and times;
 - c. The estimated time noncompliance is expected to continue if it has not been corrected; and,
 - d. Steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance.
 3. The Director may waive the written report on a case-by-case basis if the oral report has been received within 24 hours by the Division of Water Quality, by phone, at (801) 538-6146.
 4. Reports shall be submitted to the addresses in Part III.G., Reporting of Monitoring Results.
- K. Other Noncompliance Reporting. Instances of noncompliance not required to be reported within 24 hours shall be reported at the time that monitoring reports for Part III.B. are submitted. The reports shall contain the information listed in Part III.J.
- L. Inspection and Entry. JSSDWRF shall allow the Director, or authorized representative thereof, upon the presentation of credentials and other documents as may be required by law, to:
1. Enter upon JSSDWRF's premises where a regulated facility or activity is located or conducted, or where records must be kept under the conditions of this permit;
 2. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit;
 3. Inspect at reasonable times any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this permit, including, but not limited to, biosolids treatment, collection, storage facilities or area, transport vehicles and containers, and land application sites; and,
 4. Sample or monitor at reasonable times, for the purpose of assuring permit compliance or as otherwise authorized by the Act, any substances or parameters at any location, including, but not limited to, digested biosolids before dewatering, dewatered biosolids, biosolids transfer or staging areas, any ground or surface waters at the land application sites, or biosolids, soils, or vegetation on the land application sites.
 5. JSSDWRF shall make the necessary arrangements with the landowner or leaseholder to obtain permission or clearance, so that the Director, or authorized representative thereof, upon the presentation of credentials and other documents as may be required by law, will be permitted to enter without delay for the purposes of performing their responsibilities.

IV. STORM WATER REQUIREMENTS.

- A. Coverage of This Section. The requirements listed under this section shall apply to storm water discharges. Storm water discharges from the following portions of the facility may be eligible for coverage under this permit: biosolids drying beds, haul or access roads on which transportation of biosolids may occur, grit screen cleaning areas, chemical loading, unloading and storage areas, salt or sand storage areas, vehicle or equipment storage and maintenance areas, or any other wastewater treatment device or system, used in the storage, treatment, recycling, and reclamation of municipal or domestic sewage, including lands dedicated to the disposal of sewage sludge that are located within the confines of the facility that may have a reasonable expectation to contribute to pollutants in a storm water discharge.
- B. Prohibition of Non-Storm Water Discharges. Except for discharges identified in *Part I.*, and discharges described below in this paragraph, non-storm water discharges are prohibited. The following non-storm water discharges may be authorized under this permit provided the non-storm water component of the discharge is in compliance with this section; discharges from fire fighting activities; fire hydrant flushing; potable water sources including waterline flushing; drinking fountain water; irrigation drainage and lawn watering; routine external building wash down water where detergents or other compounds have not been used in the process; pavement wash waters where spills or leaks of toxic or hazardous materials (including oils and fuels) have not occurred (unless all spilled material has been removed) and where detergents are not used; air conditioning condensate; uncontaminated compressor condensate; uncontaminated springs; uncontaminated ground water; and foundation or footing drains where flows are not contaminated with process materials such as solvents.
- C. Storm Water Pollution Prevention Plan Requirements. JSSDWRP must have (on site) or develop and implement a storm water pollution prevention plan as a condition of this permit.
1. Contents of the Plan. The plan shall include, at a minimum, the following items:
 - a. *Pollution Prevention Team.* Each plan shall identify a specific individual or individuals within the facility organization as members of a storm water Pollution Prevention Team who are responsible for developing the storm water pollution prevention plan and assisting the facility or plant manager in its implementation, maintenance, and revision. The plan shall clearly identify the responsibilities of each team member. The activities and responsibilities of the team shall address all aspects of the facility's storm water pollution prevention plan.
 - b. *Description of Potential Pollutant Sources.* Each plan shall provide a description of potential sources which may reasonably be expected to add significant amounts of pollutants to storm water discharges or which may result in the discharge of pollutants during dry weather from separate storm sewers draining the facility. Each plan shall identify all activities and significant materials, which may be reasonably expected to have the potential as a significant pollutant source. Each plan shall include, at a minimum:
 - (1) *Drainage.* A site map indicating drainage areas and storm water outfalls. For each area of the facility that generates storm water discharges associated with the waste water treatment related activity with a reasonable potential for containing significant amounts of pollutants, a prediction of the direction of flow and an identification of the types of pollutants that are likely to be present in storm water

PART IV
STORM WATER PERMIT NO. UTR000000

discharges associated with the activity. Factors to consider include the toxicity of the pollutant; quantity of chemicals used, produced or discharged; the likelihood of contact with storm water; and history of significant leaks or spills of toxic or hazardous pollutants. Flows with a significant potential for causing erosion shall be identified. The site map shall include but not be limited to:

- (a) Drainage direction and discharge points from all wastewater associated activities including but not limited to grit screen cleaning, bio-solids drying beds and transport, chemical/material loading, unloading and storage areas, vehicle maintenance areas, salt or sand storage areas.
 - (b) Location of any erosion and sediment control structure or other control measures utilized for reducing pollutants in storm water runoff.
 - (c) Location of bio-solids drying beds where exposed to precipitation or where the transportation of bio-solids may be spilled onto internal roadways or tracked off site.
 - (d) Location where grit screen cleaning or other routinely performed industrial activities are located and are exposed to precipitation.
 - (e) Location of any handling, loading, unloading or storage of chemicals or potential pollutants such as caustics, hydraulic fluids, lubricants, solvents or other petroleum products, or hazardous wastes and where these may be exposed to precipitation.
 - (f) Locations where any major spills or leaks of toxic or hazardous materials have occurred.
 - (g) Location of any sand or salt piles.
 - (h) Location of fueling stations or vehicle and equipment maintenance and cleaning areas that are exposed to precipitation.
 - (i) Location of receiving streams or other surface water bodies.
 - (j) Locations of outfalls and the types of discharges contained in the drainage areas of the outfalls.
- (2) *Inventory of Exposed Materials.* An inventory of the types of materials handled at the site that potentially may be exposed to precipitation. Such inventory shall include a narrative description of significant materials that have been handled, treated, stored or disposed in a manner to allow exposure to storm water between the time of 3 years prior to the effective date of this permit and the present; method and location of onsite storage or disposal; materials management practices employed to minimize contact of materials

PART IV
STORM WATER PERMIT NO. UTR000000

with storm water runoff between the time of 3 years prior to the effective date of this permit and the present; the location and a description of existing structural and nonstructural control measures to reduce pollutants in storm water runoff; and a description of any treatment the storm water receives.

- (3) *Spills and Leaks.* A list of significant spills and significant leaks of toxic or hazardous pollutants that occurred at areas that are exposed to precipitation or that otherwise drain to a storm water conveyance at the facility after the date of 3 years prior to the effective date of this permit. Such list shall be updated as appropriate during the term of the permit.
- (4) *Sampling Data.* A summary of existing discharge sampling data describing pollutants in storm water discharges from the facility, including a summary of sampling data collected during the term of this permit.
- (5) *Summary of Potential Pollutant Sources and Risk Assessment.* A narrative description of the potential pollutant sources from the following activities associated with treatment works: access roads/rail lines; loading and unloading operations; outdoor storage activities; material handling sites; outdoor vehicle storage or maintenance sites; significant dust or particulate generating processes; and onsite waste disposal practices. Specific potential pollutants shall be identified where known.
- (6) *Measures and Controls.* JSSDWRF shall develop a description of storm water management controls appropriate for the facility, and implement such controls. The appropriateness and priorities of controls in a plan shall reflect identified potential sources of pollutants at the facility. The description of storm water management controls shall address the following minimum components, including a schedule for implementing such controls:
 - (7) *Good Housekeeping.* All areas that may contribute pollutants to storm waters discharges shall be maintained in a clean, orderly manner. These are practices that would minimize the generation of pollutants at the source or before it would be necessary to employ sediment ponds or other control measures at the discharge outlets. Where applicable, such measures or other equivalent measures would include the following: sweepers and covered storage to minimize dust generation and storm runoff; conservation of vegetation where possible to minimize erosion; sweeping of haul roads, bio-solids access points, and exits to reduce or eliminate off site tracking; sweeping of sand or salt storage areas to minimize entrainment in storm water runoff; collection, removal, and proper disposal of waste oils and other fluids resulting from vehicle and equipment maintenance; other equivalent measures to address identified potential sources of pollution.
- (8) *Preventive Maintenance.* A preventive maintenance program shall involve timely inspection and maintenance of storm water

PART IV
STORM WATER PERMIT NO. UTR000000

management devices (e.g., cleaning oil/water separators, catch basins) as well as inspecting and testing facility equipment and systems to uncover conditions that could cause breakdowns or failures resulting in discharges of pollutants to surface waters, and ensuring appropriate maintenance of such equipment and systems.

- (9) *Spill Prevention and Response Procedures.* Areas where potential spills that can contribute pollutants to storm water discharges can occur, and their accompanying drainage points, shall be identified clearly in the storm water pollution prevention plan. Where appropriate, specifying material handling procedures, storage requirements, and use of equipment such as diversion valves in the plan should be considered. Procedures and equipment for cleaning up spills shall be identified in the plan and made available to the appropriate personnel.
- (10) *Inspections.* In addition to the comprehensive site evaluation required under paragraph (*Part IV.C.1.b.(16)*) of this section, qualified facility personnel shall be identified to inspect designated equipment and areas of the facility on a periodic basis. The following areas shall be included in all inspections: access roads/rail lines, equipment storage and maintenance areas (both indoor and outdoor areas); fueling; material handling areas, residual treatment, storage, and disposal areas; and wastewater treatment areas. A set of tracking or follow-up procedures shall be used to ensure that appropriate actions are taken in response to the inspections. Records of inspections shall be maintained. The use of a checklist developed by the facility is encouraged.
- (11) *Employee Training.* Employee training programs shall inform personnel responsible for implementing activities identified in the storm water pollution prevention plan or otherwise responsible for storm water management at all levels of responsibility of the components and goals of the storm water pollution prevention plan. Training should address topics such as spill response, good housekeeping and material management practices. The pollution prevention plan shall identify how often training will take place, but training should be held at least annually (once per calendar year). Employee training must, at a minimum, address the following areas when applicable to a facility: petroleum product management; process chemical management; spill prevention and control; fueling procedures; general good housekeeping practices; proper procedures for using fertilizers, herbicides and pesticides.
- (12) *Record keeping and Internal Reporting Procedures.* A description of incidents (such as spills, or other discharges), along with other information describing the quality and quantity of storm water discharges shall be included in the plan required under this part. Inspections and maintenance activities shall be documented and records of such activities shall be incorporated into the plan.
- (13) *Non-storm Water Discharges.*

PART IV
STORM WATER PERMIT NO. UTR000000

- (a) *Certification.* The plan shall include a certification that the discharge has been tested or evaluated for the presence of non-storm water discharges. The certification shall include the identification of potential significant sources of non-storm water at the site, a description of the results of any test and/or evaluation for the presence of non-storm water discharges, the evaluation criteria or testing method used, the date of any testing and/or evaluation, and the onsite drainage points that were directly observed during the test. Certifications shall be signed in accordance with *Part VII.G* of this permit.
- (b) *Exceptions.* Except for flows from fire-fighting activities, sources of non-storm water listed in *Part IV.B. (Prohibition of Non-storm Water Discharges)* of this permit that are combined with storm water discharges associated with industrial activity must be identified in the plan. The plan shall identify and ensure the implementation of appropriate pollution prevention measures for the non-storm water component(s) of the discharge.
- (c) *Failure to Certify.* Any facility that is unable to provide the certification required (testing for non-storm water discharges), must notify the *Director* within 180 days after the effective date of this permit. If the failure to certify is caused by the inability to perform adequate tests or evaluations, such notification shall describe: the procedure of any test conducted for the presence of non-storm water discharges; the results of such test or other relevant observations; potential sources of non-storm water discharges to the storm sewer; and why adequate tests for such storm sewers were not feasible. Non-storm water discharges to waters of the State, which are not, authorized by a *UPDES* permit are unlawful, and must be terminated.
- (14) *Sediment and Erosion Control.* The plan shall identify areas, which, due to topography, activities, or other factors, have a high potential for significant soil erosion, and identify structural, vegetative, and/or stabilization measures to be used to limit erosion.
- (15) *Management of Runoff.* The plan shall contain a narrative consideration of the appropriateness of traditional storm water management practices (practices other than those which control the generation or source(s) of pollutants) used to divert, infiltrate, reuse, or otherwise manage storm water runoff in a manner that reduces pollutants in storm water discharges from the site. The plan shall provide that measures that *JSSDWRF* determines to be reasonable and appropriate shall be implemented and maintained. The potential of various sources at the facility to contribute pollutants to storm water discharges associated with industrial activity *Part IV.C.1.b (Description of Potential Pollutant Sources)* of this permit] shall be considered when determining reasonable and appropriate measures. Appropriate measures or other equivalent measures may include:

PART IV
STORM WATER PERMIT NO. UTR000000

vegetative swales and practices, reuse of collected storm water (such as for a process or as an irrigation source), inlet controls (such as oil/water separators), snow management activities, infiltration devices, wet detention/retention devices and discharging storm water through the waste water facility for treatment.

(16) *Comprehensive Site Compliance Evaluation.* Qualified personnel shall conduct site compliance evaluations at appropriate intervals specified in the plan, but in no case less than once a year. Such evaluations shall provide:

(a) Areas contributing to a storm water discharge associated with industrial activity shall be visually inspected for evidence of, or the potential for, pollutants entering the drainage system. Measures to reduce pollutant loadings shall be evaluated to determine whether they are adequate and properly implemented in accordance with the terms of the permit or whether additional control measures are needed. Structural storm water management measures, sediment and erosion control measures, and other structural pollution prevention measures identified in the plan shall be observed to ensure that they are operating correctly. A visual inspection of equipment needed to implement the plan, such as spill response equipment, shall be made.

(b) Based on the results of the evaluation, the description of potential pollutant sources identified in the plan in accordance with *Part IV.C.1.b* (Description of Potential Pollutant Sources) of this section and pollution prevention measures and controls identified in the plan in accordance with *Part IV.C.1.b.(6)* (Measures and Controls) of this section shall be revised as appropriate within 2 weeks of such evaluation and shall provide for implementation of any changes to the plan in a timely manner, but in no case more than 12 weeks after the evaluation.

(c) A report summarizing the scope of the evaluation, personnel making the evaluation, the date(s) of the evaluation, major observations relating to the implementation of the storm water pollution prevention plan, and actions taken in accordance with paragraph *i.* (above) shall be made and retained as part of the storm water pollution prevention plan for at least 3 years after the date of the evaluation. The report shall identify any incidents of noncompliance. Where a report does not identify any incidents of noncompliance, the report shall contain a certification that the facility is in compliance with the storm water pollution prevention plan and this permit. The report shall be signed in accordance with *Part VII.G* (Signatory Requirements) of this permit.

(17) *Deadlines for Plan Preparation and Compliance.* JSSDWRF shall prepare and implement a plan in compliance with the provisions of this section within 270 days of the effective date of this

PART IV
STORM WATER PERMIT NO. UTR000000

permit. If JSSDWRF already has a plan, it shall be revised according to *Part IV.C.1.b.(16)*, Comprehensive Site Evaluation.

- (18) *Keeping Plans Current.* JSSDWRF shall amend the plan whenever there is a change in design, construction, operation, or maintenance, that has a significant effect on the potential for the discharge of pollutants to the waters of the state or if the storm water pollution prevention plan proves to be ineffective in eliminating or significantly minimizing pollutants from sources identified by the plan, or in otherwise achieving the general objective of controlling pollutants in storm water discharges associated with the activities at the facility.

D. Monitoring and Reporting Requirements.

1. Quarterly Visual Examination of Storm Water Quality. Facilities shall perform and document a visual examination of a storm water discharge associated with industrial activity from each outfall, except discharges exempted below. The examination must be made at least once in each of the following designated periods during daylight hours unless there is insufficient rainfall or snow melt to produce a runoff event: January through March; April through June; July through September; and October through December.
 - a. *Sample and Data Collection.* Examinations shall be made of samples collected within the first 30 minutes (or as soon thereafter as practical, but not to exceed 1 hour) of when the runoff or snowmelt begins discharging. The examinations shall document observations of color, odor, clarity, floating solids, settled solids, suspended solids, foam, oil sheen, and other obvious indicators of storm water pollution. The examination must be conducted in a well lit area. No analytical tests are required to be performed on the samples. All such samples shall be collected from the discharge resulting from a storm event that is greater than 0.1 inches in magnitude and that occurs at least 72 hours from the previously measurable (greater than 0.1 inch rainfall) storm event. Where practicable, the same individual should carry out the collection and examination of discharges for entire permit term.
 - b. *Visual Storm Water Discharge Examination Reports.* Visual examination reports must be maintained onsite in the pollution prevention plan. The report shall include the examination date and time, examination personnel, the nature of the discharge (i.e., runoff or snow melt), visual quality of the storm water discharge (including observations of color, odor, clarity, floating solids, settled solids, suspended solids, foam, oil sheen, and other obvious indicators of storm water pollution), and probable sources of any observed storm water contamination.
 - c. *Representative Discharge.* When JSSDWRF has two or more outfalls that, based on a consideration of industrial activity, significant materials, and management practices and activities within the area drained by the outfall, JSSDWRF reasonably believes discharge substantially identical effluents, JSSDWRF may collect a sample of effluent of one of such outfalls and report that the observation data also applies to the substantially identical outfall(s) provided that JSSDWRF includes in the storm water pollution prevention plan a description of the location of the outfalls and explains in detail why

PART IV
STORM WATER PERMIT NO. UTR000000

the outfalls are expected to discharge substantially identical effluents. In addition, for each outfall that JSSDWRF believes is representative, an estimate of the size of the drainage area (in square feet) and an estimate of the runoff coefficient of the drainage area [e.g., low (under 40 percent), medium (40 to 65 percent), or high (above 65 percent)] shall be provided in the plan.

- d. *Adverse Conditions.* When a discharger is unable to collect samples over the course of the visual examination period as a result of adverse climatic conditions, the discharger must document the reason for not performing the visual examination and retain this documentation onsite with the results of the visual examination. Adverse weather conditions, which may prohibit the collection of samples, include weather conditions that create dangerous conditions for personnel (such as local flooding, high winds, hurricane, tornadoes, electrical storms, etc.) or otherwise make the collection of a sample impracticable (drought, extended frozen conditions, etc.).
- e. *Inactive and Unstaffed Site.* When a discharger is unable to conduct visual storm water examinations at an inactive and unstaffed site, the operator of the facility may exercise a waiver of the monitoring requirement as long as the facility remains inactive and unstaffed. The facility must maintain a certification with the pollution prevention plan stating that the site is inactive and unstaffed so that performing visual examinations during a qualifying event is not feasible.

PART V
DISCHARGE PERMIT NO. UT0025747
BIOSOLIDS PERMIT NO. UTL-025747
STORM WATER PERMIT NO. UTR000000

V. MONITORING, RECORDING & GENERAL REPORTING REQUIREMENTS

- A. Representative Sampling. Samples taken in compliance with the monitoring requirements established under *Part I* shall be collected from the effluent stream prior to discharge into the receiving waters. Samples and measurements shall be representative of the volume and nature of the monitored discharge. Samples of biosolids shall be collected at a location representative of the quality of biosolids immediately prior to the use-disposal practice.
- B. Monitoring Procedures. Monitoring must be conducted according to test procedures approved under *Utah Administrative Code ("UAC") R317-2-10 and 40CFR Part 503*, unless other test procedures have been specified in this permit.
- C. Penalties for Tampering. The *Act* provides that any person who falsifies, tampers with, or knowingly renders inaccurate, any monitoring device or method required to be maintained under this permit shall, upon conviction, be punished by a fine of not more than \$10,000 per violation, or by imprisonment for not more than six months per violation, or by both.
- D. Compliance Schedules. Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any Compliance Schedule of this permit shall be submitted no later than 14 days following each schedule date.
- E. Additional Monitoring by the Permittee. If JSSDWRF monitors any parameter more frequently than required by this permit, using test procedures approved under *UAC R317-2-10 and 40 CFR 503* or as specified in this permit, the results of this monitoring shall be included in the calculation and reporting of the data submitted in the DMR or the Biosolids Report Form. Such increased frequency shall also be indicated. Only those parameters required by the permit need to be reported.
- F. Records Contents. Records of monitoring information shall include:
1. The date, exact place, and time of sampling or measurements;
 2. The individual(s) who performed the sampling or measurements;
 3. The date(s) and time(s) analyses were performed;
 4. The individual(s) who performed the analyses;
 5. The analytical techniques or methods used; and,
 6. The results of such analyses.
- G. Retention of Records. JSSDWRF shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by this permit, and records of all data used to complete the application for this permit, for a period of at least five years from the date of the sample, measurement, report or application. This period may be extended by request of the Director at any time. A copy of this UPDES permit must be maintained on site during the duration of activity at the permitted location
- H. Twenty-four Hour Notice of Noncompliance Reporting.
1. JSSDWRF shall (orally) report any noncompliance including transportation accidents, spills, and uncontrolled runoff from biosolids transfer or land application sites which may seriously endanger health or environment, as soon as possible, but no later than twenty-four (24) hours from the time JSSDWRF first became aware of

PART V
DISCHARGE PERMIT NO. UT0025747
BIOSOLIDS PERMIT NO. UTL-025747
STORM WATER PERMIT NO. UTR000000

circumstances. The report shall be made to the Division of Water Quality, (801) 538-6146, or 24-hour answering service (801) 536-4123.

2. The following occurrences of noncompliance shall be reported by telephone (801) 536-4123 as soon as possible but no later than 24 hours from the time JSSDWRf becomes aware of the circumstances:
 - a. Any noncompliance which may endanger health or the environment;
 - b. Any unanticipated bypass, which exceeds any effluent limitation in the permit (See *Part VI.G, Bypass of Treatment Facilities.*);
 - c. Any upset which exceeds any effluent limitation in the permit (See *Part VI.H, Upset Conditions.*);
 - d. Violation of a maximum daily discharge limitation for any of the pollutants listed in the permit; or,
 - e. Violation of any of the Table 3 metals limits, the pathogen limits, the vector attraction reduction limits or the management practices for biosolids that have been sold or given away.
 3. A written submission shall also be provided within five days of the time that JSSDWRf becomes aware of the circumstances. The written submission shall contain:
 - a. A description of the noncompliance and its cause;
 - b. The period of noncompliance, including exact dates and times;
 - c. The estimated time noncompliance is expected to continue if it has not been corrected;
 - d. Steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance; and,
 - e. Steps taken, if any, to mitigate the adverse impacts on the environment and human health during the noncompliance period.
 4. The Director may waive the written report on a case-by-case basis if the oral report has been received within 24 hours by the Division of Water Quality, (801) 538-6146.
 5. Reports shall be submitted to the addresses in *Part I.D, Reporting of Monitoring Results.*
- I. Other Noncompliance Reporting. Instances of noncompliance not required to be reported within 24 hours shall be reported at the time that monitoring reports for *Part I.D* are submitted. The reports shall contain the information listed in *Part V.H.3*
- J. Inspection and Entry JSSDWRf shall allow the Director, or an authorized representative, upon the presentation of credentials and other documents as may be required by law, to:

PART V
DISCHARGE PERMIT NO. UT0025747
BIOSOLIDS PERMIT NO. UTL-025747
STORM WATER PERMIT NO. UTR000000

1. Enter upon JSSDWRF's premises where a regulated facility or activity is located or conducted, or where records must be kept under the conditions of the permit;
2. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit;
3. Inspect at reasonable times any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this permit, including but not limited to, biosolids treatment, collection, storage facilities or area, transport vehicles and containers, and land application sites;
4. Sample or monitor at reasonable times, for the purpose of assuring permit compliance or as otherwise authorized by the *Act*, any substances or parameters at any location, including, but not limited to, digested biosolids before dewatering, dewatered biosolids, biosolids transfer or staging areas, any ground or surface waters at the land application sites or biosolids, soils, or vegetation on the land application sites; and,
5. JSSDWRF shall make the necessary arrangements with the landowner or leaseholder to obtain permission or clearance, the Director, or authorized representative, upon the presentation of credentials and other documents as may be required by law, will be permitted to enter without delay for the purposes of performing their responsibilities.

PART VI
DISCHARGE PERMIT NO. UT0025747
BIOSOLIDS PERMIT NO. UTL-025747
STORM WATER PERMIT NO. UTR000000

VI. COMPLIANCE RESPONSIBILITIES

- A. Duty to Comply. JSSDWRF must comply with all conditions of this permit. Any permit noncompliance constitutes a violation of the Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application. JSSDWRF shall give advance notice to the Director of any planned changes in the permitted facility or activity, which may result in noncompliance with permit requirements.
- B. Penalties for Violations of Permit Conditions. The Act provides that any person who violates a permit condition implementing provisions of the Act is subject to a civil penalty not to exceed \$10,000 per day of such violation. Any person who willfully or negligently violates permit conditions or the Act is subject to a fine not exceeding \$25,000 per day of violation. Any person convicted under UCA 19-5-115(2) a second time shall be punished by a fine not exceeding \$50,000 per day. Except as provided at Part VI.G, Bypass of Treatment Facilities and Part VI.H, Upset Conditions, nothing in this permit shall be construed to relieve JSSDWRF of the civil or criminal penalties for noncompliance.
- C. Need to Halt or Reduce Activity not a Defense. It shall not be a defense for JSSDWRF in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit.
- D. Duty to Mitigate. JSSDWRF shall take all reasonable steps to minimize or prevent any discharge in violation of this permit, which has a reasonable likelihood of adversely affecting human health or the environment. JSSDWRF shall also take all reasonable steps to minimize or prevent any land application in violation of this permit.
- E. Proper Operation and Maintenance. JSSDWRF shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by JSSDWRF to achieve compliance with the conditions of this permit. Proper operation and maintenance also includes adequate laboratory controls and quality assurance procedures. This provision requires the operation of back-up or auxiliary facilities or similar systems, which are installed by JSSDWRF only when the operation is necessary to achieve compliance with the conditions of the permit.
- F. Removed Substances. Collected screening, grit, solids, sludge, or other pollutants removed in the course of treatment shall be disposed of in such a manner so as to prevent any pollutant from entering any waters of the state or creating a health hazard. Sludge/digester supernatant and filter backwash shall not directly enter either the final effluent or waters of the state by any other direct route.
- G. Bypass of Treatment Facilities.

PART VI
DISCHARGE PERMIT NO. UT0025747
BIOSOLIDS PERMIT NO. UTL-025747
STORM WATER PERMIT NO. UTR000000

1. Bypass Not Exceeding Limitations. JSSDWRF may allow any bypass to occur which does not cause effluent limitations to be exceeded, but only if it also is for essential maintenance to assure efficient operation. These bypasses are not subject to paragraph 2 and 3 of this section.
2. Prohibition of Bypass.
 - a. Bypass is prohibited, and the Director may take enforcement action against JSSDWRF for bypass, unless:
 - (1) Bypass was unavoidable to prevent loss of human life, personal injury, or severe property damage;
 - (2) There were no feasible alternatives to bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate backup equipment should have been installed in the exercise of reasonable engineering judgement to prevent a bypass which occurred during normal periods of equipment downtime or preventive maintenance, and
 - (3) JSSDWRF submitted notices as required under *section VI.G.3.*
 - b. The Director may approve an anticipated bypass, after considering its adverse effects, if the Director determines that it will meet the three conditions listed in *sections VI.G.2.a (1), (2) and (3).*
3. Notice.
 - a. *Anticipated bypass.* Except as provided above in *section VI.G.2* and below in *section VI.G.3.b*, if JSSDWRF knows in advance of the need for a bypass, it shall submit prior notice, at least ninety days before the date of bypass. The prior notice shall include the following unless otherwise waived by the Director:
 - (1) Evaluation of alternative to bypass, including cost-benefit analysis containing an assessment of anticipated resource damages;
 - (2) A specific bypass plan describing the work to be performed including scheduled dates and times. JSSDWRF must notify the Director in advance of any changes to the bypass schedule;
 - (3) Description of specific measures to be taken to minimize environmental and public health impacts;

PART VI
DISCHARGE PERMIT NO. UT0025747
BIOSOLIDS PERMIT NO. UTL-025747
STORM WATER PERMIT NO. UTR000000

- (4) A notification plan sufficient to alert all downstream users, the public and others reasonably expected to be impacted by the bypass;
 - (5) A water quality assessment plan to include sufficient monitoring of the receiving water before, during and following the bypass to enable evaluation of public health risks and environmental impacts; and,
 - (6) Any additional information requested by the Director.
- b. *Emergency Bypass.* Where ninety days advance notice is not possible, JSSDWRF must notify the Director, and the Director of the Department of Natural Resources, as soon as it becomes aware of the need to bypass and provide to the Director the information in *section VI.G.3.a.(1) through (6)* to the extent practicable.
- c. *Unanticipated bypass.* JSSDWRF shall submit notice of an unanticipated bypass to the Director as required under *Part IV.H, Twenty Four Hour Reporting.* JSSDWRF shall also immediately notify the Director of the Department of Natural Resources, the public and downstream users and shall implement measures to minimize impacts to public health and environment to the extent practicable.

H. Upset Conditions.

- 1. Effect of an upset. An upset constitutes an affirmative defense to an action brought for noncompliance with technology based permit effluent limitations if the requirements of paragraph 2 of this section are met. The Director's administrative determination regarding a claim of upset cannot be judiciously challenged by JSSDWRF until such time as an action is initiated for noncompliance.
- 2. Conditions necessary for a demonstration of upset. A permittee who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed, contemporaneous operating logs, or other relevant evidence that:
 - a. An upset occurred and that JSSDWRF can identify the cause(s) of the upset;
 - b. The permitted facility was at the time being properly operated;
 - c. JSSDWRF submitted notice of the upset as required under *Part V.H, Twenty-four Hour Notice of Noncompliance Reporting*; and,

PART VI
DISCHARGE PERMIT NO. UT0025747
BIOSOLIDS PERMIT NO. UTL-025747
STORM WATER PERMIT NO. UTR000000

- d. JSSDWRF complied with any remedial measures required under *Part VI.D, Duty to Mitigate.*
3. Burden of proof. In any enforcement proceeding, JSSDWRF seeking to establish the occurrence of an upset has the burden of proof.

P/N DRAFT

PART VII
DISCHARGE PERMIT NO. UT0025747
BIOSOLIDS PERMIT NO. UTL-025747
STORM WATER PERMIT NO. UTR000000

VII. GENERAL REQUIREMENTS

- A. Planned Changes. JSSDWRF shall give notice to the Director as soon as possible of any planned physical alterations or additions to the permitted facility. Notice is required only when the alteration or addition could significantly change the nature or increase the quantity of parameters discharged or pollutant sold or given away. This notification applies to pollutants, which are not subject to effluent limitations in the permit. In addition, if there are any planned substantial changes to JSSDWRF's existing sludge facilities or their manner of operation or to current sludge management practices of storage and disposal, JSSDWRF shall give notice to the Director of any planned changes at least 30 days prior to their implementation.
- B. Anticipated Noncompliance. JSSDWRF shall give advance notice to the Director of any planned changes in the permitted facility or activity, which may result in noncompliance with permit requirements.
- C. Permit Actions. This permit may be modified, revoked and reissued, or terminated for cause. The filing of a request by JSSDWRF for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance, does not stay any permit condition.
- D. Duty to Reapply. If JSSDWRF wishes to continue an activity regulated by this permit after the expiration date of this permit, JSSDWRF shall apply for and obtain a new permit. The application shall be submitted at least 180 days before the expiration date of this permit.
- E. Duty to Provide Information. JSSDWRF shall furnish to the Director, within a reasonable time, any information which the Director may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit, or to determine compliance with this permit. JSSDWRF shall also furnish to the Director, upon request, copies of records required to be kept by this permit.
- F. Other Information. When JSSDWRF becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application or any report to the Director, it shall promptly submit such facts or information.
- G. Signatory Requirements. All applications, reports or information submitted to the Director shall be signed and certified.
1. All permit applications shall be signed by either a principal executive officer or ranking elected official.
 2. All reports required by the permit and other information requested by the Director shall be signed by a person described above or by a duly authorized representative of that person. A person is a duly authorized representative only if:

**PART VII
DISCHARGE PERMIT NO. UT0025747
BIOSOLIDS PERMIT NO. UTL-025747
STORM WATER PERMIT NO. UTR000000**

- a. The authorization is made in writing by a person described above and submitted to the Director, and,
 - b. The authorization specifies either an individual or a position having responsibility for the overall operation of the regulated facility, such as the position of plant manager, superintendent, position of equivalent responsibility, or an individual or position having overall responsibility for environmental matters. A duly authorized representative may thus be either a named individual or any individual occupying a named position.
3. Changes to authorization. If an authorization under *paragraph VII.G.2* is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization satisfying the requirements of *paragraph VII.G.2* must be submitted to the Director prior to or together with any reports, information, or applications to be signed by an authorized representative.
 4. Certification. Any person signing a document under this section shall make the following certification:

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."
- H. Penalties for Falsification of Reports. The *Act* provides that any person who knowingly makes any false statement, representation, or certification in any record or other document submitted or required to be maintained under this permit, including monitoring reports or reports of compliance or noncompliance shall, upon conviction be punished by a fine of not more than \$10,000.00 per violation, or by imprisonment for not more than six months per violation, or by both.
 - I. Availability of Reports. Except for data determined to be confidential under *UAC R317-8-3.2*, all reports prepared in accordance with the terms of this permit shall be available for public inspection at the office of Director. As required by the *Act*, permit applications, permits and effluent data shall not be considered confidential.
 - J. Oil and Hazardous Substance Liability. Nothing in this permit shall be construed to preclude JSSDWRF of any legal action or relieve JSSDWRF from any

PART VII
DISCHARGE PERMIT NO. UT0025747
BIOSOLIDS PERMIT NO. UTL-025747
STORM WATER PERMIT NO. UTR000000

responsibilities, liabilities, or penalties to which JSSDWRF is or may be subject under the *Act*.

- K. Property Rights. The issuance of this permit does not convey any property rights of any sort, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.
- L. Severability. The provisions of this permit are severable, and if any provisions of this permit, or the application of any provision of this permit to any circumstance, is held invalid, the application of such provision to other circumstances, and the remainder of this permit, shall not be affected thereby.
- M. Transfers. This permit may be automatically transferred to a new permittee if:
1. The current permittee notifies the Director at least 20 days in advance of the proposed transfer date;
 2. The notice includes a written agreement between the existing and new permittee's containing a specific date for transfer of permit responsibility, coverage, and liability between them; and,
 3. The Director does not notify the existing permittee and the proposed new permittee of his or her intent to modify, or revoke and reissue the permit. If this notice is not received, the transfer is effective on the date specified in the agreement mentioned in paragraph 2 above.
- N. State or Federal Laws. Nothing in this permit shall be construed to preclude the institution of any legal action or relieve JSSDWRF from any responsibilities, liabilities, or penalties established pursuant to any applicable state law or regulation under authority preserved by *UCA 19-5-117* and *Section 510* of the *Act* or any applicable Federal or State transportation regulations, such as but not limited to the Department of Transportation regulations.
- O. Water Quality - Reopener Provision. This permit may be reopened and modified (following proper administrative procedures) to include the appropriate effluent limitations and compliance schedule, if necessary, if one or more of the following events occurs:
1. Water Quality Standards for the receiving water(s) to which JSSDWRF discharges are modified in such a manner as to require different effluent limits than contained in this permit.
 2. A final wasteload allocation is developed and approved by the State and/or EPA for incorporation in this permit.

PART VII
DISCHARGE PERMIT NO. UT0025747
BIOSOLIDS PERMIT NO. UTL-025747
STORM WATER PERMIT NO. UTR000000

3. Revisions to the current CWA § 208 area wide treatment management plans or promulgations/revisions to TMDLs (40 CFR 130.7) approved by the EPA and adopted by DWQ which calls for different effluent limitations than contained in this permit.
- P. Biosolids – Reopener Provision. This permit may be reopened and modified (following proper administrative procedures) to include the appropriate biosolids limitations (and compliance schedule, if necessary), management practices, other appropriate requirements to protect public health and the environment, or if there have been substantial changes (or such changes are planned) in biosolids use or disposal practices; applicable management practices or numerical limitations for pollutants in biosolids have been promulgated which are more stringent than the requirements in this permit; and/or it has been determined that JSSDWRFs biosolids use or land application practices do not comply with existing applicable state of federal regulations.
- Q. Toxicity Limitation - Reopener Provision. This permit may be reopened and modified (following proper administrative procedures) to include, whole effluent toxicity (WET) limitations, a compliance date, a compliance schedule, a change in the whole effluent toxicity (biomonitoring) protocol, additional or modified numerical limitations, or any other conditions related to the control of toxicants if one or more of the following events occur;
1. Toxicity is detected, as per *Part I.C.3.a* and b of this permit, during the duration of this permit.
 2. The TRE results indicate that compliance with the toxic limits will require an implementation schedule past the date for compliance and the Director agrees with the conclusion.
 3. The TRE results indicate that the toxicant(s) represent pollutant(s) that may be controlled with specific numerical limits, and the Director agrees that numerical controls are the most appropriate course of action.
 4. Following the implementation of numerical control(s) of toxicant(s), the Director agrees that a modified biomonitoring protocol is necessary to compensate for those toxicant that are controlled numerically.
 5. The TRE reveals other unique conditions or characteristics, which in the opinion of the permit issuing authority justify the incorporation of unanticipated special conditions in the permit.
- R. Storm Water-Reopener Provision. At any time during the duration (life) of this permit, this permit may be reopened and modified (following proper administrative procedures) as per *UAC R317.8*, to include, any applicable storm water provisions and requirements, a storm water pollution prevention plan, a compliance schedule, a

PART VII
DISCHARGE PERMIT NO. UT0025747
BIOSOLIDS PERMIT NO. UTL-025747
STORM WATER PERMIT NO. UTR000000

compliance date, monitoring and/or reporting requirements, or any other conditions related to the control of storm water discharges to "waters-of-State".

PW DRAFT

PART VIII
DISCHARGE PERMIT NO. UT0025747
BIOSOLIDS PERMIT NO. UTL-025747
STORM WATER PERMIT NO. UTR000000

VIII. DEFINITIONS

A. Wastewater.

1. The "7-day (and weekly) average", other than for e-coli bacteria, fecal coliform bacteria, and total coliform bacteria, is the arithmetic average of all samples collected during a consecutive 7-day period or calendar week, whichever is applicable. Geometric means shall be calculated for e-coli bacteria, fecal coliform bacteria, and total coliform bacteria. The 7-day and weekly averages are applicable only to those effluent characteristics for which there are 7-day average effluent limitations. The calendar week, which begins on Sunday and ends on Saturday, shall be used for purposes of reporting self-monitoring data on discharge monitoring report forms. Weekly averages shall be calculated for all calendar weeks with Saturdays in the month. If a calendar week overlaps two months (i.e., the Sunday is in one month and the Saturday in the following month), the weekly average calculated for that calendar week shall be included in the data for the month that contains Saturday.
2. The "30-day (and monthly) average," other than for e-coli bacteria, fecal coliform bacteria and total coliform bacteria, is the arithmetic average of all samples collected during a consecutive 30-day period or calendar month, whichever is applicable. Geometric means shall be calculated for e-coli bacteria, fecal coliform bacteria and total coliform bacteria. The calendar month shall be used for purposes of reporting self-monitoring data on discharge monitoring report forms.
3. "Act," means the *Utah Water Quality Act*.
4. "Acute toxicity" occurs when 50 percent or more mortality is observed for either test species at any effluent concentration.
5. "Bypass," means the diversion of waste streams from any portion of a treatment facility.
6. "Chronic toxicity" occurs when the survival, growth, or reproduction for either test species exposed to a dilution of 25 percent effluent (or lower) is significantly less (at the 95 percent confidence level) than the survival, growth, or reproduction of the control specimens.
7. "Composite Samples" shall be flow proportioned. The composite sample shall, as a minimum, contain at least four (4) samples collected over the compositing period. Unless otherwise specified, the time between the collection of the first sample and the last sample shall not be less than six (6) hours nor more than 24 hours. Acceptable methods for preparation of composite samples are as follows:
 - a. Constant time interval between samples, sample volume proportional to flow rate at time of sampling;

PART VIII
DISCHARGE PERMIT NO. UT0025747
BIOSOLIDS PERMIT NO. UTL-025747
STORM WATER PERMIT NO. UTR000000

- b. Constant time interval between samples, sample volume proportional to total flow (volume) since last sample. For the first sample, the flow rate at the time the sample was collected may be used;
 - c. Constant sample volume, time interval between samples proportional to flow (i.e., sample taken every "X" gallons of flow); and,
 - d. Continuous sample volume, with sample collection rate proportional to flow rate.
8. "CWA," means *The Federal Water Pollution Control Act*, as amended, by *The Clean Water Act of 1987*.
9. "Daily Maximum" (Daily Max.) is the maximum value allowable in any single sample or instantaneous measurement.
10. "EPA," means the United States Environmental Protection Agency.
11. "Director," means Director of the Utah Division of Water Quality.
12. A "grab" sample, for monitoring requirements, is defined as a single "dip and take" sample collected at a representative point in the discharge stream.
13. An "instantaneous" measurement, for monitoring requirements, is defined as a single reading, observation, or measurement.
14. "Severe Property Damage," means substantial physical damage to property, damage to the treatment facilities which causes them to become inoperable, or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production.
15. "Upset," means an exceptional incident in which there is unintentional and temporary noncompliance with technology-based permit effluent limitations because of factors beyond the reasonable control of the permittee. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventative maintenance, or careless or improper operation.

B. Biosolids.

- 1. "Biosolids," means any material or material derived from sewage solids that have been biologically treated.
- 2. "Dry Weight-Basis," means 100 percent solids (i.e. zero percent moisture).

PART VIII
DISCHARGE PERMIT NO. UT0025747
BIOSOLIDS PERMIT NO. UTL-025747
STORM WATER PERMIT NO. UTR000000

3. "Land Application" is the spraying or spreading of biosolids onto the land surface; the injection of biosolids below the land surface; or the incorporation of biosolids into the land so that the biosolids can either condition the soil or fertilize crops or vegetation grown in the soil. Land application includes distribution and marketing (i.e. the selling or giving away of the biosolids).
4. "Pathogen," means an organism that is capable of producing an infection or disease in a susceptible host.
5. "Pollutant" for the purposes of this permit is an organic substance, an inorganic substance, a combination of organic and inorganic substances, or pathogenic organisms that after discharge and upon exposure, ingestion, inhalation, or assimilation into an organism either directly from the environment or indirectly by ingestion through the food-chain, could on the basis of information available to the Administrator of EPA, cause death, disease, behavioral abnormalities, cancer, genetic mutations, physiological malfunctions (including malfunction in reproduction), or physical deformations in either organisms or offspring of the organisms.
6. "Runoff" is rainwater, leachate, or other liquid that drains over any part of a land surface and runs off the land surface.
7. "Similar Container" is either an open or closed receptacle. This includes, but is not limited to, a bucket, a box, a carton, and a vehicle or trailer with a load capacity of one metric ton or less.
8. "Total Solids" are the materials in the biosolids that remain as a residue if the biosolids are dried at 103° or 105° Celsius.
9. "Treatment Works" are either federally owned, publicly owned, or privately owned devices or systems used to treat (including recycling and reclamation) either domestic sewage or a combination of domestic sewage and industrial waste or liquid manure.
10. "Vector Attraction" is the characteristic of biosolids that attracts rodents, flies, mosquitos or other organisms capable of transporting infectious agents.
11. "Animals" for the purpose of this permit are domestic livestock.
12. "Annual Whole Sludge Application Rate" is the amount of sewage sludge (dry-weight basis) that can be applied to a unit area of land during a cropping cycle.
13. "Agronomic Rate" is the whole sludge application rate (dry-weight basis) designed to:
(1) provide the amount of nitrogen needed by the crop or vegetation grown on the land; and
(2) minimize the amount of nitrogen in the sewage sludge that passes below the root zone of the crop or vegetation grown on the land to the ground water.

PART VIII
DISCHARGE PERMIT NO. UT0025747
BIOSOLIDS PERMIT NO. UTL-025747
STORM WATER PERMIT NO. UTR000000

14. "Annual Pollutant Loading Rate" is the maximum amount of a pollutant (dry-weight basis) that can be applied to a unit area of land during a 365-day period.
15. "Application Site or Land Application Site" means all contiguous areas of a users' property intended for sludge application.
16. "Cumulative Pollutant Loading Rate" is the maximum amount of an inorganic pollutant (dry-weight basis) that can be applied to a unit area of land.
17. "Grit and Screenings" are sand, gravel, cinders, other materials with a high specific gravity and relatively large materials such as rags generated during preliminary treatment of domestic sewage at a treatment works and shall be disposed of according to *40 CFR 258*.
18. "High Potential for Public Contact Site" is land with a high potential for contact by the public. This includes, but is not limited to, public parks, ball fields, cemeteries, plant nurseries, turf farms, and golf courses.
19. "Low Potential for Public Contact Site" is the land with a low potential for contact by the public. This includes, but is not limited to, farms, ranches, reclamation areas, and other lands which are private lands, restricted public lands, or lands which are not generally accessible to or used by the public.
20. "Monthly Average" is the arithmetic mean of all measurements taken during the month.
21. "Volatile Solids" is the amount of the total solids in sewage sludge lost when the sludge is combusted at 550 degrees Celsius for 15-20 minutes in the presence of excess air.

C. Storm Water.

1. "Best Management Practices" ("BMPs") means schedules of activities, prohibitions of practices, maintenance procedures, and other management practices to prevent or reduce the pollution of waters of the State. BMPs also include treatment requirements, operating procedures, and practices to control facility site runoff, spillage or leaks, sludge or waste disposal, or drainage from raw material storage.
2. "Coal pile runoff" means the rainfall runoff from or through any coal storage pile.
3. "Co-located industrial activity" means when a facility has industrial activities being conducted onsite that are described under more than one of the coverage sections of *Appendix II* in the General Multi-Sector Permit for Storm Water Discharges Associated with Industrial Activity. Facilities with co-located industrial activities shall comply with all applicable monitoring and pollution prevention plan requirements of each section in which a co-located industrial activity is described.

PART VIII
DISCHARGE PERMIT NO. UT0025747
BIOSOLIDS PERMIT NO. UTL-025747
STORM WATER PERMIT NO. UTR000000

4. "Commercial Treatment and Disposal Facilities" means facilities that receive, on a commercial basis, any produced hazardous waste (not their own) and treat or dispose of those wastes as a service to the generators. Such facilities treating and/or disposing exclusively residential hazardous wastes are not included in this definition.
5. "Landfill" means an area of land or an excavation in which wastes are placed for permanent disposal, and that is not a land application unit, surface impoundment, injection well, or waste pile.
6. "Land application unit" means an area where wastes are applied onto or incorporated into the soil surface (excluding manure spreading operations) for treatment or disposal.
7. "Municipal separate storm sewer system" (large and/or medium) means all municipal separate storm sewers that are either:
 - a. Located in an incorporated place (city) with a population of 100,000 or more as determined by the latest Decennial Census by the Bureau of Census (at the issuance date of this permit, Salt Lake City is the only city in Utah that falls in this category); or
 - b. Located in the counties with unincorporated urbanized populations of 100,000 or more, except municipal separate storm sewers that are located in the incorporated places, townships or towns within such counties (at the issuance date of this permit Salt Lake County is the only county that falls in this category); or
 - c. Owned or operated by a municipality other than those described in paragraph *a.* or *b.* (above) and that are designated by the *Director* as part of the large or medium municipal separate storm sewer system.
8. "NOI" means "notice of intent", it is an application form that is used to obtain coverage under the General Multi-Sector Permit for Storm Water Discharges Associated with Industrial Activity.
9. "NOT" means "notice of termination", it is a form used to terminate coverage under the General Multi-Sector Permit for Storm Water Discharges Associated with Industrial Activity.
10. "Point source" means any discernible, confined, and discrete conveyance, including but not limited to, any pipe, ditch, channel, tunnel, conduit, well, discrete fissure, container, rolling stock, concentrated animal feeding operation, landfill leachate collection system, vessel or other floating craft from which pollutants are or may be discharged. This term does not include return flows from irrigated agriculture or agricultural storm water runoff.

PART VIII
DISCHARGE PERMIT NO. UT0025747
BIOSOLIDS PERMIT NO. UTL-025747
STORM WATER PERMIT NO. UTR000000

11. "Section 313 water priority chemical" means a chemical or chemical categories that:
- a. Are listed at *40 CFR 372.65* pursuant to *Section 313* of the *Emergency Planning and Community Right-to-Know Act (EPCRA)* (also known as *Title III of the Superfund Amendments and Reauthorization Act (SARA)* of 1986);
 - b. Are present at or above threshold levels at a facility subject to *EPCRA Section 313* reporting requirements; and
 - c. Meet at least one of the following criteria:
 - (1) Are listed in *Appendix D* of *40 CFR Part 122* on either Table II (organic priority pollutants), Table III (certain metals, cyanides, and phenols) or Table V (certain toxic pollutants and hazardous substances);
 - (2) Are listed as a hazardous substance pursuant to *Section 311(b)(2)(A)* of the *CWA* at *40 CFR 116.4*; or
 - (3) Are pollutants for which EPA has published acute or chronic water quality criteria. See *Appendix III* of this permit. This appendix was revised based on final rulemaking EPA published in the *Federal Register* November 30, 1994.
12. "Significant materials" includes, but is not limited to: raw materials; fuels; materials such as solvents, detergents, and plastic pellets; finished materials such as metallic products; raw materials used in food processing or production; hazardous substances designated under *Section 101(14)* of *CERCLA*; any chemical the facility is required to report pursuant to *EPCRA Section 313*; fertilizers; pesticides; and waste products such as ashes, slag and sludge that have the potential to be released with storm water discharges.
13. "Significant spills" includes, but is not limited to: releases of oil or hazardous substances in excess of reportable quantities under *Section 311 of the Clean Water Act* (see *40 CFR 110.10* and *CFR 117.21*) or *Section 102* of *CERCLA* (see *40 CFR 302.4*).
14. "Storm water" means storm water runoff, snowmelt runoff, and surface runoff and drainage.
15. "SWDMR" means "storm water discharge monitoring report", a report of the results of storm water monitoring required by the permit. The Division of Water Quality provides the storm water discharge monitoring report form.

PART VIII
DISCHARGE PERMIT NO. UT0025747
BIOSOLIDS PERMIT NO. UTL-025747
STORM WATER PERMIT NO. UTR000000

16. "Storm water associated with industrial activity" (*UAC R317-8-3.8(6)(c) & (d)*) means the discharge from any conveyance that is used for collecting and conveying storm water and that is directly related to manufacturing, processing or raw materials storage areas at an industrial plant. The term does not include discharges from facilities or activities excluded from the *UPDES* program. For the categories of industries identified in paragraphs (*a*) through (*j*) of this definition, the term includes, but is not limited to, storm water discharges from industrial plant yards; immediate access roads and rail lines used or traveled by carriers of raw materials, manufactured products, waste material, or by-products used or created by the facility; material handling sites; refuse sites; sites used for the application or disposal of process waste waters (as defined in *40 CFR Part 401*); sites used for the storage and maintenance of material handling equipment; sites used for residual treatment, storage, or disposal; shipping and receiving areas; manufacturing buildings; storage areas (including tank farms) for raw materials, and intermediate and finished products; and areas where industrial activity has taken place in the past and significant materials remain and are exposed to storm water. For the categories of industries identified in paragraph (*k*) of this definition, the term includes only storm water discharges from all areas (except access roads and rail lines) listed in the previous sentence where material handling equipment or activities, raw materials, intermediate products, final products, waste materials, by-products, or industrial machinery are exposed to storm water. For the purposes of this paragraph, material handling activities include the storage, loading and unloading, transportation, or conveyance of any raw material, intermediate product, finished product, by-product or waste product. The term excludes areas located on plant lands separate from the plant's industrial activities, such as office buildings and accompanying parking lots as long as the drainage from the excluded areas is not mixed with storm water drained from the above described areas. Industrial facilities (including industrial facilities that are Federally, State, or municipally owned or operated that meet the description of the facilities listed in paragraphs (*a*) to (*k*) of this definition) include those facilities designated under *UAC R317-8-3.8(1)(a)5*. The following categories of facilities are considered to be engaging in "industrial activity" for purposes of this subsection:
- a. Facilities subject to storm water effluent limitations guidelines, new source performance standards, or toxic pollutant effluent standards under *40 CFR Subchapter N* (except facilities with toxic pollutant effluent standards that are exempted under category (*k*) of this definition);
 - b. Facilities classified as Standard Industrial Classifications 24 (except 2434), 26 (except 265 and 267), 28 (except 283 and 285), 29, 311, 32 (except 323), 33, 3441, 373;
 - c. Facilities classified as Standard Industrial Classifications 10 through 14 (mineral industry) including active or inactive mining operations (except for areas of coal mining operations no longer meeting the definition of a reclamation area under *40 CFR 434.11(l)* because the performance bond issued to the facility by the appropriate SMCRA authority has been released,

PART VIII
DISCHARGE PERMIT NO. UT0025747
BIOSOLIDS PERMIT NO. UTL-025747
STORM WATER PERMIT NO. UTR000000

or except for areas of non-coal mining operations that have been released from applicable State or Federal reclamation requirements after December 17, 1990) and oil and gas exploration, production, processing, or treatment operations, or transmission facilities that discharge storm water contaminated by contact with or that has come into contact with, any overburden, raw material, intermediate products, finished products, byproducts or waste products located on the site of such operations; inactive mining operations are mining sites that are not being actively mined, but that have an identifiable owner/operator;

- d. Hazardous waste treatment, storage, or disposal facilities, including those that are operating under interim status or a permit under Subtitle C of RCRA;
- e. Landfills, land application sites, and open dumps that have received any industrial wastes (waste that is received from any of the facilities described under this subsection) including those that are subject to regulation under *Subtitle D of RCRA*;
- f. Facilities involved in the recycling of materials, including metal scrapyards, battery reclaimers, salvage yards, and automobile junkyards, including but limited to those classified as Standard Industrial Classification 5015 and 5093;
- g. Steam electric power generating facilities, including coal handling sites;
- h. Transportation facilities classified as Standard Industrial Classifications 40, 41, 42 (except 4221-25), 43, 44, 45 and 5171 that have vehicle maintenance shops, equipment cleaning operations, or airport deicing operations. Only those portions of the facility that are either involved in vehicle maintenance (including vehicle rehabilitation, mechanical repairs, painting, fueling, and lubrication), equipment cleaning operations, airport deicing operations, or that are otherwise identified under paragraphs (a) to (g) or (l) to (k) of this subsection are associated with industrial activity;
- i. Treatment works treating domestic sewage or any other sewage sludge or wastewater treatment device or system, used in the storage treatment, recycling, and reclamation of municipal or domestic sewage, including land dedicated to the disposal of sewage sludge that are located within the confines of the facility, with a design flow of 1.0 MGD or more, or required to have an approved pretreatment program under *40 CFR Part 403*. Not included are farm lands, domestic gardens or lands used for sludge management where sludge is beneficially reused and that are not physically located in the confines of the facility, or areas that are in compliance with *40 CFR Part 503*;

PART VIII
DISCHARGE PERMIT NO. UT0025747
BIOSOLIDS PERMIT NO. UTL-025747
STORM WATER PERMIT NO. UTR000000

- j. Construction activity including clearing, grading and excavation activities except: operations that result in the disturbance of less than 5 acres of total land area that are not part of a larger common plan of development or sale;
 - k. Facilities under Standard Industrial Classifications 20, 21, 22, 23, 2434, 25, 265, 267, 27, 283, 285, 30, 31 (except 311), 323, 34 (except 3441), 35, 36, 37 (except 373), 38, 39, 4221-25, (and that are not otherwise included within categories (a) to (j))
17. "Waste pile" means any non-containerized accumulation of solid, non-flowing waste that is used for treatment or storage.

P/N DRAFT

