



State of Utah

GARY R. HERBERT
Governor

SPENCER J. COX
Lieutenant Governor

Department of
Environmental Quality

Alan Matheson
Executive Director

DIVISION OF WATER QUALITY
Walter L. Baker, P.E.
Director

December 7, 2015

DIVISION OF WATER QUALITY
UTAH DEPARTMENT OF ENVIRONMENTAL QUALITY
PUBLIC NOTICE TO REISSUE A UPDES PERMIT

PURPOSE OF PUBLIC NOTICE

THE PURPOSE OF THIS PUBLIC NOTICE IS TO DECLARE THE STATE OF UTAH'S INTENTION TO REISSUE A UTAH POLLUTANT DISCHARGE ELIMINATION SYSTEM (UPDES) PERMIT UNDER AUTHORITY OF THE UTAH WATER POLLUTION CONTROL ACT, SECTION 19-5-104(9) AND 107(2), UTAH CODE ANNOTATED 1953, AS AMENDED. SAID "PERMIT" REFERS TO THE UPDES PERMIT AND THE FACT SHEET STATEMENT OF BASIS (INCLUDING TOTAL MAXIMUM DAILY LOADS (TMDL'S)) IF APPLICABLE, AS PER SECTION 303(D) OF THE FEDERAL CLEAN WATER ACT (CWA)].

PERMIT INFORMATION

PERMITTEE NAME:	Orem Water Reclamation Facility
MAILING ADDRESS:	1797 West 1000 South, Orem, UT 84058
TELEPHONE NUMBER:	801-229-7471
FACILITY LOCATION:	1797 West 1000 South, Orem, UT 84058
UPDES PERMIT NO.:	UT0020915
PERMITTED OUTFALLS:	001A
RECEIVING WATER:	Powell Slough and thence Utah Lake

BACKGROUND

The facility serves the City of Orem, the City of Lindon, and a portion of the Town of Vineyard. The average design flow is 13.5 MGD, with a design population equivalent of 135,000. The facility is located at 1797 West 1000 South in Orem City, Utah County, Utah latitude 40°16'39" and longitude 111°44'19", with STORET Number 499525. The City of Orem has modified the disinfection at the wastewater treatment plant from chlorine to UV. Due to the modification, the City of Orem will no longer be required to sample for chlorine. Orem's City permit includes Pretreatment, Biosolids and Storm Water components.

PUBLIC COMMENTS

Public comments are invited any time prior to the deadline of the close of business on January 6, 2016. Written public comments can be submitted to: Jennifer Robinson, UPDES Surface Water Section, Utah Division of Water Quality, P.O. Box 144870, Salt Lake City, Utah 84114-4870 or by email at: jenrobinson@utah.gov. After considering public comment the Utah Division of Water Quality may execute the permit issuance, revise it, or abandon it. The permit is available for public review under <http://www.deq.utah.gov/NewsNotices/notices/water/index.htm>. If internet access is not available, a copy may be obtained by calling Jennifer Robinson at 801-536-4383.